



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

DOH Accreditation No.03-014-1820-LW-2 Valid until December 2020
DENR C.R.No. 074/2018 Valid until September 24, 2021

TEST REPORT

Client: **Manila Water Philippine Ventures (MWPV)**

Test Report No.: **TR-21A-126A**

Address: **Level 3 2nd Phase, BPO Bldg., UP Town Corporate Center, 216 Katipunan Ave., Diliman, Quezon City**

Date and Time Received: **06 Jan 2021 @04:30PM**

Contact Person: **Ms. Florisza I. Faustino**

Sampled By: **ECEM**

COC Number: **2021-A0047**

Report Date: **13 Jan 2021**

Sample ID:	S21-A06-034D	Sampling Date:	06 Jan 2021
Sample Description:	N5	Sampling Time:	09:00 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Jan 2021 @04:58PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @04:58PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	06 Jan 2021 @06:29PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @04:58PM	AHP

Sample ID:	S21-A06-035D	Sampling Date:	06 Jan 2021
Sample Description:	SRCC Boston	Sampling Time:	09:28 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Jan 2021 @05:01PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:01PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	06 Jan 2021 @06:29PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:01PM	AHP

Sample ID:	S21-A06-036D	Sampling Date:	06 Jan 2021
Sample Description:	N4	Sampling Time:	09:35 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Jan 2021 @05:04PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:04PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	06 Jan 2021 @06:29PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:04PM	AHP

Sample ID:	S21-A06-037D	Sampling Date:	06 Jan 2021
Sample Description:	N7	Sampling Time:	09:45 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Jan 2021 @05:07PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:07PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	06 Jan 2021 @06:29PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:07PM	AHP

Sample ID:	S21-A06-038D	Sampling Date:	06 Jan 2021
Sample Description:	Reservoir 1	Sampling Time:	09:50 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Jan 2021 @05:10PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:10PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	06 Jan 2021 @06:29PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:10PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID:	S21-A06-039D	Sampling Date:	06 Jan 2021
Sample Description:	Mr. Gregorio Residence	Sampling Time:	10:00 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Jan 2021 @05:13PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:13PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	06 Jan 2021 @06:29PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:13PM	AHP

Sample ID:	S21-A06-040D	Sampling Date:	06 Jan 2021
Sample Description:	N2	Sampling Time:	10:07 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Jan 2021 @05:16PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:16PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	06 Jan 2021 @06:29PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:16PM	AHP

Sample ID:	S21-A06-041D	Sampling Date:	06 Jan 2021
Sample Description:	N1	Sampling Time:	10:12 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Jan 2021 @05:19PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:19PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	06 Jan 2021 @06:29PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:19PM	AHP

Sample ID:	S21-A06-042D	Sampling Date:	06 Jan 2021
Sample Description:	N3	Sampling Time:	10:18 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Jan 2021 @05:22PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:22PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	06 Jan 2021 @06:29PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:22PM	AHP

Sample ID:	S21-A06-043D	Sampling Date:	06 Jan 2021
Sample Description:	Deepwell 7	Sampling Time:	10:22 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Jan 2021 @05:25PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:25PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	06 Jan 2021 @06:29PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:25PM	AHP

Sample ID:	S21-A06-044D	Sampling Date:	06 Jan 2021
Sample Description:	BNC Pawikan	Sampling Time:	10:51 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Jan 2021 @05:28PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:28PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	06 Jan 2021 @06:29PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:28PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID:	S21-A06-045D	Sampling Date:	06 Jan 2021
Sample Description:	Deepwell 6	Sampling Time:	10:39 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Jan 2021 @05:31PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:31PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	06 Jan 2021 @06:29PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:31PM	AHP

Sample ID:	S21-A06-046D	Sampling Date:	06 Jan 2021
Sample Description:	BNC Backdoor	Sampling Time:	10:52 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Jan 2021 @05:34PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:34PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	06 Jan 2021 @06:29PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:34PM	AHP

Sample ID:	S21-A06-047D	Sampling Date:	06 Jan 2021
Sample Description:	Villas	Sampling Time:	10:58 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Jan 2021 @05:37PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:37PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	06 Jan 2021 @06:29PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:37PM	AHP

Sample ID:	S21-A06-048D	Sampling Date:	06 Jan 2021
Sample Description:	Beechcroft	Sampling Time:	11:03 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Jan 2021 @05:40PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:40PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	06 Jan 2021 @06:29PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:40PM	AHP

Sample ID:	S21-A06-049D	Sampling Date:	06 Jan 2021
Sample Description:	Sports Center Common Area	Sampling Time:	11:15 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Jan 2021 @05:43PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:43PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	06 Jan 2021 @06:29PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:43PM	AHP

Sample ID:	S21-A06-050D	Sampling Date:	06 Jan 2021
Sample Description:	Sports Center Kitchen	Sampling Time:	11:17 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Jan 2021 @05:46PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:46PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	06 Jan 2021 @06:29PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:46PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID:	S21-A06-051D	Sampling Date:	06 Jan 2021
Sample Description:	Golf Kitchen	Sampling Time:	11:40 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Jan 2021 @05:49PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:49PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	06 Jan 2021 @06:29PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:49PM	AHP

Sample ID:	S21-A06-052D	Sampling Date:	06 Jan 2021
Sample Description:	Caddie	Sampling Time:	11:46 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Jan 2021 @05:52PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:52PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	06 Jan 2021 @06:29PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:52PM	AHP

Sample ID:	S21-A06-053D	Sampling Date:	06 Jan 2021
Sample Description:	Deepwell 5	Sampling Time:	11:49 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Jan 2021 @05:55PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:55PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	06 Jan 2021 @06:29PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:55PM	AHP

Sample ID:	S21-A06-054D	Sampling Date:	06 Jan 2021
Sample Description:	Deepwell 8	Sampling Time:	11:50 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Jan 2021 @05:58PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:58PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	06 Jan 2021 @06:29PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @05:58PM	AHP

Sample ID:	S21-A06-055D	Sampling Date:	06 Jan 2021
Sample Description:	Deepwell 9	Sampling Time:	11:51 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Jan 2021 @06:01PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @06:01PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	06 Jan 2021 @06:29PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @06:01PM	AHP

Sample ID:	S21-A06-056D	Sampling Date:	06 Jan 2021
Sample Description:	N9	Sampling Time:	12:00 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Jan 2021 @06:04PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @06:04PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	06 Jan 2021 @06:29PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @06:04PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID:	S21-A06-057D	Sampling Date:	06 Jan 2021
Sample Description:	SBV Condo	Sampling Time:	12:08 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Jan 2021 @06:07PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @06:07PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	06 Jan 2021 @06:29PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @06:07PM	AHP

Sample ID:	S21-A06-058D	Sampling Date:	06 Jan 2021
Sample Description:	Reservoir 2	Sampling Time:	12:20 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Jan 2021 @06:10PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @06:10PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	06 Jan 2021 @06:29PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @06:10PM	AHP

Sample ID:	S21-A06-059D	Sampling Date:	06 Jan 2021
Sample Description:	N6B	Sampling Time:	12:25 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Jan 2021 @06:13PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @06:13PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	06 Jan 2021 @06:29PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @06:13PM	AHP

Sample ID:	S21-A06-060D	Sampling Date:	06 Jan 2021
Sample Description:	Deepwell 10	Sampling Time:	12:34 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Jan 2021 @06:16PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @06:16PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	06 Jan 2021 @06:29PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @06:16PM	AHP

Sample ID:	S21-A06-061D	Sampling Date:	06 Jan 2021
Sample Description:	Deepwell 11	Sampling Time:	12:35 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Jan 2021 @06:19PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @06:19PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	06 Jan 2021 @06:29PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Jan 2021 @06:19PM	AHP

Notes & References:

Standard Methods for the Examination of Water and Wastewater, 23rd Edition.
DOH Administrative Order No. 2017-0010, PNSDW 2017.



echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Certified by:

Anita H. Pineda 13 Jan 2021

Anita H. Pineda, RMT

Medical Technologist, PRC No. 52546

Approved by:

May Ann M. Estavillo 13 Jan 2021

May Ann M. Estavillo, RCh

QA/QC Manager, PRC No. 8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
company seal



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

DOH Accreditation No.03-014-1820-LW-2 Valid until December 2020

DENR C.R.No. 074/2018 Valid until September 24, 2021

TEST REPORT

Client: **Manila Water Philippine Ventures (MWPV)** Test Report No.: **TR-21A-126B**
 Address: **Level 3 2nd Phase, BPO Bldg., UP Town Corporate Center, 216 Katipunan Ave., Diliman, Quezon City** Date and Time Received: **06 Jan 2021 @04:30PM**
 Contact Person: **Ms. Florisza I. Faustino** Sampled By: **ECHEM**
 COC Number: **2021-A0047** Report Date: **21 Jan 2021**

Sample ID: **S21-A06-034D** Sampling Date: **06 Jan 2021**
 Sample Description: **N5** Sampling Time: **09:00 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Arsenic	<0.005	mg/L	0.01	Gaseous Hydride Atomic Absorption Spectroscopy	14 Jan 2021	JIB
Cadmium	<0.0003	mg/L	0.003	Flame Atomic Absorption Spectroscopy	18 Jan 2021	JIB
Iron	<0.10	mg/L	1.0	Phenanthroline	20 Jan 2021	LDM
Lead	<0.0004	mg/L	0.01	Flame Atomic Absorption Spectroscopy	15 Jan 2021	JIB
Manganese	<0.15	mg/L	0.40	Persulfate	19 Jan 2021	LDM
Color, Apparent	<5 @pH 7.64	CU	10	Visual Comparison	07 Jan 2021	JSS
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	06 Jan 2021	RRM
pH (on-site)	7.31 @28.9°C	---	6.5-8.5	Electrometric	06 Jan 2021	FGC
Total Dissolved Solids (TDS)	238	mg/L	600	Gravimetric, Dried @180°C	07 Jan 2021	JSS
Turbidity	<1.0	NTU	5.0	Colorimetric	07 Jan 2021	LDM

Sample ID: **S21-A06-035D** Sampling Date: **06 Jan 2021**
 Sample Description: **SRCC Boston** Sampling Time: **09:28 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Arsenic	<0.005	mg/L	0.01	Gaseous Hydride Atomic Absorption Spectroscopy	14 Jan 2021	JIB
Cadmium	<0.0003	mg/L	0.003	Flame Atomic Absorption Spectroscopy	18 Jan 2021	JIB
Iron	<0.10	mg/L	1.0	Phenanthroline	20 Jan 2021	LDM
Lead	<0.0004	mg/L	0.01	Flame Atomic Absorption Spectroscopy	15 Jan 2021	JIB
Manganese	<0.15	mg/L	0.40	Persulfate	19 Jan 2021	LDM
Color, Apparent	5 @pH 7.95	CU	10	Visual Comparison	07 Jan 2021	JSS
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	06 Jan 2021	RRM
pH (on-site)	7.41 @29.1°C	---	6.5-8.5	Electrometric	06 Jan 2021	FGC
Total Dissolved Solids (TDS)	245	mg/L	600	Gravimetric, Dried @180°C	07 Jan 2021	JSS
Turbidity	<1.0	NTU	5.0	Colorimetric	07 Jan 2021	LDM



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID: **S21-A06-036D**

Sampling Date: **06 Jan 2021**

Sample Description: **N4**

Sampling Time: **09:35 AM**

Sample Matrix: **Drinking Water**

Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Arsenic	<0.005	mg/L	0.01	Gaseous Hydride Atomic Absorption Spectroscopy	14 Jan 2021	JIB
Cadmium	<0.0003	mg/L	0.003	Flame Atomic Absorption Spectroscopy	18 Jan 2021	JIB
Iron	<0.10	mg/L	1.0	Phenanthroline	20 Jan 2021	LDM
Lead	<0.0004	mg/L	0.01	Flame Atomic Absorption Spectroscopy	15 Jan 2021	JIB
Manganese	<0.15	mg/L	0.40	Persulfate	19 Jan 2021	LDM
Chlorine, Residual	0.60	mg/L	0.30-1.50	Colorimetric	06 Jan 2021	FGC
Color, Apparent	<5 @pH7.31	CU	10	Visual Comparison	07 Jan 2021	JSS
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	06 Jan 2021	RRM
pH (on-site)	7.30 @28.5°C	---	6.5-8.5	Electrometric	06 Jan 2021	FGC
Total Dissolved Solids (TDS)	200	mg/L	600	Gravimetric, Dried @180°C	07 Jan 2021	JSS
Turbidity	<1.0	NTU	5.0	Colorimetric	07 Jan 2021	LDM

Sample ID: **S21-A06-037D**

Sampling Date: **06 Jan 2021**

Sample Description: **N7**

Sampling Time: **09:45 AM**

Sample Matrix: **Drinking Water**

Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Arsenic	<0.005	mg/L	0.01	Gaseous Hydride Atomic Absorption Spectroscopy	14 Jan 2021	JIB
Cadmium	<0.0003	mg/L	0.003	Flame Atomic Absorption Spectroscopy	18 Jan 2021	JIB
Iron	<0.10	mg/L	1.0	Phenanthroline	20 Jan 2021	LDM
Lead	<0.0004	mg/L	0.01	Flame Atomic Absorption Spectroscopy	15 Jan 2021	JIB
Manganese	<0.15	mg/L	0.40	Persulfate	19 Jan 2021	LDM
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	06 Jan 2021	FGC
Color, Apparent	<5 @pH 6.71	CU	10	Visual Comparison	07 Jan 2021	JSS
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	06 Jan 2021	RRM
pH (on-site)	6.71 @28.0°C	---	6.5-8.5	Electrometric	06 Jan 2021	FGC
Total Dissolved Solids (TDS)	201	mg/L	600	Gravimetric, Dried @180°C	07 Jan 2021	JSS
Turbidity	<1.0	NTU	5.0	Colorimetric	07 Jan 2021	LDM

Sample ID: **S21-A06-038D**

Sampling Date: **06 Jan 2021**

Sample Description: **Reservoir 1**

Sampling Time: **09:50 AM**

Sample Matrix: **Drinking Water**

Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Arsenic	<0.005	mg/L	0.01	Gaseous Hydride Atomic Absorption Spectroscopy	14 Jan 2021	JIB
Cadmium	<0.0003	mg/L	0.003	Flame Atomic Absorption Spectroscopy	18 Jan 2021	JIB
Iron	<0.10	mg/L	1.0	Phenanthroline	20 Jan 2021	LDM
Lead	<0.0004	mg/L	0.01	Flame Atomic Absorption Spectroscopy	15 Jan 2021	JIB
Manganese	<0.15	mg/L	0.40	Persulfate	19 Jan 2021	LDM
Chlorine, Residual	1.0	mg/L	0.30-1.50	Colorimetric	06 Jan 2021	FGC
Color, Apparent	<5 @pH 6.81	CU	10	Visual Comparison	07 Jan 2021	JSS
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	06 Jan 2021	RRM
pH (on-site)	6.67 @29.2°C	---	6.5-8.5	Electrometric	06 Jan 2021	FGC
Total Dissolved Solids (TDS)	210	mg/L	600	Gravimetric, Dried @180°C	07 Jan 2021	JSS
Turbidity	<1.0	NTU	5.0	Colorimetric	07 Jan 2021	LDM



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID: **S21-A06-039D**

Sampling Date: **06 Jan 2021**

Sample Description: **Mr. Gregorio Residence**

Sampling Time: **10:00 AM**

Sample Matrix: **Drinking Water**

Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Arsenic	<0.005	mg/L	0.01	Gaseous Hydride Atomic Absorption Spectroscopy	14 Jan 2021	JIB
Cadmium	<0.0003	mg/L	0.003	Flame Atomic Absorption Spectroscopy	18 Jan 2021	JIB
Iron	<0.10	mg/L	1.0	Phenanthroline	20 Jan 2021	LDM
Lead	<0.0004	mg/L	0.01	Flame Atomic Absorption Spectroscopy	15 Jan 2021	JIB
Manganese	<0.15	mg/L	0.40	Persulfate	19 Jan 2021	LDM
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	06 Jan 2021	FGC
Color, Apparent	<5 @pH 6.96	CU	10	Visual Comparison	07 Jan 2021	JSS
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	06 Jan 2021	RRM
pH (on-site)	6.94 @29.0°C	---	6.5-8.5	Electrometric	06 Jan 2021	FGC
Total Dissolved Solids (TDS)	205	mg/L	600	Gravimetric, Dried @180°C	07 Jan 2021	JSS
Turbidity	<1.0	NTU	5.0	Colorimetric	07 Jan 2021	LDM

Sample ID: **S21-A06-040D**

Sampling Date: **06 Jan 2021**

Sample Description: **N2**

Sampling Time: **10:07 AM**

Sample Matrix: **Drinking Water**

Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Arsenic	<0.005	mg/L	0.01	Gaseous Hydride Atomic Absorption Spectroscopy	14 Jan 2021	JIB
Cadmium	<0.0003	mg/L	0.003	Flame Atomic Absorption Spectroscopy	18 Jan 2021	JIB
Iron	<0.10	mg/L	1.0	Phenanthroline	20 Jan 2021	LDM
Lead	<0.0004	mg/L	0.01	Flame Atomic Absorption Spectroscopy	15 Jan 2021	JIB
Manganese	<0.15	mg/L	0.40	Persulfate	19 Jan 2021	LDM
Chlorine, Residual	1.0	mg/L	0.30-1.50	Colorimetric	06 Jan 2021	FGC
Color, Apparent	<5 @pH 6.68	CU	10	Visual Comparison	07 Jan 2021	JSS
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	06 Jan 2021	RRM
pH (on-site)	6.73 @28.7°C	---	6.5-8.5	Electrometric	06 Jan 2021	FGC
Total Dissolved Solids (TDS)	208	mg/L	600	Gravimetric, Dried @180°C	07 Jan 2021	JSS
Turbidity	<1.0	NTU	5.0	Colorimetric	07 Jan 2021	LDM

Sample ID: **S21-A06-041D**

Sampling Date: **06 Jan 2021**

Sample Description: **N1**

Sampling Time: **10:12 AM**

Sample Matrix: **Drinking Water**

Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Arsenic	<0.005	mg/L	0.01	Gaseous Hydride Atomic Absorption Spectroscopy	14 Jan 2021	JIB
Cadmium	<0.0003	mg/L	0.003	Flame Atomic Absorption Spectroscopy	18 Jan 2021	JIB
Iron	<0.10	mg/L	1.0	Phenanthroline	20 Jan 2021	LDM
Lead	<0.0004	mg/L	0.01	Flame Atomic Absorption Spectroscopy	15 Jan 2021	JIB
Manganese	<0.15	mg/L	0.40	Persulfate	19 Jan 2021	LDM
Chlorine, Residual	0.90	mg/L	0.30-1.50	Colorimetric	06 Jan 2021	FGC
Color, Apparent	<5 @pH 7.01	CU	10	Visual Comparison	07 Jan 2021	JSS
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	06 Jan 2021	RRM
pH (on-site)	7.07 @28.9°C	---	6.5-8.5	Electrometric	06 Jan 2021	FGC
Total Dissolved Solids (TDS)	205	mg/L	600	Gravimetric, Dried @180°C	07 Jan 2021	JSS
Turbidity	<1.0	NTU	5.0	Colorimetric	07 Jan 2021	LDM



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID:	S21-A06-042D	Sampling Date:	06 Jan 2021
Sample Description:	N3	Sampling Time:	10:18 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Arsenic	<0.005	mg/L	0.01	Gaseous Hydride Atomic Absorption Spectroscopy	14 Jan 2021	JIB
Cadmium	<0.0003	mg/L	0.003	Flame Atomic Absorption Spectroscopy	18 Jan 2021	JIB
Iron	<0.10	mg/L	1.0	Phenanthroline	20 Jan 2021	LDM
Lead	<0.0004	mg/L	0.01	Flame Atomic Absorption Spectroscopy	15 Jan 2021	JIB
Manganese	<0.15	mg/L	0.40	Persulfate	19 Jan 2021	LDM
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	06 Jan 2021	FGC
Color, Apparent	<5 @pH 7.12	CU	10	Visual Comparison	07 Jan 2021	JSS
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	06 Jan 2021	RRM
pH (on-site)	7.04 @29.1°C	---	6.5-8.5	Electrometric	06 Jan 2021	FGC
Total Dissolved Solids (TDS)	205	mg/L	600	Gravimetric, Dried @180°C	07 Jan 2021	JSS
Turbidity	<1.0	NTU	5.0	Colorimetric	07 Jan 2021	LDM

Sample ID:	S21-A06-043D	Sampling Date:	06 Jan 2021
Sample Description:	Deepwell 7	Sampling Time:	10:22 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Arsenic	<0.005	mg/L	0.01	Gaseous Hydride Atomic Absorption Spectroscopy	14 Jan 2021	JIB
Cadmium	<0.0003	mg/L	0.003	Flame Atomic Absorption Spectroscopy	18 Jan 2021	JIB
Iron	<0.10	mg/L	1.0	Phenanthroline	20 Jan 2021	LDM
Lead	<0.0004	mg/L	0.01	Flame Atomic Absorption Spectroscopy	15 Jan 2021	JIB
Manganese	<0.15	mg/L	0.40	Persulfate	19 Jan 2021	LDM
Color, Apparent	<5 @pH 6.58	CU	10	Visual Comparison	07 Jan 2021	JSS
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	06 Jan 2021	RRM
pH (on-site)	6.58 @28.3°C	---	6.5-8.5	Electrometric	06 Jan 2021	FGC
Total Dissolved Solids (TDS)	187	mg/L	600	Gravimetric, Dried @180°C	07 Jan 2021	JSS
Turbidity	<1.0	NTU	5.0	Colorimetric	07 Jan 2021	LDM

Sample ID:	S21-A06-044D	Sampling Date:	06 Jan 2021
Sample Description:	BNC Pawikan	Sampling Time:	10:51 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Arsenic	<0.005	mg/L	0.01	Gaseous Hydride Atomic Absorption Spectroscopy	14 Jan 2021	JIB
Cadmium	<0.0003	mg/L	0.003	Flame Atomic Absorption Spectroscopy	18 Jan 2021	JIB
Iron	<0.10	mg/L	1.0	Phenanthroline	20 Jan 2021	LDM
Lead	<0.0004	mg/L	0.01	Flame Atomic Absorption Spectroscopy	15 Jan 2021	JIB
Manganese	<0.15	mg/L	0.40	Persulfate	19 Jan 2021	LDM
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	06 Jan 2021	FGC
Color, Apparent	5 @pH 6.85	CU	10	Visual Comparison	07 Jan 2021	JSS
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	06 Jan 2021	RRM
pH (on-site)	6.75 @26.2°C	---	6.5-8.5	Electrometric	06 Jan 2021	FGC
Total Dissolved Solids (TDS)	201	mg/L	600	Gravimetric, Dried @180°C	07 Jan 2021	JSS
Turbidity	<1.0	NTU	5.0	Colorimetric	07 Jan 2021	LDM



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID: **S21-A06-045D**
 Sample Description: **Deepwell 6**
 Sample Matrix: **Drinking Water**

Sampling Date: **06 Jan 2021**
 Sampling Time: **10:39 AM**
 Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Arsenic	<0.005	mg/L	0.01	Gaseous Hydride Atomic Absorption Spectroscopy	14 Jan 2021	JIB
Cadmium	<0.0003	mg/L	0.003	Flame Atomic Absorption Spectroscopy	18 Jan 2021	JIB
Iron	<0.10	mg/L	1.0	Phenanthroline	20 Jan 2021	LDM
Lead	<0.0004	mg/L	0.01	Flame Atomic Absorption Spectroscopy	15 Jan 2021	JIB
Manganese	0.47	mg/L	0.40	Persulfate	19 Jan 2021	LDM
Color, Apparent	5 @pH 6.87	CU	10.00	Visual Comparison	07 Jan 2021	JSS
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	06 Jan 2021	RRM
pH (on-site)	6.77 @29.1°C	---	6.5-8.5	Electrometric	06 Jan 2021	FGC
Total Dissolved Solids (TDS)	209	mg/L	600	Gravimetric, Dried @180°C	07 Jan 2021	JSS
Turbidity	<1.0	NTU	5.0	Colorimetric	07 Jan 2021	LDM

Sample ID: **S21-A06-046D**
 Sample Description: **BNC Backdoor**
 Sample Matrix: **Drinking Water**

Sampling Date: **06 Jan 2021**
 Sampling Time: **10:52 AM**
 Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Arsenic	<0.005	mg/L	0.01	Gaseous Hydride Atomic Absorption Spectroscopy	14 Jan 2021	JIB
Cadmium	<0.0003	mg/L	0.003	Flame Atomic Absorption Spectroscopy	18 Jan 2021	JIB
Iron	<0.10	mg/L	1.0	Phenanthroline	20 Jan 2021	LDM
Lead	<0.0004	mg/L	0.01	Flame Atomic Absorption Spectroscopy	15 Jan 2021	JIB
Manganese	<0.15	mg/L	0.40	Persulfate	19 Jan 2021	LDM
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	06 Jan 2021	FGC
Color, Apparent	5 @pH 6.80	CU	10	Visual Comparison	07 Jan 2021	JSS
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	06 Jan 2021	RRM
pH (on-site)	6.75 @29.0°C	---	6.5-8.5	Electrometric	06 Jan 2021	FGC
Total Dissolved Solids (TDS)	201	mg/L	600	Gravimetric, Dried @180°C	07 Jan 2021	JSS
Turbidity	<1.0	NTU	5.0	Colorimetric	07 Jan 2021	LDM

Sample ID: **S21-A06-047D**
 Sample Description: **Villas**
 Sample Matrix: **Drinking Water**

Sampling Date: **06 Jan 2021**
 Sampling Time: **10:58 AM**
 Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Arsenic	<0.005	mg/L	0.01	Gaseous Hydride Atomic Absorption Spectroscopy	14 Jan 2021	JIB
Cadmium	<0.0003	mg/L	0.003	Flame Atomic Absorption Spectroscopy	18 Jan 2021	JIB
Iron	<0.10	mg/L	1.0	Phenanthroline	20 Jan 2021	LDM
Lead	<0.0004	mg/L	0.01	Flame Atomic Absorption Spectroscopy	15 Jan 2021	JIB
Manganese	<0.15	mg/L	0.40	Persulfate	19 Jan 2021	LDM
Chlorine, Residual	0.60	mg/L	0.30-1.50	Colorimetric	06 Jan 2021	FGC
Color, Apparent	<5 @pH 6.80	CU	10	Visual Comparison	07 Jan 2021	JSS
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	06 Jan 2021	RRM
pH (on-site)	6.74 @28.5°C	---	6.5-8.5	Electrometric	06 Jan 2021	FGC
Total Dissolved Solids (TDS)	192	mg/L	600	Gravimetric, Dried @180°C	07 Jan 2021	JSS
Turbidity	<1.0	NTU	5.0	Colorimetric	07 Jan 2021	LDM



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID:	S21-A06-048D	Sampling Date:	06 Jan 2021
Sample Description:	Beechcroft	Sampling Time:	11:03 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Arsenic	<0.005	mg/L	0.01	Gaseous Hydride Atomic Absorption Spectroscopy	14 Jan 2021	JIB
Cadmium	<0.0003	mg/L	0.003	Flame Atomic Absorption Spectroscopy	18 Jan 2021	JIB
Iron	<0.10	mg/L	1.0	Phenanthroline	20 Jan 2021	LDM
Lead	<0.0004	mg/L	0.01	Flame Atomic Absorption Spectroscopy	15 Jan 2021	JIB
Manganese	<0.15	mg/L	0.40	Persulfate	19 Jan 2021	LDM
Chlorine, Residual	0.60	mg/L	0.30-1.50	Colorimetric	06 Jan 2021	FGC
Color, Apparent	<5 @pH 6.77	CU	10	Visual Comparison	07 Jan 2021	JSS
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	06 Jan 2021	RRM
pH (on-site)	6.77 @28.3°C	---	6.5-8.5	Electrometric	06 Jan 2021	FGC
Total Dissolved Solids (TDS)	195	mg/L	600	Gravimetric, Dried @180°C	07 Jan 2021	JSS
Turbidity	<1.0	NTU	5.0	Colorimetric	07 Jan 2021	LDM

Sample ID:	S21-A06-049D	Sampling Date:	06 Jan 2021
Sample Description:	Sports Center Common Area	Sampling Time:	11:15 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Arsenic	<0.005	mg/L	0.01	Gaseous Hydride Atomic Absorption Spectroscopy	14 Jan 2021	JIB
Cadmium	<0.0003	mg/L	0.003	Flame Atomic Absorption Spectroscopy	18 Jan 2021	JIB
Iron	<0.10	mg/L	1.0	Phenanthroline	20 Jan 2021	LDM
Lead	<0.0004	mg/L	0.01	Flame Atomic Absorption Spectroscopy	15 Jan 2021	JIB
Manganese	<0.15	mg/L	0.40	Persulfate	19 Jan 2021	LDM
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	06 Jan 2021	FGC
Color, Apparent	<5 @pH 6.71	CU	10	Visual Comparison	07 Jan 2021	JSS
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	06 Jan 2021	RRM
pH (on-site)	6.75 @29.1°C	---	6.5-8.5	Electrometric	06 Jan 2021	FGC
Total Dissolved Solids (TDS)	199	mg/L	600	Gravimetric, Dried @180°C	07 Jan 2021	JSS
Turbidity	<1.0	NTU	5.0	Colorimetric	07 Jan 2021	LDM

Sample ID:	S21-A06-050D	Sampling Date:	06 Jan 2021
Sample Description:	Sports Center Kitchen	Sampling Time:	11:17 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Arsenic	<0.005	mg/L	0.01	Gaseous Hydride Atomic Absorption Spectroscopy	14 Jan 2021	JIB
Cadmium	<0.0003	mg/L	0.003	Flame Atomic Absorption Spectroscopy	18 Jan 2021	JIB
Iron	<0.10	mg/L	1.0	Phenanthroline	20 Jan 2021	LDM
Lead	<0.0004	mg/L	0.01	Flame Atomic Absorption Spectroscopy	15 Jan 2021	JIB
Manganese	<0.15	mg/L	0.40	Persulfate	19 Jan 2021	LDM
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	06 Jan 2021	FGC
Color, Apparent	<5 @pH 6.71	CU	10	Visual Comparison	07 Jan 2021	JSS
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	06 Jan 2021	RRM
pH (on-site)	6.74 @28.2°C	---	6.5-8.5	Electrometric	06 Jan 2021	FGC
Total Dissolved Solids (TDS)	201	mg/L	600	Gravimetric, Dried @180°C	07 Jan 2021	JSS
Turbidity	<1.0	NTU	5.0	Colorimetric	07 Jan 2021	LDM



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID: S21-A06-051D	Sampling Date: 06 Jan 2021					
Sample Description: Golf Kitchen	Sampling Time: 11:40 AM					
Sample Matrix: Drinking Water	Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Arsenic	<0.005	mg/L	0.01	Gaseous Hydride Atomic Absorption Spectroscopy	14 Jan 2021	JIB
Cadmium	<0.0003	mg/L	0.003	Flame Atomic Absorption Spectroscopy	18 Jan 2021	JIB
Iron	<0.10	mg/L	1.0	Phenanthroline	20 Jan 2021	LDM
Lead	<0.0004	mg/L	0.01	Flame Atomic Absorption Spectroscopy	15 Jan 2021	JIB
Manganese	<0.15	mg/L	0.40	Persulfate	19 Jan 2021	LDM
Chlorine, Residual	<0.02	mg/L	0.30-1.50	Colorimetric	06 Jan 2021	FGC
Color, Apparent	<5 @pH 7.39	CU	10	Visual Comparison	07 Jan 2021	JSS
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	06 Jan 2021	RRM
pH (on-site)	7.10 @28.3°C	---	6.5-8.5	Electrometric	06 Jan 2021	FGC
Total Dissolved Solids (TDS)	243	mg/L	600	Gravimetric, Dried @180°C	08 Jan 2021	JSS
Turbidity	<1.0	NTU	5.0	Colorimetric	07 Jan 2021	LDM

Sample ID: S21-A06-052D	Sampling Date: 06 Jan 2021					
Sample Description: Caddie	Sampling Time: 11:46 AM					
Sample Matrix: Drinking Water	Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Arsenic	<0.005	mg/L	0.01	Gaseous Hydride Atomic Absorption Spectroscopy	14 Jan 2021	JIB
Cadmium	<0.0003	mg/L	0.003	Flame Atomic Absorption Spectroscopy	18 Jan 2021	JIB
Iron	<0.10	mg/L	1.0	Phenanthroline	20 Jan 2021	LDM
Lead	<0.0004	mg/L	0.01	Flame Atomic Absorption Spectroscopy	15 Jan 2021	JIB
Manganese	<0.15	mg/L	0.40	Persulfate	19 Jan 2021	LDM
Color, Apparent	<5 @pH 7.37	CU	10	Visual Comparison	07 Jan 2021	JSS
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	06 Jan 2021	RRM
pH (on-site)	7.14 @29.5°C	---	6.5-8.5	Electrometric	06 Jan 2021	FGC
Total Dissolved Solids (TDS)	240	mg/L	600	Gravimetric, Dried @180°C	08 Jan 2021	JSS
Turbidity	<1.0	NTU	5.0	Colorimetric	07 Jan 2021	LDM

Sample ID: S21-A06-053D	Sampling Date: 06 Jan 2021					
Sample Description: Deepwell 5	Sampling Time: 11:49 AM					
Sample Matrix: Drinking Water	Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Arsenic	<0.005	mg/L	0.01	Gaseous Hydride Atomic Absorption Spectroscopy	14 Jan 2021	JIB
Cadmium	<0.0003	mg/L	0.003	Flame Atomic Absorption Spectroscopy	18 Jan 2021	JIB
Iron	<0.10	mg/L	1.0	Phenanthroline	20 Jan 2021	LDM
Lead	<0.0004	mg/L	0.01	Flame Atomic Absorption Spectroscopy	15 Jan 2021	JIB
Manganese	<0.15	mg/L	0.40	Persulfate	19 Jan 2021	LDM
Color, Apparent	10 @pH 6.74	CU	10	Visual Comparison	07 Jan 2021	JSS
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	06 Jan 2021	RRM
pH (on-site)	6.77 @29.9°C	---	6.5-8.5	Electrometric	06 Jan 2021	FGC
Total Dissolved Solids (TDS)	200	mg/L	600	Gravimetric, Dried @180°C	08 Jan 2021	JSS
Turbidity	1.4	NTU	5.0	Colorimetric	07 Jan 2021	LDM



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID:	S21-A06-054D	Sampling Date:	06 Jan 2021
Sample Description:	Deepwell 8	Sampling Time:	11:50 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Arsenic	<0.005	mg/L	0.01	Gaseous Hydride Atomic Absorption Spectroscopy	14 Jan 2021	JIB
Cadmium	<0.0003	mg/L	0.003	Flame Atomic Absorption Spectroscopy	18 Jan 2021	JIB
Iron	<0.10	mg/L	1.0	Phenanthroline	20 Jan 2021	LDM
Lead	<0.0004	mg/L	0.01	Flame Atomic Absorption Spectroscopy	15 Jan 2021	JIB
Manganese	<0.15	mg/L	0.40	Persulfate	19 Jan 2021	LDM
Color, Apparent	5 @pH 6.67	CU	10	Visual Comparison	07 Jan 2021	JSS
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	06 Jan 2021	RRM
pH (on-site)	6.74 @28.1°C	---	6.5-8.5	Electrometric	06 Jan 2021	FGC
Total Dissolved Solids (TDS)	199	mg/L	600	Gravimetric, Dried @180°C	08 Jan 2021	JSS
Turbidity	<1.0	NTU	5.0	Colorimetric	07 Jan 2021	LDM

Sample ID:	S21-A06-055D	Sampling Date:	06 Jan 2021
Sample Description:	Deepwell 9	Sampling Time:	11:51 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Arsenic	<0.005	mg/L	0.01	Gaseous Hydride Atomic Absorption Spectroscopy	14 Jan 2021	JIB
Cadmium	<0.0003	mg/L	0.003	Flame Atomic Absorption Spectroscopy	18 Jan 2021	JIB
Iron	<0.10	mg/L	1.0	Phenanthroline	20 Jan 2021	LDM
Lead	<0.0004	mg/L	0.01	Flame Atomic Absorption Spectroscopy	15 Jan 2021	JIB
Manganese	<0.15	mg/L	0.40	Persulfate	19 Jan 2021	LDM
Color, Apparent	5 @pH 6.68	CU	10	Visual Comparison	07 Jan 2021	JSS
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	06 Jan 2021	RRM
pH (on-site)	6.72 @28.9°C	---	6.5-8.5	Electrometric	06 Jan 2021	FGC
Total Dissolved Solids (TDS)	206	mg/L	600	Gravimetric, Dried @180°C	08 Jan 2021	JSS
Turbidity	<1.0	NTU	5.0	Colorimetric	07 Jan 2021	LDM

Sample ID:	S21-A06-056D	Sampling Date:	06 Jan 2021
Sample Description:	N9	Sampling Time:	12:00 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Arsenic	<0.005	mg/L	0.01	Gaseous Hydride Atomic Absorption Spectroscopy	14 Jan 2021	JIB
Cadmium	<0.0003	mg/L	0.003	Flame Atomic Absorption Spectroscopy	18 Jan 2021	JIB
Iron	<0.10	mg/L	1.0	Phenanthroline	20 Jan 2021	LDM
Lead	<0.0004	mg/L	0.01	Flame Atomic Absorption Spectroscopy	15 Jan 2021	JIB
Manganese	<0.15	mg/L	0.40	Persulfate	19 Jan 2021	LDM
Color, Apparent	<5 @pH 7.34	CU	10	Visual Comparison	07 Jan 2021	JSS
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	06 Jan 2021	RRM
pH (on-site)	7.11 @28.6°C	---	6.5-8.5	Electrometric	06 Jan 2021	FGC
Total Dissolved Solids (TDS)	228	mg/L	600	Gravimetric, Dried @180°C	08 Jan 2021	JSS
Turbidity	<1.0	NTU	5.0	Colorimetric	07 Jan 2021	LDM



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID: **S21-A06-057D**

Sampling Date: **06 Jan 2021**

Sample Description: **SBV Condo**

Sampling Time: **12:08 PM**

Sample Matrix: **Drinking Water**

Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Arsenic	<0.005	mg/L	0.01	Gaseous Hydride Atomic Absorption Spectroscopy	14 Jan 2021	JIB
Cadmium	<0.0003	mg/L	0.003	Flame Atomic Absorption Spectroscopy	18 Jan 2021	JIB
Iron	<0.10	mg/L	1.0	Phenanthroline	20 Jan 2021	LDM
Lead	<0.0004	mg/L	0.01	Flame Atomic Absorption Spectroscopy	15 Jan 2021	JIB
Manganese	<0.15	mg/L	0.40	Persulfate	19 Jan 2021	LDM
Color, Apparent	<5 @pH 7.28	CU	10	Visual Comparison	07 Jan 2021	JSS
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	06 Jan 2021	RRM
pH (on-site)	7.10 @29.1°C	---	6.5-8.5	Electrometric	06 Jan 2021	FGC
Total Dissolved Solids (TDS)	237	mg/L	600	Gravimetric, Dried @180°C	08 Jan 2021	JSS
Turbidity	<1.0	NTU	5.0	Colorimetric	07 Jan 2021	LDM

Sample ID: **S21-A06-058D**

Sampling Date: **06 Jan 2021**

Sample Description: **Reservoir 2**

Sampling Time: **12:20 PM**

Sample Matrix: **Drinking Water**

Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Arsenic	<0.005	mg/L	0.01	Gaseous Hydride Atomic Absorption Spectroscopy	14 Jan 2021	JIB
Cadmium	<0.0003	mg/L	0.003	Flame Atomic Absorption Spectroscopy	18 Jan 2021	JIB
Iron	<0.10	mg/L	1.0	Phenanthroline	20 Jan 2021	LDM
Lead	<0.0004	mg/L	0.01	Flame Atomic Absorption Spectroscopy	15 Jan 2021	JIB
Manganese	<0.15	mg/L	0.40	Persulfate	19 Jan 2021	LDM
Color, Apparent	<5 @pH 7.08	CU	10	Visual Comparison	07 Jan 2021	JSS
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	06 Jan 2021	RRM
pH (on-site)	6.93 @29.6°C	---	6.5-8.5	Electrometric	06 Jan 2021	FGC
Total Dissolved Solids (TDS)	242	mg/L	600	Gravimetric, Dried @180°C	08 Jan 2021	JSS
Turbidity	<1.0	NTU	5.0	Colorimetric	07 Jan 2021	LDM

Sample ID: **S21-A06-059D**

Sampling Date: **06 Jan 2021**

Sample Description: **N6B**

Sampling Time: **12:25 PM**

Sample Matrix: **Drinking Water**

Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Arsenic	<0.005	mg/L	0.01	Gaseous Hydride Atomic Absorption Spectroscopy	14 Jan 2021	JIB
Cadmium	<0.0003	mg/L	0.003	Flame Atomic Absorption Spectroscopy	18 Jan 2021	JIB
Iron	<0.10	mg/L	1.0	Phenanthroline	20 Jan 2021	LDM
Lead	<0.0004	mg/L	0.01	Flame Atomic Absorption Spectroscopy	15 Jan 2021	JIB
Manganese	<0.15	mg/L	0.40	Persulfate	19 Jan 2021	LDM
Color, Apparent	<5 @pH 7.24	CU	10	Visual Comparison	07 Jan 2021	JSS
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	06 Jan 2021	RRM
pH (on-site)	7.08 @28.5°C	---	6.5-8.5	Electrometric	06 Jan 2021	FGC
Total Dissolved Solids (TDS)	240	mg/L	600	Gravimetric, Dried @180°C	08 Jan 2021	JSS
Turbidity	<1.0	NTU	5.0	Colorimetric	07 Jan 2021	LDM



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID: **S21-A06-060D**

Sampling Date: **06 Jan 2021**

Sample Description: **Deepwell 10**

Sampling Time: **12:34 PM**

Sample Matrix: **Drinking Water**

Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Arsenic	<0.005	mg/L	0.01	Gaseous Hydride Atomic Absorption Spectroscopy	14 Jan 2021	JIB
Cadmium	<0.0003	mg/L	0.003	Flame Atomic Absorption Spectroscopy	18 Jan 2021	JIB
Iron	<0.10	mg/L	1.0	Phenanthroline	20 Jan 2021	LDM
Lead	<0.0004	mg/L	0.01	Flame Atomic Absorption Spectroscopy	15 Jan 2021	JIB
Manganese	0.64	mg/L	0.40	Persulfate	19 Jan 2021	LDM
Color, Apparent	10 @pH 7.17	CU	10	Visual Comparison	07 Jan 2021	JSS
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	06 Jan 2021	RRM
pH (on-site)	7.14 @29.2°C	---	6.5-8.5	Electrometric	06 Jan 2021	FGC
Total Dissolved Solids (TDS)	235	mg/L	600	Gravimetric, Dried @180°C	08 Jan 2021	JSS
Turbidity	<1.0	NTU	5.0	Colorimetric	07 Jan 2021	LDM

Sample ID: **S21-A06-061D**

Sampling Date: **06 Jan 2021**

Sample Description: **Deepwell 11**

Sampling Time: **12:35 PM**

Sample Matrix: **Drinking Water**

Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Arsenic	<0.005	mg/L	0.01	Gaseous Hydride Atomic Absorption Spectroscopy	14 Jan 2021	JIB
Cadmium	<0.0003	mg/L	0.003	Flame Atomic Absorption Spectroscopy	18 Jan 2021	JIB
Iron	<0.10	mg/L	1.0	Phenanthroline	20 Jan 2021	LDM
Lead	<0.0004	mg/L	0.01	Flame Atomic Absorption Spectroscopy	15 Jan 2021	JIB
Manganese	0.64	mg/L	0.40	Persulfate	19 Jan 2021	LDM
Color, Apparent	5 @pH 7.16	CU	10	Visual Comparison	07 Jan 2021	JSS
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	06 Jan 2021	RRM
pH (on-site)	7.14 @29.1°C	---	6.5-8.5	Electrometric	06 Jan 2021	FGC
Total Dissolved Solids (TDS)	242	mg/L	600	Gravimetric, Dried @180°C	08 Jan 2021	JSS
Turbidity	<1.0	NTU	5.0	Colorimetric	07 Jan 2021	LDM

Notes & References:


Standard Methods for the Examination of Water and Wastewater, 23rd Edition.

DOH Administrative Order No. 2017-0010, PNSDW 2017.

Skyray AAS 9000, Atomic Absorption Spectrophotometry

Test Methods for Evaluating Solid Wastes, Vol 1A, USEPA, Third Edition

Certified & Approved by:


May Ann M. Estavillo, RCh

QA/QC Manager, PRC No.8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
company seal



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

DOH Accreditation No.03-014-1820-LW-2 Valid until December 2020
DENR C.R.No. 074/2018 Valid until September 24, 2021

TEST REPORT

Client: **Manila Water Philippine Ventures (MWPV)**
Address: Level 3 2nd Phase, BPO Bldg., UP Town Corporate Center, 216 Katipunan Ave., Diliman, Quezon City
Contact Person: **Ms. Florisza I. Faustino**
COC Number: **2021-A0293**

Test Report No.: **TR-21A-294**
Date and Time Received: **27 Jan 2021@06:30 PM**
Sampled By: **ECHEM**
Report Date: **28 Jan 2021**

Sample ID: **S21-A27-001D**
Sample Description: **SRCC Boston**
Sample Matrix: **Drinking Water**

Sampling Date: **27 Jan 2021**
Sampling Time: **11:10 AM**
Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.60	mg/L	0.30-1.50	Colorimetric	27 Jan 2021	MGF

Sample ID: **S21-A27-002D**
Sample Description: **N5**
Sample Matrix: **Drinking Water**

Sampling Date: **27 Jan 2021**
Sampling Time: **11:15 AM**
Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.50	mg/L	0.30-1.50	Colorimetric	27 Jan 2021	MGF

Sample ID: **S21-A27-004D**
Sample Description: **N6B**
Sample Matrix: **Drinking Water**

Sampling Date: **27 Jan 2021**
Sampling Time: **11:25 AM**
Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.60	mg/L	0.30-1.50	Colorimetric	27 Jan 2021	MGF

Sample ID: **S21-A27-005D**
Sample Description: **Reservoir 2**
Sample Matrix: **Drinking Water**

Sampling Date: **27 Jan 2021**
Sampling Time: **11:37 AM**
Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.50	mg/L	0.30-1.50	Colorimetric	27 Jan 2021	MGF

Sample ID: **S21-A27-006D**
Sample Description: **SBV Condo**
Sample Matrix: **Drinking Water**

Sampling Date: **27 Jan 2021**
Sampling Time: **11:48 AM**
Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.50	mg/L	0.30-1.50	Colorimetric	27 Jan 2021	MGF

Sample ID: **S21-A27-008D**
Sample Description: **N9**
Sample Matrix: **Drinking Water**

Sampling Date: **27 Jan 2021**
Sampling Time: **11:58 AM**
Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.60	mg/L	0.30-1.50	Colorimetric	27 Jan 2021	MGF



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION


Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga
Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
Technical: 0917-164-2927 • 0917-164-2944

Sample ID:	S21-A27-009D	Sampling Date:	27 Jan 2021			
Sample Description:	Cadie	Sampling Time:	12:10 PM			
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan			
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.60	mg/L	0.30-1.50	Colorimetric	27 Jan 2021	MGF

Notes & References:

Standard Methods for the Examination of Water and Wastewater, 23rd Edition.
DOH Administrative Order No. 2017-0010, PNSDW 2017.

Certified & Approved by:


May Ann M. Estavillo, RCh
QA/QC Manager, PRC No.8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
company seal