



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

DOH Accreditation No.03-014-1820-LW-2 Valid until December 2020

DENR C.R.No. 074/2018 Valid until September 24, 2021

TEST REPORT

Client: **Manila Water Philippine Ventures (MWPV)**
Address: **Level 3 2nd Phase, BPO Bldg., UP Town Corporate Center, 216 Katipunan Ave., Dillman, Quezon City**
Contact Person: **Ms. Florisza I. Faustino**
COC Number: **2020-J0029**

Test Report No.: **TR-20J-081A**
Date and Time Received: **02 Oct 2020 @03:05PM**
Sampled By: **ECHEM**
Report Date: **07 Oct 2020**

Sample ID: **S20-J02-013D** Sampling Date: **02 Oct 2020**
Sample Description: **N5** Sampling Time: **09:20 AM**
Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @03:14PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:14PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:14PM	AHP

Sample ID: **S20-J02-014D** Sampling Date: **02 Oct 2020**
Sample Description: **SRCC Boston** Sampling Time: **09:25 AM**
Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @03:17PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:17PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:17PM	AHP

Sample ID: **S20-J02-015D** Sampling Date: **02 Oct 2020**
Sample Description: **N4** Sampling Time: **09:35 AM**
Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @03:20PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:20PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:20PM	AHP

Sample ID: **S20-J02-016D** Sampling Date: **02 Oct 2020**
Sample Description: **N7** Sampling Time: **09:45 AM**
Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @03:23PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:23PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:23PM	AHP

Sample ID: **S20-J02-017D** Sampling Date: **02 Oct 2020**
Sample Description: **Reservoir 1** Sampling Time: **09:51 AM**
Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @03:26PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:26PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:26PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID:	S20-J02-018D	Sampling Date:	02 Oct 2020
Sample Description:	Mr. Gregorio Residence	Sampling Time:	09:58 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @03:29PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:29PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:29PM	AHP

Sample ID:	S20-J02-019D	Sampling Date:	02 Oct 2020
Sample Description:	N3	Sampling Time:	10:10 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @03:32PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:32PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:32PM	AHP

Sample ID:	S20-J02-020D	Sampling Date:	02 Oct 2020
Sample Description:	Deepwell 7	Sampling Time:	10:15 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @03:35PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:35PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:35PM	AHP

Sample ID:	S20-J02-021D	Sampling Date:	02 Oct 2020
Sample Description:	N1	Sampling Time:	10:24 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @03:38PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:38PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:38PM	AHP

Sample ID:	S20-J02-022D	Sampling Date:	02 Oct 2020
Sample Description:	N2	Sampling Time:	10:31 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @03:41PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:41PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:41PM	AHP

Sample ID:	S20-J02-023D	Sampling Date:	02 Oct 2020
Sample Description:	Deepwell 6	Sampling Time:	10:43 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @03:44PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:44PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:44PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID:	S20-J02-024D	Sampling Date:	02 Oct 2020
Sample Description:	Villas	Sampling Time:	10:55 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @03:47PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:47PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:47PM	AHP

Sample ID:	S20-J02-025D	Sampling Date:	02 Oct 2020
Sample Description:	Beechcroft	Sampling Time:	11:03 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @03:50PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:50PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:50PM	AHP

Sample ID:	S20-J02-026D	Sampling Date:	02 Oct 2020
Sample Description:	Deepwell 8	Sampling Time:	11:34 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @03:53PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:53PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:53PM	AHP

Sample ID:	S20-J02-027D	Sampling Date:	02 Oct 2020
Sample Description:	Deepwell 9	Sampling Time:	11:45 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @03:56PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:56PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:56PM	AHP

Sample ID:	S20-J02-028D	Sampling Date:	02 Oct 2020
Sample Description:	Deepwell 10	Sampling Time:	11:55 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @03:59PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:59PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:59PM	AHP

Sample ID:	S20-J02-029D	Sampling Date:	02 Oct 2020
Sample Description:	N9	Sampling Time:	11:59 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @04:02PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @04:02PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @04:02PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID:	S20-J02-030D	Sampling Date:	02 Oct 2020
Sample Description:	SBV Condo	Sampling Time:	12:06 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @04:05PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @04:05PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @04:05PM	AHP

Sample ID:	S20-J02-031D	Sampling Date:	02 Oct 2020
Sample Description:	Reservoir 2	Sampling Time:	12:14 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @04:08PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @04:08PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @04:08PM	AHP

Sample ID:	S20-J02-032D	Sampling Date:	02 Oct 2020
Sample Description:	N6B	Sampling Time:	12:21 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @04:11PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @04:11PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @04:11PM	AHP

Notes & References:

Standard Methods for the Examination of Water and Wastewater, 23rd Edition.
DOH Administrative Order No. 2017-0010, PNSDW 2017.

Certified by:

Anita H. Pineda 07 Oct 2020
Anita H. Pineda, RMT
Medical Technologist, PRC No. 52546

Approved by:

May Ann M. Estavillo 07 Oct 2020
May Ann M. Estavillo, RCh
QC Manager, PRC No. 8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
company seal



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-164-2927 • 0917-164-2944

DOH Accreditation No.03-014-1820-LW-2 Valid until December 2020
 DENR C.R.No. 074/2018 Valid until September 24, 2021

TEST REPORT

Client: **Manila Water Philippine Ventures (MWPV)** Test Report No.: **TR-20K-083A**
 Address: **Level 3 2nd Phase, BPO Bldg., UP Town Corporate Center, 216 Katipunan Ave., Diliman, Quezon City** Date and Time Received: **30 Oct 2020 @04:50PM**
 Contact Person: **Ms. Florisza I. Faustino** Sampled By: **ECHEM**
 COC Number: **2020-J0309** Report Date: **10 Nov 2020**

Sample ID: **S20-J30-025D** Sampling Date: **30 Oct 2020**
 Sample Description: **BNC Pawikan** Sampling Time: **09:57 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	30 Oct 2020 @04:59PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	30 Oct 2020 @04:59PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	30 Oct 2020 @05:10AM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	30 Oct 2020 @04:59PM	AHP

Sample ID: **S20-J30-026D** Sampling Date: **30 Oct 2020**
 Sample Description: **Caddie** Sampling Time: **10:25 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	30 Oct 2020 @05:03PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	30 Oct 2020 @05:03PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	30 Oct 2020 @05:10AM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	30 Oct 2020 @05:03PM	AHP

Notes & References:

Standard Methods for the Examination of Water and Wastewater, 23rd Edition.
 DOH Administrative Order No. 2017-0010, PNSDW 2017.

Certified by:

Anita H. Pineda 11 Nov 2020
Anita H. Pineda, RMT
 Medical Technologist, PRC No. 52546

Approved by:

May Ann M. Estavillo 11 Nov 2020
May Ann M. Estavillo, RCh
 QA/QC Manager, PRC No. 8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
 company seal



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

DOH Accreditation No.03-014-1820-LW-2 Valid until December 2020

DENR C.R.No. 074/2018 Valid until September 24, 2021

TEST REPORT

Client: **Manila Water Philippine Ventures (MWPV)**
Address: **Level 3 2nd Phase, BPO Bldg., UP Town Corporate Center, 216 Katipunan Ave., Diliman, Quezon City**
Contact Person: **Ms. Florisza I. Faustino**
COC Number: **2020-J0252**

Test Report No.: **TR-20J-326A**
Date and Time Received: **23 Oct 2020 @05:18PM**
Sampled By: **ECHEM**
Report Date: **28 Oct 2020**

Sample ID: **S20-J23-035D** Sampling Date: **23 Oct 2020**
Sample Description: **BNC Backdoor** Sampling Time: **09:43 AM**
Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	23 Oct 2020 @05:34PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	23 Oct 2020 @05:34PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	23 Oct 2020 @05:55PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	23 Oct 2020 @05:34PM	AHP

Sample ID: **S20-J23-036D** Sampling Date: **23 Oct 2020**
Sample Description: **Sports Center Common Area** Sampling Time: **10:00 AM**
Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	23 Oct 2020 @05:37PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	23 Oct 2020 @05:37PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	23 Oct 2020 @05:55PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	23 Oct 2020 @05:37PM	AHP

Sample ID: **S20-J23-037D** Sampling Date: **23 Oct 2020**
Sample Description: **Sports Center Kitchen** Sampling Time: **10:05 AM**
Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	23 Oct 2020 @05:40PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	23 Oct 2020 @05:40PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	23 Oct 2020 @05:55PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	23 Oct 2020 @05:40PM	AHP

Sample ID: **S20-J23-038D** Sampling Date: **23 Oct 2020**
Sample Description: **Golf Kitchen** Sampling Time: **10:20 AM**
Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	23 Oct 2020 @05:43PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	23 Oct 2020 @05:55PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	23 Oct 2020 @05:43PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	23 Oct 2020 @05:43PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

DOH Accreditation No.03-014-1820-LW-2 Valid until December 2020

DENR C.R.No. 074/2018 Valid until September 24, 2021

TEST REPORT

Client: **Manila Water Philippine Ventures (MWPV)**
Address: **Level 3 2nd Phase, BPO Bldg., UP Town Corporate Center, 216 Katipunan Ave., Dillman, Quezon City**
Contact Person: **Ms. Florisza I. Faustino**
COC Number: **2020-J0029**

Test Report No.: **TR-20J-081A**
Date and Time Received: **02 Oct 2020 @03:05PM**
Sampled By: **ECHEM**
Report Date: **07 Oct 2020**

Sample ID: **S20-J02-013D** Sampling Date: **02 Oct 2020**
Sample Description: **N5** Sampling Time: **09:20 AM**
Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @03:14PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:14PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:14PM	AHP

Sample ID: **S20-J02-014D** Sampling Date: **02 Oct 2020**
Sample Description: **SRCC Boston** Sampling Time: **09:25 AM**
Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @03:17PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:17PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:17PM	AHP

Sample ID: **S20-J02-015D** Sampling Date: **02 Oct 2020**
Sample Description: **N4** Sampling Time: **09:35 AM**
Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @03:20PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:20PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:20PM	AHP

Sample ID: **S20-J02-016D** Sampling Date: **02 Oct 2020**
Sample Description: **N7** Sampling Time: **09:45 AM**
Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @03:23PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:23PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:23PM	AHP

Sample ID: **S20-J02-017D** Sampling Date: **02 Oct 2020**
Sample Description: **Reservoir 1** Sampling Time: **09:51 AM**
Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @03:26PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:26PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:26PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID:	S20-J02-018D	Sampling Date:	02 Oct 2020
Sample Description:	Mr. Gregorio Residence	Sampling Time:	09:58 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @03:29PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:29PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:29PM	AHP

Sample ID:	S20-J02-019D	Sampling Date:	02 Oct 2020
Sample Description:	N3	Sampling Time:	10:10 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @03:32PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:32PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:32PM	AHP

Sample ID:	S20-J02-020D	Sampling Date:	02 Oct 2020
Sample Description:	Deepwell 7	Sampling Time:	10:15 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @03:35PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:35PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:35PM	AHP

Sample ID:	S20-J02-021D	Sampling Date:	02 Oct 2020
Sample Description:	N1	Sampling Time:	10:24 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @03:38PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:38PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:38PM	AHP

Sample ID:	S20-J02-022D	Sampling Date:	02 Oct 2020
Sample Description:	N2	Sampling Time:	10:31 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @03:41PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:41PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:41PM	AHP

Sample ID:	S20-J02-023D	Sampling Date:	02 Oct 2020
Sample Description:	Deepwell 6	Sampling Time:	10:43 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @03:44PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:44PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:44PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID:	S20-J02-024D	Sampling Date:	02 Oct 2020
Sample Description:	Villas	Sampling Time:	10:55 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @03:47PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:47PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:47PM	AHP

Sample ID:	S20-J02-025D	Sampling Date:	02 Oct 2020
Sample Description:	Beechcroft	Sampling Time:	11:03 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @03:50PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:50PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:50PM	AHP

Sample ID:	S20-J02-026D	Sampling Date:	02 Oct 2020
Sample Description:	Deepwell 8	Sampling Time:	11:34 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @03:53PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:53PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:53PM	AHP

Sample ID:	S20-J02-027D	Sampling Date:	02 Oct 2020
Sample Description:	Deepwell 9	Sampling Time:	11:45 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @03:56PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:56PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:56PM	AHP

Sample ID:	S20-J02-028D	Sampling Date:	02 Oct 2020
Sample Description:	Deepwell 10	Sampling Time:	11:55 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @03:59PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:59PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @03:59PM	AHP

Sample ID:	S20-J02-029D	Sampling Date:	02 Oct 2020
Sample Description:	N9	Sampling Time:	11:59 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @04:02PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @04:02PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @04:02PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID:	S20-J02-030D	Sampling Date:	02 Oct 2020
Sample Description:	SBV Condo	Sampling Time:	12:06 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @04:05PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @04:05PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @04:05PM	AHP

Sample ID:	S20-J02-031D	Sampling Date:	02 Oct 2020
Sample Description:	Reservoir 2	Sampling Time:	12:14 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @04:08PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @04:08PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @04:08PM	AHP

Sample ID:	S20-J02-032D	Sampling Date:	02 Oct 2020
Sample Description:	N6B	Sampling Time:	12:21 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Oct 2020 @04:11PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @04:11PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Oct 2020 @04:32PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Oct 2020 @04:11PM	AHP

Notes & References:

Standard Methods for the Examination of Water and Wastewater, 23rd Edition.
DOH Administrative Order No. 2017-0010, PNSDW 2017.

Certified by:

Anita H. Pineda 07 Oct 2020
Anita H. Pineda, RMT
Medical Technologist, PRC No. 52546

Approved by:

May Ann M. Estavillo 07 Oct 2020
May Ann M. Estavillo, RCh
QC Manager, PRC No. 8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
company seal