



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

DOH Accreditation No.03-002-21-LW-2 Valid until December 31, 2023

DENR C.R.No. 074/2018 Valid until September 24, 2021

TEST REPORT

Client: **Manila Water Philippine Ventures (MWPV)**

Address: **Level 3 2nd Phase, BPO Bldg., UP Town Corporate Center, 216 Katipunan Ave., Diliman, Quezon City**

Contact Person: **Ms. Florisza I. Faustino**

COC Number: **2021-J0076**

Test Report No.: **TR-21J-217A**

Date and Time Received: **05 Oct 2021 @03:55PM**

Sampled By: **ECHEM**

Report Date: **15 Oct 2021**

Sample ID:	S21-J05-066D	Sampling Date:	05 Oct 2021
Sample Description:	N5	Sampling Time:	09:00 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	05 Oct 2021 @05:05PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:05PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	05 Oct 2021 @07:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:05PM	AHP

Sample ID:	S21-J05-067D	Sampling Date:	05 Oct 2021
Sample Description:	SRCC Boston	Sampling Time:	09:10 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	05 Oct 2021 @05:08PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:08PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	05 Oct 2021 @07:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:08PM	AHP

Sample ID:	S21-J05-068D	Sampling Date:	05 Oct 2021
Sample Description:	N4	Sampling Time:	09:15 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	05 Oct 2021 @05:11PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:11PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	05 Oct 2021 @07:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:11PM	AHP

Sample ID:	S21-J05-069D	Sampling Date:	05 Oct 2021
Sample Description:	N7	Sampling Time:	09:25 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	05 Oct 2021 @05:14PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:14PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	05 Oct 2021 @07:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:14PM	AHP

Sample ID:	S21-J05-070D	Sampling Date:	05 Oct 2021
Sample Description:	Mr. Gregorio Residence	Sampling Time:	09:33 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	05 Oct 2021 @05:17PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:17PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	05 Oct 2021 @07:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:17PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID:	S21-J05-072D	Sampling Date:	05 Oct 2021
Sample Description:	N2	Sampling Time:	09:55 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	05 Oct 2021 @05:23PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:23PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	05 Oct 2021 @07:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:23PM	AHP

Sample ID:	S21-J05-073D	Sampling Date:	05 Oct 2021
Sample Description:	N1	Sampling Time:	10:10 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	05 Oct 2021 @05:26PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:26PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	05 Oct 2021 @07:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:26PM	AHP

Sample ID:	S21-J05-074D	Sampling Date:	05 Oct 2021
Sample Description:	N3	Sampling Time:	10:15 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	05 Oct 2021 @05:29PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:29PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	05 Oct 2021 @07:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:29PM	AHP

Sample ID:	S21-J05-076D	Sampling Date:	05 Oct 2021
Sample Description:	BNC Pawikan	Sampling Time:	10:30 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	05 Oct 2021 @05:35PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:35PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	05 Oct 2021 @07:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:35PM	AHP

Sample ID:	S21-J05-078D	Sampling Date:	05 Oct 2021
Sample Description:	Beechcroft	Sampling Time:	10:45 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	05 Oct 2021 @05:41PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:41PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	05 Oct 2021 @07:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:41PM	AHP

Sample ID:	S21-J05-079D	Sampling Date:	05 Oct 2021
Sample Description:	Villas	Sampling Time:	10:50 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	05 Oct 2021 @05:44PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:44PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	05 Oct 2021 @07:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:44PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID:	S21-J05-080D	Sampling Date:	05 Oct 2021
Sample Description:	BNC Backdoor	Sampling Time:	10:55 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	05 Oct 2021 @05:47PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:47PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	05 Oct 2021 @07:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:47PM	AHP

Sample ID:	S21-J05-082D	Sampling Date:	05 Oct 2021
Sample Description:	Sports Center Common Area	Sampling Time:	11:15 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	05 Oct 2021 @05:53PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:53PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	05 Oct 2021 @07:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:53PM	AHP

Sample ID:	S21-J05-083D	Sampling Date:	05 Oct 2021
Sample Description:	Sports Center Kitchen	Sampling Time:	11:20 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	05 Oct 2021 @05:56PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:56PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	05 Oct 2021 @07:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:56PM	AHP

Sample ID:	S21-J05-084D	Sampling Date:	05 Oct 2021
Sample Description:	Caddie	Sampling Time:	11:30 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	05 Oct 2021 @05:59PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:59PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	05 Oct 2021 @07:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:59PM	AHP

Sample ID:	S21-J05-087D	Sampling Date:	05 Oct 2021
Sample Description:	N9	Sampling Time:	12:00 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	05 Oct 2021 @06:08PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @06:08PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	05 Oct 2021 @07:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @06:08PM	AHP

Sample ID:	S21-J05-090D	Sampling Date:	05 Oct 2021
Sample Description:	SBV Condo	Sampling Time:	12:20 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	05 Oct 2021 @06:17PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @06:17PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	05 Oct 2021 @07:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @06:17PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID: **S21-J05-091D** Sampling Date: **05 Oct 2021**
Sample Description: **N6B** Sampling Time: **12:25 PM**
Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	05 Oct 2021 @06:20PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @06:20PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	05 Oct 2021 @07:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @06:20PM	AHP


Notes & References:

Standard Methods for the Examination of Water and Wastewater, 23rd Edition.
DOH Administrative Order No. 2017-0010, PNSDW 2017.

Certified by:


Anita H. Pineda, RMT
Medical Technologist, PRC No. 52546

Approved by:


May Ann M. Estavillo, RCh
QA/QC Manager, PRC No. 8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
company seal



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

DOH Accreditation No.03-002-21-LW-2 Valid until December 31, 2023

DENR C.R.No. 074/2018 Valid until September 24, 2021

TEST REPORT

Client: **Manila Water Philippine Ventures (MWPV)**

Test Report No.: **TR-21J-217A**

Address: **Level 3 2nd Phase, BPO Bldg., UP Town Corporate Center, 216 Katipunan Ave., Diliman, Quezon City**

Date and Time Received: **05 Oct 2021 @03:55PM**

Contact Person: **Ms. Florisza I. Faustino**

Sampled By: **ECHEM**

COC Number: **2021-J0076**

Report Date: **15 Oct 2021**

Sample ID:	S21-J05-071D	Sampling Date:	05 Oct 2021
Sample Description:	Reservoir 1	Sampling Time:	09:45 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	05 Oct 2021 @05:20PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:20PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	05 Oct 2021 @07:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:20PM	AHP


Sample ID:	S21-J05-092D	Sampling Date:	05 Oct 2021
Sample Description:	Reservoir 2	Sampling Time:	12:30 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	05 Oct 2021 @06:23PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @06:23PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	05 Oct 2021 @07:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @06:23PM	AHP

Notes & References:

Standard Methods for the Examination of Water and Wastewater, 23rd Edition.
DOH Administrative Order No. 2017-0010, PNSDW 2017.

Certified by:


Anita H. Pineda, RMT
Medical Technologist, PRC No. 52546

Approved by:


May Ann M. Estavillo, RCh
QA/QC Manager, PRC No.8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
company seal



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

DOH Accreditation No.03-002-21-LW-2 Valid until December 31, 2023
DENR C.R.No. 074/2018 Valid until September 24, 2021

TEST REPORT

Client: **Manila Water Philippine Ventures (MWPV)**

Address: **Level 3 2nd Phase, BPO Bldg., UP Town Corporate Center, 216 Katipunan Ave., Diliman, Quezon City**

Contact Person: **Ms. Florisza I. Faustino**

COC Number: **2021-J0076**

Test Report No.: **TR-21J-217A**

Date and Time Received: **05 Oct 2021 @03:55PM**

Sampled By: **ECHEM**

Report Date: **15 Oct 2021**

Sample ID:	S21-J05-075D	Sampling Date:	05 Oct 2021
Sample Description:	Deepwell 7	Sampling Time:	10:20 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	05 Oct 2021 @05:32PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:32PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	05 Oct 2021 @07:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:32PM	AHP

Sample ID:	S21-J05-077D	Sampling Date:	05 Oct 2021
Sample Description:	Deepwell 6	Sampling Time:	10:37 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	05 Oct 2021 @05:38PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:38PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	05 Oct 2021 @07:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:38PM	AHP

Sample ID:	S21-J05-081D	Sampling Date:	05 Oct 2021
Sample Description:	Deepwell 5	Sampling Time:	11:10 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	05 Oct 2021 @05:50PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:50PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	05 Oct 2021 @07:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @05:50PM	AHP

Sample ID:	S21-J05-085D	Sampling Date:	05 Oct 2021
Sample Description:	Deepwell 8	Sampling Time:	11:35 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	05 Oct 2021 @06:02PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @06:02PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	05 Oct 2021 @07:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @06:02PM	AHP

Sample ID:	S21-J05-086D	Sampling Date:	05 Oct 2021
Sample Description:	Deepwell 9	Sampling Time:	11:50 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	05 Oct 2021 @06:05PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @06:05PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	05 Oct 2021 @07:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @06:05PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID:	S21-J05-088D	Sampling Date:	05 Oct 2021
Sample Description:	Deepwell 10	Sampling Time:	12:07 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	05 Oct 2021 @06:11PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @06:11PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	05 Oct 2021 @07:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @06:11PM	AHP


Sample ID:	S21-J05-089D	Sampling Date:	05 Oct 2021
Sample Description:	Deepwell 11	Sampling Time:	12:15 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	05 Oct 2021 @06:14PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @06:14PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	05 Oct 2021 @07:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	05 Oct 2021 @06:14PM	AHP


Notes & References:

Standard Methods for the Examination of Water and Wastewater, 23rd Edition.
DOH Administrative Order No. 2017-0010, PNSDW 2017.

Certified by:


Anita H. Pineda, RMT
Medical Technologist, PRC No. 52546

Approved by:


May Ann R. Estavillo, RCh
QA/QC Manager, PRC No.8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
company seal