



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: ecchemenvironmental@gmail.com
 Technical: 0917-164-2927 • 0917-164-2944

DOH Accreditation No.03-002-21-LW-2 Valid until December 31, 2023
 DENR C.R.No. 074/2021 Valid until September 28, 2024

TEST REPORT

Client: **Manila Water Philippine Ventures (MWPV)** Test Report No.: **TR-21K-201**
 Address: **Level 3 2nd Phase, BPO Bldg., UP Town Corporate Center, 216 Katipunan Ave., Diliman, Quezon City** Date and Time Received: **03 Nov 2021 @03:30PM**
 Contact Person: **Ms. Floriza I. Faustino** Sampled By: **ECHEM**
 COC Number: **2021-K0033** Report Date: **15 Nov 2021**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
Sample ID: S21-K03-070D Sampling Date: 03 Nov 2021 Sample Description: N5 Sampling Time: 08:05 AM Sample Matrix: Drinking Water Sampling Location: Anvaya Cove, Morong, Bataan							
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Nov 2021 @04:50PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @04:50PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Nov 2021 @06:24PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @04:50PM	AHP
Sample ID: S21-K03-071D Sampling Date: 03 Nov 2021 Sample Description: SRCC Boston Sampling Time: 08:15 AM Sample Matrix: Drinking Water Sampling Location: Anvaya Cove, Morong, Bataan							
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Nov 2021 @04:53PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @04:53PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Nov 2021 @06:24PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @04:53PM	AHP
Sample ID: S21-K03-073D Sampling Date: 03 Nov 2021 Sample Description: N7 Sampling Time: 08:25 AM Sample Matrix: Drinking Water Sampling Location: Anvaya Cove, Morong, Bataan							
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Nov 2021 @04:59PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @04:59PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Nov 2021 @06:24PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @04:59PM	AHP
Sample ID: S21-K03-074D Sampling Date: 03 Nov 2021 Sample Description: Mr. Gregorio Residence Sampling Time: 08:50 AM Sample Matrix: Drinking Water Sampling Location: Anvaya Cove, Morong, Bataan							
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Nov 2021 @05:02PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:02PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Nov 2021 @06:24PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:02PM	AHP
Sample ID: S21-K03-076D Sampling Date: 03 Nov 2021 Sample Description: N2 Sampling Time: 09:15 AM Sample Matrix: Drinking Water Sampling Location: Anvaya Cove, Morong, Bataan							
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Nov 2021 @05:08PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:08PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Nov 2021 @06:24PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:08PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: ecchemenvironmental@gmail.com
 Technical: 0917-164-2927 • 0917-164-2944

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
Sample ID: S21-K03-077D Sample Description: N1 Sample Matrix: Drinking Water Sampling Date: 03 Nov 2021 Sampling Time: 09:20 AM Sampling Location: Anvaya Cove, Morong, Bataan							
<i>E.coli</i>	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Nov 2021 @05:11PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:11PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Nov 2021 @06:24PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:11PM	AHP
Sample ID: S21-K03-078D Sample Description: N3 Sample Matrix: Drinking Water Sampling Date: 03 Nov 2021 Sampling Time: 09:25 AM Sampling Location: Anvaya Cove, Morong, Bataan							
<i>E.coli</i>	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Nov 2021 @05:14PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:14PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Nov 2021 @06:24PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:14PM	AHP
Sample ID: S21-K03-080D Sample Description: BNC Pawikan Sample Matrix: Drinking Water Sampling Date: 03 Nov 2021 Sampling Time: 09:50 AM Sampling Location: Anvaya Cove, Morong, Bataan							
<i>E.coli</i>	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Nov 2021 @05:20PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:20PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Nov 2021 @06:24PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:20PM	AHP
Sample ID: S21-K03-082D Sample Description: Beechcroft Sample Matrix: Drinking Water Sampling Date: 03 Nov 2021 Sampling Time: 10:15 AM Sampling Location: Anvaya Cove, Morong, Bataan							
<i>E.coli</i>	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Nov 2021 @05:26PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:26PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Nov 2021 @06:24PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:26PM	AHP
Sample ID: S21-K03-083D Sample Description: Villas Sample Matrix: Drinking Water Sampling Date: 03 Nov 2021 Sampling Time: 10:20 AM Sampling Location: Anvaya Cove, Morong, Bataan							
<i>E.coli</i>	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Nov 2021 @05:29PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:29PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Nov 2021 @06:24PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:29PM	AHP
Sample ID: S21-K03-084D Sample Description: BNC Backdoor Sample Matrix: Drinking Water Sampling Date: 03 Nov 2021 Sampling Time: 09:55 AM Sampling Location: Anvaya Cove, Morong, Bataan							
<i>E.coli</i>	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Nov 2021 @05:32PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:32PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Nov 2021 @06:24PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:32PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-164-2927 • 0917-164-2944

Sample ID:	S21-K03-086D	Sampling Date:	03 Nov 2021
Sample Description:	Sports Center Common Area	Sampling Time:	10:40 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Nov 2021 @05:38PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:38PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Nov 2021 @06:24PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:38PM	AHP

Sample ID:	S21-K03-087D	Sampling Date:	03 Nov 2021
Sample Description:	Sports Center Kitchen	Sampling Time:	10:45 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Nov 2021 @05:41PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:41PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Nov 2021 @06:24PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:41PM	AHP

Sample ID:	S21-K03-088D	Sampling Date:	03 Nov 2021
Sample Description:	Golf Kitchen	Sampling Time:	10:55 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Nov 2021 @05:44PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:44PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Nov 2021 @06:24PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:44PM	AHP

Sample ID:	S21-K03-089D	Sampling Date:	03 Nov 2021
Sample Description:	Caddie	Sampling Time:	11:00 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Nov 2021 @05:47PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:47PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Nov 2021 @06:24PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:47PM	AHP

Sample ID:	S21-K03-092D	Sampling Date:	03 Nov 2021
Sample Description:	N9	Sampling Time:	11:35 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Nov 2021 @05:56PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:56PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Nov 2021 @06:24PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:56PM	AHP

Sample ID:	S21-K03-095D	Sampling Date:	03 Nov 2021
Sample Description:	SBV Condo	Sampling Time:	11:45 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Nov 2021 @06:06PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @06:06PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Nov 2021 @06:24PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @06:06PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION


Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga
Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
Technical: 0917-164-2927 • 0917-164-2944

Sample ID:	S21-K03-096D				Sampling Date:	03 Nov 2021	
Sample Description:	NGB				Sampling Time:	12:00 PM	
Sample Matrix:	Drinking Water				Sampling Location:	Anvaya Cove, Morong, Bataan	
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Nov 2021 @06:09PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @06:09PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Nov 2021 @06:24PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @06:09PM	AHP

Notes & References:

Standard Methods for the Examination of Water and Wastewater, 23rd Edition.
DOH Administrative Order No. 2017-0010, PNSDW 2017.

Certified by:


Anita H. Pineda, RMT
Medical Technologist, PRC No. 52546

Approved by:


May Ann M. Estavillo, RCh
QA/QC Manager, PRC No. 8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
company seal



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-164-2927 • 0917-164-2944

DOH Accreditation No.03-002-21-LW-2 Valid until December 31, 2023
 DENR C.R.No. 074/2021 Valid until September 28, 2024

TEST REPORT


Client: **Manila Water Philippine Ventures (MWPV)** Test Report No.: **TR-21K-201**
 Address: **Level 3 2nd Phase, BPO Bldg., UP Town Corporate Center, 216 Katipunan Ave., Diliman, Quezon City** Date and Time Received: **03 Nov 2021 @03:30PM**
 Contact Person: **Ms. Florisza I. Faustino** Sampled By: **ECHEM**
 COC Number: **2021-K0033** Report Date: **15 Nov 2021**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
Sample ID: S21-K03-075D Sampling Date: 03 Nov 2021 Sample Description: Reservoir 1 Sampling Time: 09:00 AM Sample Matrix: Drinking Water Sampling Location: Anvaya Cove, Morong, Bataan							
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Nov 2021 @05:05PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:05PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Nov 2021 @06:24PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:05PM	AHP
Sample ID: S21-K03-097D Sampling Date: 03 Nov 2021 Sample Description: Reservoir 2 Sampling Time: 12:10 PM Sample Matrix: Drinking Water Sampling Location: Anvaya Cove, Morong, Bataan							
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Nov 2021 @06:12PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @06:12PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Nov 2021 @06:24PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @06:12PM	AHP


Notes & References:

Standard Methods for the Examination of Water and Wastewater, 23rd Edition.
 DOH Administrative Order No. 2017-0010, PNSDW 2017.

Certified by:


Arlita H. Pineda, RMT
 Medical Technologist, PRC No. 52546

Approved by:


May Ann M. Estavillo, RCh
 QA/QC Manager, PRC No. 8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
 company seal



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-164-2927 • 0917-164-2944

DOH Accreditation No.03-002-21-LW-2 Valid until December 31, 2023
 DENR C.R.No. 074/2021 Valid until September 28, 2024

TEST REPORT

Client: **Manila Water Philippine Ventures (MWPV)** Test Report No.: **TR-21K-201**
 Address: **Level 3 2nd Phase, BPO Bldg., UP Town Corporate Center, 216 Katipunan Ave., Diliman, Quezon City** Date and Time Received: **03 Nov 2021 @03:30PM**
 Contact Person: **Ms. Florisza I. Faustino** Sampled By: **ECHEM**
 COC Number: **2021-K0033** Report Date: **15 Nov 2021**

Sample ID: **S21-K03-079D** Sampling Date: **03 Nov 2021**
 Sample Description: **Deepwell 7** Sampling Time: **09:35 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Nov 2021 @05:17PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:17PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Nov 2021 @06:24PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:17PM	AHP

Sample ID: **S21-K03-081D** Sampling Date: **03 Nov 2021**
 Sample Description: **Deepwell 6** Sampling Time: **10:05 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Nov 2021 @05:23PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:23PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Nov 2021 @06:24PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:23PM	AHP

Sample ID: **S21-K03-085D** Sampling Date: **03 Nov 2021**
 Sample Description: **Deepwell 5** Sampling Time: **10:30 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Nov 2021 @05:35PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:35PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Nov 2021 @06:24PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:35PM	AHP

Sample ID: **S21-K03-090D** Sampling Date: **03 Nov 2021**
 Sample Description: **Deepwell 8** Sampling Time: **11:10 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Nov 2021 @05:50PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:50PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Nov 2021 @06:24PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:50PM	AHP

Sample ID: **S21-K03-091D** Sampling Date: **03 Nov 2021**
 Sample Description: **Deepwell 9** Sampling Time: **11:12 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Nov 2021 @05:53PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:53PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Nov 2021 @06:24PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:53PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-164-2927 • 0917-164-2944

Sample ID:	S21-K03-093D	Sampling Date:	03 Nov 2021
Sample Description:	Deepwell 10	Sampling Time:	11:30 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Nov 2021 @05:59PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:59PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Nov 2021 @06:24PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @05:59PM	AHP

Sample ID:	S21-K03-094D	Sampling Date:	03 Nov 2021
Sample Description:	Deepwell 11	Sampling Time:	11:40 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Nov 2021 @06:03PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @06:03PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Nov 2021 @06:24PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Nov 2021 @06:03PM	AHP

Notes & References:

Standard Methods for the Examination of Water and Wastewater, 23rd Edition.
 DOH Administrative Order No. 2017-0010, PNSDW 2017.

Certified by:

Anita H. Pineda 15 Nov 2021
Anita H. Pineda, RMT
 Medical Technologist, PRC No. 52546

Approved by:

May Ann M. Estavillo 15 Nov 2021
May Ann M. Estavillo, RCh
 QA/QC Manager, PRC No. 8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
 company seal