

30 APRIL 2020

ANVAYA COVE
Morong, Bataan

This report shows the result of MWPV's service level obligations for the month of APRIL 2020.

APRIL 2020 KPI REPORT

KPI	RESULT(S)	REMARKS
Water Production	128,989.3 m ³	-
Used Water Production	2,604.0 m ³	-
Water Quality Compliance	100%	28 samples for Bacteriological analysis. Iron and Manganese determination has already been included as parameter being tested by our laboratory-service provider. We'll provide the official test result once released.
Water Availability	24/7	
Pressure	Average pressure 35psi	23 pressure points

Initiative/s
<ul style="list-style-type: none"> On-going Improvement and Implementation of Branding for facilities *Standard repainting of facilities and imprinting of logos

PREPARED BY:


BELLVIN Y. SANCHEZ
NCL 1 – Territory Manager

NOTED BY:


MANUEL JOSE M. VARGAS
Estate Water- Business Zone Manager

This report is for internal purposes only between MWPV and APMC. This may not be reproduced in part or in full and may not be used for any advertisement or litigation purposes without permission from Manila Water Philippine Ventures.