



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

DOH Accreditation No.03-002-21-LW-2 Valid until December 31, 2023

DENR C.R.No. 074/2018 Valid until September 24, 2021

TEST REPORT

Client: **Manila Water Philippine Ventures (MWPV)**

Address: **Level 3 2nd Phase, BPO Bldg., UP Town Corporate Center, 216 Katipunan Ave., Diliman, Quezon City**

Contact Person: **Ms. Florisza I. Faustino**

COC Number: **2021-H0005**

Test Report No.: **TR-21H-130**

Date and Time Received: **02 Aug 2021 @04:00PM**

Sampled By: **ECHEM**

Report Date: **11 Aug 2021**

Sample ID:	S21-H02-015D	Sampling Date:	02 Aug 2021
Sample Description:	N5	Sampling Time:	10:15 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Aug 2021 @06:30PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @06:30PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Aug 2021 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @06:30PM	AHP

Sample ID:	S21-H02-016D	Sampling Date:	02 Aug 2021
Sample Description:	SRCC Boston	Sampling Time:	10:30 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Aug 2021 @06:33PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @06:33PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Aug 2021 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @06:33PM	AHP

Sample ID:	S21-H02-017D	Sampling Date:	02 Aug 2021
Sample Description:	N4	Sampling Time:	10:38 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Aug 2021 @06:36PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @06:36PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Aug 2021 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @06:36PM	AHP

Sample ID:	S21-H02-018D	Sampling Date:	02 Aug 2021
Sample Description:	N7	Sampling Time:	10:49 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Aug 2021 @06:39PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @06:39PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Aug 2021 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @06:39PM	AHP

Sample ID:	S21-H02-019D	Sampling Date:	02 Aug 2021
Sample Description:	Mr. Gregorio Residence	Sampling Time:	10:58 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Aug 2021 @06:42PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @06:42PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Aug 2021 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @06:42PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: ecchemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID:	S21-H02-021D	Sampling Date:	02 Aug 2021
Sample Description:	N2	Sampling Time:	11:17 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Aug 2021 @06:48PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @06:48PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Aug 2021 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @06:48PM	AHP

Sample ID:	S21-H02-022D	Sampling Date:	02 Aug 2021
Sample Description:	N1	Sampling Time:	11:25 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Aug 2021 @06:51PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @06:51PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Aug 2021 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @06:51PM	AHP

Sample ID:	S21-H02-023D	Sampling Date:	02 Aug 2021
Sample Description:	N3	Sampling Time:	11:32 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Aug 2021 @06:54PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @06:54PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Aug 2021 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @06:54PM	AHP

Sample ID:	S21-H02-025D	Sampling Date:	02 Aug 2021
Sample Description:	BNC Pawikan	Sampling Time:	11:54 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Aug 2021 @07:00PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @07:00PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Aug 2021 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @07:00PM	AHP

Sample ID:	S21-H02-027D	Sampling Date:	02 Aug 2021
Sample Description:	Beechcroft	Sampling Time:	12:17 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Aug 2021 @07:06PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @07:06PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Aug 2021 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @07:06PM	AHP

Sample ID:	S21-H02-028D	Sampling Date:	02 Aug 2021
Sample Description:	Villas	Sampling Time:	12:22 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Aug 2021 @07:09PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @07:09PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Aug 2021 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @07:09PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID:	S21-H02-029D	Sampling Date:	02 Aug 2021
Sample Description:	BNC Backdoor	Sampling Time:	12:27 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Aug 2021 @07:12PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @07:12PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Aug 2021 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @07:12PM	AHP

Sample ID:	S21-H02-031D	Sampling Date:	02 Aug 2021
Sample Description:	Sports Center Common Area	Sampling Time:	12:39 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Aug 2021 @07:18PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @07:18PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Aug 2021 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @07:18PM	AHP

Sample ID:	S21-H02-032D	Sampling Date:	02 Aug 2021
Sample Description:	Sports Center Kitchen	Sampling Time:	12:43 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Aug 2021 @07:21PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @07:21PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Aug 2021 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @07:21PM	AHP

Sample ID:	S21-H02-033D	Sampling Date:	02 Aug 2021
Sample Description:	Golf Kitchen	Sampling Time:	12:48 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Aug 2021 @07:24PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @07:24PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Aug 2021 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @07:24PM	AHP

Sample ID:	S21-H02-034D	Sampling Date:	02 Aug 2021
Sample Description:	Caddle	Sampling Time:	01:14 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Aug 2021 @07:27PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @07:27PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Aug 2021 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @07:27PM	AHP

Sample ID:	S21-H02-037D	Sampling Date:	02 Aug 2021
Sample Description:	N9	Sampling Time:	01:39 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Aug 2021 @07:36PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @07:36PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Aug 2021 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @07:36PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID:	S21-H02-039D	Sampling Date:	02 Aug 2021
Sample Description:	SBV Condo	Sampling Time:	01:54 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Aug 2021 @07:42PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @07:42PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Aug 2021 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @07:42PM	AHP

Sample ID:	S21-H02-041D	Sampling Date:	02 Aug 2021
Sample Description:	N6B	Sampling Time:	02:15 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Aug 2021 @07:48PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @07:48PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Aug 2021 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @07:48PM	AHP

Notes & References:

Standard Methods for the Examination of Water and Wastewater, 23rd Edition.
DOH Administrative Order No. 2017-0010, PNSDW 2017.

Certified by:

Anita H. Pineda 11 Aug 2021
Anita H. Pineda, RMT
Medical Technologist, PRC No. 52546

Approved by:

May Ann M. Estavillo 11 Aug 2021
May Ann M. Estavillo, RCh
QA/QC Manager, PRC No. 8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
company seal



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

DOH Accreditation No.03-002-21-LW-2 Valid until December 31, 2023

DENR C.R.No. 074/2018 Valid until September 24, 2021

TEST REPORT

Client: **Manila Water Philippine Ventures (MWPV)**

Address: **Level 3 2nd Phase, BPO Bldg., UP Town Corporate Center, 216 Katipunan Ave., Diliman, Quezon City**

Contact Person: **Ms. Florisza I. Faustino**

COC Number: **2021-H0005**

Test Report No.: **TR-21H-130**

Date and Time Received: **02 Aug 2021 @04:00PM**

Sampled By: **ECHEM**

Report Date: **11 Aug 2021**

Sample ID:	S21-H02-020D	Sampling Date:	02 Aug 2021
Sample Description:	Reservoir 1	Sampling Time:	11:09 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Aug 2021 @06:45PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @06:45PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Aug 2021 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @06:45PM	AHP


Sample ID:	S21-H02-040D	Sampling Date:	02 Aug 2021
Sample Description:	Reservoir 2	Sampling Time:	02:10 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Aug 2021 @07:45PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @07:45PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Aug 2021 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @07:45PM	AHP

Notes & References:

Standard Methods for the Examination of Water and Wastewater, 23rd Edition.
DOH Administrative Order No. 2017-0010, PNSDW 2017.

Certified by:


Anita H. Pineda, RMT
Medical Technologist, PRC No. 52546

Approved by:


May Ann M. Estavillo, RCI
QA/QC Manager, PRC No.8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
company seal



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: ecchemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

DOH Accreditation No.03-002-21-LW-2 Valid until December 31, 2023

DENR C.R.No. 074/2018 Valid until September 24, 2021

TEST REPORT

Client: **Manila Water Philippine Ventures (MWPV)**

Address: **Level 3 2nd Phase, BPO Bldg., UP Town Corporate Center, 216 Katipunan Ave., Diliman, Quezon City**

Contact Person: **Ms. Florisza I. Faustino**

COC Number: **2021-H0005**

Test Report No.: **TR-21H-130**

Date and Time Received: **02 Aug 2021 @04:00PM**

Sampled By: **ECHEM**

Report Date: **11 Aug 2021**

Sample ID:	S21-H02-024D	Sampling Date:	02 Aug 2021
Sample Description:	Deepwell 7	Sampling Time:	11:45 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Aug 2021 @06:57PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @06:57PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Aug 2021 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @06:57PM	AHP

Sample ID:	S21-H02-026D	Sampling Date:	02 Aug 2021
Sample Description:	Deepwell 6	Sampling Time:	12:10 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Aug 2021 @07:03PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @07:03PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Aug 2021 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @07:03PM	AHP

Sample ID:	S21-H02-030D	Sampling Date:	02 Aug 2021
Sample Description:	Deepwell 5	Sampling Time:	12:35 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Aug 2021 @07:15PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @07:15PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Aug 2021 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @07:15PM	AHP

Sample ID:	S21-H02-035D	Sampling Date:	02 Aug 2021
Sample Description:	Deepwell 8	Sampling Time:	01:20 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Aug 2021 @07:30PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @07:30PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Aug 2021 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @07:30PM	AHP

Sample ID:	S21-H02-036D	Sampling Date:	02 Aug 2021
Sample Description:	Deepwell 9	Sampling Time:	01:31 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Aug 2021 @07:33PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @07:33PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Aug 2021 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @07:33PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID:	S21-H02-038D	Sampling Date:	02 Aug 2021
Sample Description:	Deepwell 10	Sampling Time:	01:48 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Aug 2021 @07:39PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @07:39PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Aug 2021 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @07:39PM	AHP

Sample ID:	S21-H02-042D	Sampling Date:	02 Aug 2021
Sample Description:	Deepwell 11	Sampling Time:	02:30 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Aug 2021 @07:51PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @07:51PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Aug 2021 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Aug 2021 @07:51PM	AHP

Notes & References:

Standard Methods for the Examination of Water and Wastewater, 23rd Edition.
DOH Administrative Order No. 2017-0010, PNSDW 2017.

Certified by:

Anita H. Pineda 11 Aug 2021
Anita H. Pineda, RMT
Medical Technologist, PRC No. 52546

Approved by:

May Ann M. Estavillo 11 Aug 2021
May Ann M. Estavillo, RCh
QA/QC Manager, PRC No. 8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
company seal