



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-507-8753 • 0917-164-2944

DOH Accreditation No.03-010-2325-LW-2 Valid until December 31, 2025
DENR C.R.No. 074/2023 Valid until June 24, 2026

TEST REPORT

Client: **Manila Water Philippine Ventures (MWPV)**
Address: **3rd Floor, One Joroma Place, Congressional Avenue, Quezon City**
Contact Person: **Ms. Florisza I. Faustino**
COC Number: **2024-A0006**

Test Report No.: **TR-24A-044A**
Date and Time Received: **02 Jan 2024 @05:00PM**
Sampled By: **ECHEM**
Report Date: **31 Jan 2024**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Color, Apparent	<5 @7.76	CU	10	Visual Comparison	03 Jan 2024	MCD
Nitrate as NO ₃ -N	<0.05	mg/L	50	Colorimetric, Brucine	03 Jan 2024	CSF
Chlorine, Residual	0.8	---	0.3-1.5	Colorimetric	02 Jan 2024	MGF
Iron	<0.005	mg/L	1.0	Phenanthroline	09 Jan 2024	CSF
pH (on-site)	7.89 @28.6°C	---	6.5-8.5	Electrometric	02 Jan 2024	MGF
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	03 Jan 2024	MCD
Total Dissolved Solids (TDS)	299	mg/L	600	Gravimetric, Dried @180°C	03 Jan 2024	MCD
Sulfate	<1.0	mg/L	250	Turbidimetric	03 Jan 2024	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	03 Jan 2024	TGG
Arsenic	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	03 Jan 2024	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF

Sample ID: **S24-A02-008D**
Sample Description: **SRCC Boston**
Sample Matrix: **Drinking Water**

Sampling Date: **02 Jan 2024**
Sampling Time: **10:27 AM**
Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Color, Apparent	<5 @7.64	CU	10	Visual Comparison	03 Jan 2024	MCD
Nitrate as NO ₃ -N	0.08	mg/L	50	Colorimetric, Brucine	03 Jan 2024	CSF
Chlorine, Residual	0.8	---	0.3-1.5	Colorimetric	02 Jan 2024	MGF
Iron	<0.005	mg/L	1.0	Phenanthroline	09 Jan 2024	CSF
pH (on-site)	7.59 @28.9°C	---	6.5-8.5	Electrometric	02 Jan 2024	MGF
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	03 Jan 2024	MCD
Total Dissolved Solids (TDS)	279	mg/L	600	Gravimetric, Dried @180°C	03 Jan 2024	MCD
Sulfate	<1.0	mg/L	250	Turbidimetric	03 Jan 2024	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	03 Jan 2024	TGG
Arsenic	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	03 Jan 2024	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID: S24-A02-009D				Sampling Date: 02 Jan 2024		
Sample Description: N4				Sampling Time: 10:32 AM		
Sample Matrix: Drinking Water				Sampling Location: Anvaya Cove, Morong, Bataan		
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Color, Apparent	<5 @7.64	CU	10	Visual Comparison	03 Jan 2024	MCD
Nitrate as NO ₃ N	<0.05	mg/L	50	Colorimetric, Brucine	03 Jan 2024	CSF
Chlorine, Residual	0.8	---	0.3-1.5	Colorimetric	02 Jan 2024	MGF
Iron	<0.005	mg/L	1.0	Phenanthroline	09 Jan 2024	CSF
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	03 Jan 2024	MCD
pH (on-site)	7.45 @28.7°C	---	6.5-8.5	Electrometric	02 Jan 2024	MGF
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	03 Jan 2024	MCD
Total Dissolved Solids (TDS)	279	mg/L	600	Gravimetric, Dried @180°C	03 Jan 2024	MCD
Sulfate	<1.0	mg/L	250	Turbidimetric	03 Jan 2024	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	03 Jan 2024	TGG
Arsenic	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	03 Jan 2024	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF

Sample ID: S24-A02-010D				Sampling Date: 02 Jan 2024		
Sample Description: N7				Sampling Time: 10:40 AM		
Sample Matrix: Drinking Water				Sampling Location: Anvaya Cove, Morong, Bataan		
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Color, Apparent	<5 @7.65	CU	10	Visual Comparison	03 Jan 2024	MCD
Nitrate as NO ₃ N	<0.05	mg/L	50	Colorimetric, Brucine	03 Jan 2024	CSF
Chlorine, Residual	0.8	---	0.3-1.5	Colorimetric	02 Jan 2024	MGF
Iron	<0.005	mg/L	1.0	Phenanthroline	09 Jan 2024	CSF
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	03 Jan 2024	MCD
pH (on-site)	7.76 @29.1°C	---	6.5-8.5	Electrometric	02 Jan 2024	MGF
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	03 Jan 2024	MCD
Total Dissolved Solids (TDS)	295	mg/L	600	Gravimetric, Dried @180°C	03 Jan 2024	MCD
Sulfate	<1.0	mg/L	250	Turbidimetric	03 Jan 2024	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	03 Jan 2024	TGG
Arsenic	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	03 Jan 2024	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF

Sample ID: S24-A02-011D				Sampling Date: 02 Jan 2024		
Sample Description: Tulfo Residence				Sampling Time: 10:48 AM		
Sample Matrix: Drinking Water				Sampling Location: Anvaya Cove, Morong, Bataan		
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Color, Apparent	<5 @7.69	CU	10	Visual Comparison	03 Jan 2024	MCD
Nitrate as NO ₃ N	<0.05	mg/L	50	Colorimetric, Brucine	03 Jan 2024	CSF
Chlorine, Residual	0.8	---	0.3-1.5	Colorimetric	02 Jan 2024	MGF
Iron	<0.005	mg/L	1.0	Phenanthroline	09 Jan 2024	CSF
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	03 Jan 2024	MCD
pH (on-site)	7.47 @28.9°C	---	6.5-8.5	Electrometric	02 Jan 2024	MGF
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	03 Jan 2024	MCD
Total Dissolved Solids (TDS)	291	mg/L	600	Gravimetric, Dried @180°C	03 Jan 2024	MCD
Sulfate	<1.0	mg/L	250	Turbidimetric	03 Jan 2024	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	03 Jan 2024	TGG
Arsenic	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	03 Jan 2024	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID: **S24-A02-013D**
 Sample Description: **N2**
 Sample Matrix: **Drinking Water**

Sampling Date: **02 Jan 2024**
 Sampling Time: **11:10 AM**
 Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Color, Apparent	<5 @7.66	CU	10	Visual Comparison	03 Jan 2024	MCD
Nitrate as NO ₃ N	<0.05	mg/L	50	Colorimetric, Brucine	03 Jan 2024	CSF
Chlorine, Residual	0.8	---	0.3-1.5	Colorimetric	02 Jan 2024	MGF
Iron	<0.005	mg/L	1.0	Phenanthroline	09 Jan 2024	CSF
Manganese	0.40	mg/L	0.40	Persulfate	09 Jan 2024	CSF
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	03 Jan 2024	MCD
pH (on-site)	7.70 @28.9°C	---	6.5-8.5	Electrometric	02 Jan 2024	MGF
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	03 Jan 2024	MCD
Total Dissolved Solids (TDS)	267	mg/L	600	Gravimetric, Dried @180°C	03 Jan 2024	MCD
Sulfate	<1.0	mg/L	250	Turbidimetric	03 Jan 2024	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	03 Jan 2024	TGG
Arsenic	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	03 Jan 2024	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF

Sample ID: **S24-A02-014D**
 Sample Description: **N1**
 Sample Matrix: **Drinking Water**

Sampling Date: **02 Jan 2024**
 Sampling Time: **11:18 AM**
 Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Color, Apparent	<5 @7.69	CU	10	Visual Comparison	03 Jan 2024	MCD
Nitrate as NO ₃ N	<0.05	mg/L	50	Colorimetric, Brucine	03 Jan 2024	CSF
Chlorine, Residual	0.8	---	0.3-1.5	Colorimetric	02 Jan 2024	MGF
Iron	<0.005	mg/L	1.0	Phenanthroline	09 Jan 2024	CSF
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	03 Jan 2024	MCD
pH (on-site)	7.90 @28.9°C	---	6.5-8.5	Electrometric	02 Jan 2024	MGF
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	03 Jan 2024	MCD
Total Dissolved Solids (TDS)	286	mg/L	600	Gravimetric, Dried @180°C	03 Jan 2024	MCD
Sulfate	<1.0	mg/L	250	Turbidimetric	03 Jan 2024	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	03 Jan 2024	TGG
Arsenic	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	03 Jan 2024	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF

Sample ID: **S24-A02-015D**
 Sample Description: **N3**
 Sample Matrix: **Drinking Water**

Sampling Date: **02 Jan 2024**
 Sampling Time: **11:30 AM**
 Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Color, Apparent	<5 @7.72	CU	10	Visual Comparison	03 Jan 2024	MCD
Nitrate as NO ₃ N	<0.05	mg/L	50	Colorimetric, Brucine	03 Jan 2024	CSF
Chlorine, Residual	0.8	---	0.3-1.5	Colorimetric	02 Jan 2024	MGF
Iron	<0.005	mg/L	1.0	Phenanthroline	09 Jan 2024	CSF
pH (on-site)	8.41 @29.1°C	---	6.5-8.5	Electrometric	02 Jan 2024	MGF
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	03 Jan 2024	MCD
Total Dissolved Solids (TDS)	279	mg/L	600	Gravimetric, Dried @180°C	03 Jan 2024	MCD
Sulfate	<1.0	mg/L	250	Turbidimetric	03 Jan 2024	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	03 Jan 2024	TGG
Arsenic	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	03 Jan 2024	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID: **S24-A02-017D**
 Sample Description: **S1**
 Sample Matrix: **Drinking Water**

Sampling Date: **02 Jan 2024**
 Sampling Time: **11:48 AM**
 Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Color, Apparent	<5 @7.71	CU	10	Visual Comparison	03 Jan 2024	MCD
Nitrate as NO ₃ -N	<0.05	mg/L	50	Colorimetric, Brucine	03 Jan 2024	CSF
Chlorine, Residual	0.8	---	0.3-1.5	Colorimetric	02 Jan 2024	MGF
Iron	<0.005	mg/L	1.0	Phenanthroline	09 Jan 2024	CSF
Manganese	0.40	mg/L	0.40	Persulfate	09 Jan 2024	CSF
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	03 Jan 2024	MCD
pH (on-site)	7.40 @29.1°C	---	6.5-8.5	Electrometric	02 Jan 2024	MGF
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	03 Jan 2024	MCD
Total Dissolved Solids (TDS)	271	mg/L	600	Gravimetric, Dried @180°C	03 Jan 2024	MCD
Sulfate	<1.0	mg/L	250	Turbidimetric	03 Jan 2024	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	03 Jan 2024	TGG
Arsenic	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	03 Jan 2024	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF

Sample ID: **S24-A02-018D**
 Sample Description: **S2A**
 Sample Matrix: **Drinking Water**

Sampling Date: **02 Jan 2024**
 Sampling Time: **11:52 AM**
 Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Color, Apparent	5 @7.72	CU	10	Visual Comparison	03 Jan 2024	MCD
Nitrate as NO ₃ -N	<0.05	mg/L	50	Colorimetric, Brucine	03 Jan 2024	CSF
Chlorine, Residual	0.8	---	0.3-1.5	Colorimetric	02 Jan 2024	MGF
Iron	<0.005	mg/L	1.0	Phenanthroline	09 Jan 2024	CSF
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	03 Jan 2024	MCD
pH (on-site)	7.35 @29.6°C	---	6.5-8.5	Electrometric	02 Jan 2024	MGF
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	03 Jan 2024	MCD
Total Dissolved Solids (TDS)	273	mg/L	600	Gravimetric, Dried @180°C	03 Jan 2024	MCD
Sulfate	<1.0	mg/L	250	Turbidimetric	03 Jan 2024	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	03 Jan 2024	TGG
Arsenic	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	03 Jan 2024	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF

Sample ID: **S24-A02-019D**
 Sample Description: **BNC Pawikan**
 Sample Matrix: **Drinking Water**

Sampling Date: **02 Jan 2024**
 Sampling Time: **12:20 PM**
 Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Color, Apparent	5 @7.73	CU	10	Visual Comparison	03 Jan 2024	MCD
Nitrate as NO ₃ -N	<0.05	mg/L	50	Colorimetric, Brucine	03 Jan 2024	CSF
Chlorine, Residual	0.8	---	0.3-1.5	Colorimetric	02 Jan 2024	MGF
Iron	<0.005	mg/L	1.0	Phenanthroline	09 Jan 2024	CSF
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	03 Jan 2024	MCD
pH (on-site)	7.20 @28.8°C	---	6.5-8.5	Electrometric	02 Jan 2024	MGF
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	03 Jan 2024	MCD
Total Dissolved Solids (TDS)	285	mg/L	600	Gravimetric, Dried @180°C	03 Jan 2024	MCD
Sulfate	<1.0	mg/L	250	Turbidimetric	03 Jan 2024	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	03 Jan 2024	TGG
Arsenic	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	03 Jan 2024	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID: **S24-A02-020D**
 Sample Description: **Villas**
 Sample Matrix: **Drinking Water**

Sampling Date: **02 Jan 2024**
 Sampling Time: **12:30 PM**
 Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Color, Apparent	<5 @7.72	CU	10	Visual Comparison	03 Jan 2024	MCD
Nitrate as NO ₃ N	<0.05	mg/L	50	Colorimetric, Brucine	03 Jan 2024	CSF
Chlorine, Residual	0.8	—	0.3-1.5	Colorimetric	02 Jan 2024	MGF
Iron	<0.005	mg/L	1.0	Phenanthroline	09 Jan 2024	CSF
pH (on-site)	8.10 @29.8°C	—	6.5-8.5	Electrometric	02 Jan 2024	MGF
Taste	No Objectional Taste	—	No Objectional Taste	Flavor Threshold Test	03 Jan 2024	MCD
Total Dissolved Solids (TDS)	274	mg/L	600	Gravimetric, Dried @180°C	03 Jan 2024	MCD
Sulfate	<1.0	mg/L	250	Turbidimetric	03 Jan 2024	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	03 Jan 2024	TGG
Arsenic	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	03 Jan 2024	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF

Sample ID: **S24-A02-021D**
 Sample Description: **BNC Back Door**
 Sample Matrix: **Drinking Water**

Sampling Date: **02 Jan 2024**
 Sampling Time: **12:36 PM**
 Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Color, Apparent	<5 @7.70	CU	10	Visual Comparison	03 Jan 2024	MCD
Nitrate as NO ₃ N	<0.05	mg/L	50	Colorimetric, Brucine	03 Jan 2024	CSF
Chlorine, Residual	0.8	—	0.3-1.5	Colorimetric	02 Jan 2024	MGF
Iron	<0.005	mg/L	1.0	Phenanthroline	09 Jan 2024	CSF
Odor	No Objectional Odor	—	No Objectional Odor	Threshold Odor Test	03 Jan 2024	MCD
pH (on-site)	7.80 @28.7°C	—	6.5-8.5	Electrometric	02 Jan 2024	MGF
Taste	No Objectional Taste	—	No Objectional Taste	Flavor Threshold Test	03 Jan 2024	MCD
Total Dissolved Solids (TDS)	277	mg/L	600	Gravimetric, Dried @180°C	03 Jan 2024	MCD
Sulfate	<1.0	mg/L	250	Turbidimetric	03 Jan 2024	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	03 Jan 2024	TGG
Arsenic	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	03 Jan 2024	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF

Sample ID: **S24-A02-022D**
 Sample Description: **Beech Croft**
 Sample Matrix: **Drinking Water**

Sampling Date: **02 Jan 2024**
 Sampling Time: **12:41 PM**
 Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Color, Apparent	<5 @7.70	CU	10	Visual Comparison	03 Jan 2024	MCD
Nitrate as NO ₃ N	<0.05	mg/L	50	Colorimetric, Brucine	03 Jan 2024	CSF
Chlorine, Residual	0.8	—	0.3-1.5	Colorimetric	02 Jan 2024	MGF
Iron	<0.005	mg/L	1.0	Phenanthroline	09 Jan 2024	CSF
pH (on-site)	7.86 @28.8°C	—	6.5-8.5	Electrometric	02 Jan 2024	MGF
Taste	No Objectional Taste	—	No Objectional Taste	Flavor Threshold Test	03 Jan 2024	MCD
Total Dissolved Solids (TDS)	268	mg/L	600	Gravimetric, Dried @180°C	03 Jan 2024	MCD
Sulfate	<1.0	mg/L	250	Turbidimetric	03 Jan 2024	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	03 Jan 2024	TGG
Arsenic	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	03 Jan 2024	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID: S24-A02-024D				Sampling Date: 02 Jan 2024		
Sample Description: Sports Center Common Area				Sampling Time: 12:59 PM		
Sample Matrix: Drinking Water				Sampling Location: Anvaya Cove, Morong, Bataan		
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Color, Apparent	<5 @7.68	CU	10	Visual Comparison	03 Jan 2024	MCD
Nitrate as NO ₃ N	<0.05	mg/L	50	Colorimetric, Brucine	03 Jan 2024	CSF
Chlorine, Residual	0.8	—	0.3-1.5	Colorimetric	02 Jan 2024	MGF
Iron	<0.005	mg/L	1.0	Phenanthroline	09 Jan 2024	CSF
pH (on-site)	7.70 @28.8°C	—	6.5-8.5	Electrometric	02 Jan 2024	MGF
Taste	No Objectional Taste	—	No Objectional Taste	Flavor Threshold Test	03 Jan 2024	MCD
Total Dissolved Solids (TDS)	299	mg/L	600	Gravimetric, Dried @180°C	03 Jan 2024	MCD
Sulfate	<1.0	mg/L	250	Turbidimetric	03 Jan 2024	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	03 Jan 2024	TGG
Arsenic	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	03 Jan 2024	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF

Sample ID: S24-A02-025D				Sampling Date: 02 Jan 2024		
Sample Description: Sports Center Kitchen				Sampling Time: 01:04 PM		
Sample Matrix: Drinking Water				Sampling Location: Anvaya Cove, Morong, Bataan		
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Color, Apparent	<5 @7.70	CU	10	Visual Comparison	03 Jan 2024	MCD
Nitrate as NO ₃ N	<0.05	mg/L	50	Colorimetric, Brucine	03 Jan 2024	CSF
Chlorine, Residual	0.8	—	0.3-1.5	Colorimetric	02 Jan 2024	MGF
Iron	<0.005	mg/L	1.0	Phenanthroline	09 Jan 2024	CSF
Odor	No Objectional Odor	—	No Objectional Odor	Threshold Odor Test	03 Jan 2024	MCD
pH (on-site)	7.86 @28.9°C	—	6.5-8.5	Electrometric	02 Jan 2024	MGF
Taste	No Objectional Taste	—	No Objectional Taste	Flavor Threshold Test	03 Jan 2024	MCD
Total Dissolved Solids (TDS)	273	mg/L	600	Gravimetric, Dried @180°C	03 Jan 2024	MCD
Sulfate	<1.0	mg/L	250	Turbidimetric	03 Jan 2024	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	03 Jan 2024	TGG
Arsenic	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	03 Jan 2024	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF

Sample ID: S24-A02-026D				Sampling Date: 02 Jan 2024		
Sample Description: Golf Kitchen				Sampling Time: 01:15 PM		
Sample Matrix: Drinking Water				Sampling Location: Anvaya Cove, Morong, Bataan		
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Color, Apparent	<5 @7.71	CU	10	Visual Comparison	03 Jan 2024	MCD
Nitrate as NO ₃ N	<0.05	mg/L	50	Colorimetric, Brucine	03 Jan 2024	CSF
Chlorine, Residual	0.8	—	0.3-1.5	Colorimetric	02 Jan 2024	MGF
Iron	<0.005	mg/L	1.0	Phenanthroline	09 Jan 2024	CSF
pH (on-site)	7.70 @28.7°C	—	6.5-8.5	Electrometric	02 Jan 2024	MGF
Taste	No Objectional Taste	—	No Objectional Taste	Flavor Threshold Test	03 Jan 2024	MCD
Total Dissolved Solids (TDS)	284	mg/L	600	Gravimetric, Dried @180°C	03 Jan 2024	MCD
Sulfate	<1.0	mg/L	250	Turbidimetric	03 Jan 2024	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	03 Jan 2024	TGG
Arsenic	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	03 Jan 2024	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID: **S24-A02-027D**
 Sample Description: **Caddie**
 Sample Matrix: **Drinking Water**

Sampling Date: **02 Jan 2024**
 Sampling Time: **01:20 PM**
 Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Color, Apparent	<5 @7.73	CU	10	Visual Comparison	03 Jan 2024	MCD
Nitrate as NO ₃ N	<0.05	mg/L	50	Colorimetric, Brucine	03 Jan 2024	CSF
Chlorine, Residual	0.8	---	0.3-1.5	Colorimetric	02 Jan 2024	MGF
Iron	<0.005	mg/L	1.0	Phenanthroline	09 Jan 2024	CSF
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	03 Jan 2024	MCD
pH (on-site)	7.40 @28.8°C	---	6.5-8.5	Electrometric	02 Jan 2024	MGF
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	03 Jan 2024	MCD
Total Dissolved Solids (TDS)	292	mg/L	600	Gravimetric, Dried @180°C	03 Jan 2024	MCD
Sulfate	<1.0	mg/L	250	Turbidimetric	03 Jan 2024	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	03 Jan 2024	TGG
Arsenic	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	03 Jan 2024	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF

Sample ID: **S24-A02-030D**
 Sample Description: **N9**
 Sample Matrix: **Drinking Water**

Sampling Date: **02 Jan 2024**
 Sampling Time: **01:40 PM**
 Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Color, Apparent	5 @7.73	CU	10	Visual Comparison	03 Jan 2024	MCD
Nitrate as NO ₃ N	<0.05	mg/L	50	Colorimetric, Brucine	03 Jan 2024	CSF
Chlorine, Residual	0.8	---	0.3-1.5	Colorimetric	02 Jan 2024	MGF
Iron	<0.005	mg/L	1.0	Phenanthroline	09 Jan 2024	CSF
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	03 Jan 2024	MCD
pH (on-site)	7.48 @29.1°C	---	6.5-8.5	Electrometric	02 Jan 2024	MGF
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	03 Jan 2024	MCD
Total Dissolved Solids (TDS)	311	mg/L	600	Gravimetric, Dried @180°C	03 Jan 2024	MCD
Sulfate	<1.0	mg/L	250	Turbidimetric	03 Jan 2024	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	03 Jan 2024	TGG
Arsenic	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	03 Jan 2024	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF

Sample ID: **S24-A02-033D**
 Sample Description: **N6B**
 Sample Matrix: **Drinking Water**

Sampling Date: **02 Jan 2024**
 Sampling Time: **02:01 PM**
 Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Color, Apparent	5 @7.81	CU	10	Visual Comparison	03 Jan 2024	MCD
Nitrate as NO ₃ N	<0.05	mg/L	50	Colorimetric, Brucine	03 Jan 2024	CSF
Chlorine, Residual	0.8	---	0.3-1.5	Colorimetric	02 Jan 2024	MGF
Iron	<0.005	mg/L	1.0	Phenanthroline	09 Jan 2024	CSF
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	03 Jan 2024	MCD
pH (on-site)	7.13 @28.9°C	---	6.5-8.5	Electrometric	02 Jan 2024	MGF
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	03 Jan 2024	MCD
Total Dissolved Solids (TDS)	283	mg/L	600	Gravimetric, Dried @180°C	03 Jan 2024	MCD
Sulfate	<1.0	mg/L	250	Turbidimetric	03 Jan 2024	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	03 Jan 2024	TGG
Arsenic	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	03 Jan 2024	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID:	S24-A02-035D			Sampling Date:	02 Jan 2024	
Sample Description:	SBV Condo			Sampling Time:	02:14 PM	
Sample Matrix:	Drinking Water			Sampling Location:	Anvaya Cove, Morong, Bataan	
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Color, Apparent	10 @7.80	CU	10	Visual Comparison	03 Jan 2024	MCD
Nitrate as NO ₃ N	<0.05	mg/L	50	Colorimetric, Brucine	03 Jan 2024	CSF
Chlorine, Residual	0.8	—	0.3-1.5	Colorimetric	02 Jan 2024	MGF
Iron	<0.005	mg/L	1.0	Phenanthroline	09 Jan 2024	CSF
Odor	No Objectional Odor	—	No Objectional Odor	Threshold Odor Test	03 Jan 2024	MCD
pH (on-site)	7.20 @27.9°C	—	6.5-8.5	Electrometric	02 Jan 2024	MGF
Taste	No Objectional Taste	—	No Objectional Taste	Flavor Threshold Test	03 Jan 2024	MCD
Total Dissolved Solids (TDS)	301	mg/L	600	Gravimetric, Dried @180°C	03 Jan 2024	MCD
Sulfate	<1.0	mg/L	250	Turbidimetric	03 Jan 2024	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	03 Jan 2024	TGG
Arsenic	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	03 Jan 2024	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF

Notes & References:

Standard Methods for the Examination of Water and Wastewater, 24th Edition.
 DOH Administrative Order No. 2017-0010, PNSDW 2017.
 Test Methods for Evaluating Solid Wastes, Vol 1A, USEPA, Third Edition.
 ICP - OES = Inductively Coupled Plasma - Optical Emission Spectroscopy

Certified by:

Lovely Grace D. Montoya 01 Feb 2024
 Lovely Grace D. Montoya, RCh
 Chemist, PRC No. 13651

Approved by:

May Ann M. Estavillo 01 Feb 2024
 May Ann M. Estavillo, RCh
 QA/QC Manager, PRC No. 8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
 company seal



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

DOH Accreditation No. 03-010-2325-LW-2 Valid until December 31, 2025
 DENR C.R.No. 074/2023 Valid until June 24, 2026

TEST REPORT

Client: **Manila Water Philippine Ventures (MWPV)** Test Report No.: **TR-24A-044A**
 Address: **3rd Floor, One Joroma Place, Congressional Avenue, Quezon City** Date and Time Received: **02 Jan 2024 @05:00PM**
 Contact Person: **Ms. Florisza I. Faustino** Sampled By: **ECHEM**
 COC Number: **2024-A0006** Report Date: **31 Jan 2024**

Sample ID:	S24-A02-016D			Sampling Date:	02 Jan 2024	
Sample Description:	Deepwell 7			Sampling Time:	11:40 AM	
Sample Matrix:	Drinking Water			Sampling Location:	Anvaya Cove, Morong, Bataan	
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Color, Apparent	<5 @ 7.75	CU	10	Visual Comparison	03 Jan 2024	MCD
Nitrate as NO ₃ -N	<0.05	mg/L	50	Colorimetric, Brucine	03 Jan 2024	CSF
Chlorine, Residual	1.5	—	0.3-1.5	Colorimetric	02 Jan 2024	MGF
Iron	<0.005	mg/L	1.0	Phenanthroline	09 Jan 2024	CSF
pH (on-site)	8.37 @ 26.7°C	—	6.5-8.5	Electrometric	02 Jan 2024	MGF
Taste	No Objectional Taste	—	No Objectional Taste	Flavor Threshold Test	03 Jan 2024	MCD
Total Dissolved Solids (TDS)	277	mg/L	600	Gravimetric, Dried @180°C	03 Jan 2024	MCD
Sulfate	<1.0	mg/L	250	Turbidimetric	03 Jan 2024	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	03 Jan 2024	TGG
Arsenic	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	03 Jan 2024	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF

Sample ID:	S24-A02-023D			Sampling Date:	02 Jan 2024	
Sample Description:	Deepwell 5			Sampling Time:	12:50 PM	
Sample Matrix:	Drinking Water			Sampling Location:	Anvaya Cove, Morong, Bataan	
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Color, Apparent	<5 @ 7.67	CU	10	Visual Comparison	03 Jan 2024	MCD
Nitrate as NO ₃ -N	<0.05	mg/L	50	Colorimetric, Brucine	03 Jan 2024	CSF
Chlorine, Residual	1.5	—	0.3-1.5	Colorimetric	02 Jan 2024	MGF
Iron	<0.005	mg/L	1.0	Phenanthroline	09 Jan 2024	CSF
pH (on-site)	8.31 @ 28.6°C	—	6.5-8.5	Electrometric	02 Jan 2024	MGF
Taste	No Objectional Taste	—	No Objectional Taste	Flavor Threshold Test	03 Jan 2024	MCD
Total Dissolved Solids (TDS)	250	mg/L	600	Gravimetric, Dried @180°C	03 Jan 2024	MCD
Sulfate	<1.0	mg/L	250	Turbidimetric	03 Jan 2024	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	03 Jan 2024	TGG
Arsenic	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	03 Jan 2024	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF



Echem

ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID: **S24-A02-028D**
 Sample Description: **Deepwell 8**
 Sample Matrix: **Drinking Water**

Sampling Date: **02 Jan 2024**
 Sampling Time: **01:28 PM**
 Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Color, Apparent	<5 @7.73	CU	10	Visual Comparison	03 Jan 2024	MCD
Nitrate as NO ₃ N	<0.05	mg/L	50	Colorimetric, Brucine	03 Jan 2024	CSF
Chlorine, Residual	1.0	---	0.3-1.5	Colorimetric	02 Jan 2024	MGF
Iron	<0.005	mg/L	1.0	Phenanthroline	09 Jan 2024	CSF
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	03 Jan 2024	MCD
pH (on-site)	7.71 @28.9°C	---	6.5-8.5	Electrometric	02 Jan 2024	MGF
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	03 Jan 2024	MCD
Total Dissolved Solids (TDS)	271	mg/L	600	Gravimetric, Dried @180°C	03 Jan 2024	MCD
Sulfate	<1.0	mg/L	250	Turbidimetric	03 Jan 2024	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	03 Jan 2024	TGG
Arsenic	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	03 Jan 2024	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF

Sample ID: **S24-A02-029D**
 Sample Description: **Deepwell 9**
 Sample Matrix: **Drinking Water**

Sampling Date: **02 Jan 2024**
 Sampling Time: **01:34 PM**
 Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Color, Apparent	5 @7.77	CU	10	Visual Comparison	03 Jan 2024	MCD
Nitrate as NO ₃ N	<0.05	mg/L	50	Colorimetric, Brucine	03 Jan 2024	CSF
Chlorine, Residual	1.0	---	0.3-1.5	Colorimetric	02 Jan 2024	MGF
Iron	<0.005	mg/L	1.0	Phenanthroline	09 Jan 2024	CSF
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	03 Jan 2024	MCD
pH (on-site)	8.10 @28.7°C	---	6.5-8.5	Electrometric	02 Jan 2024	MGF
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	03 Jan 2024	MCD
Total Dissolved Solids (TDS)	276	mg/L	600	Gravimetric, Dried @180°C	03 Jan 2024	MCD
Sulfate	<1.0	mg/L	250	Turbidimetric	03 Jan 2024	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	03 Jan 2024	TGG
Arsenic	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	03 Jan 2024	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF

Sample ID: **S24-A02-031D**
 Sample Description: **Deepwell 10**
 Sample Matrix: **Drinking Water**

Sampling Date: **02 Jan 2024**
 Sampling Time: **01:47 PM**
 Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Color, Apparent	<5 @7.79	CU	10	Visual Comparison	03 Jan 2024	MCD
Nitrate as NO ₃ N	<0.05	mg/L	50	Colorimetric, Brucine	03 Jan 2024	CSF
Chlorine, Residual	1.0	---	0.3-1.5	Colorimetric	02 Jan 2024	MGF
Iron	<0.005	mg/L	1.0	Phenanthroline	09 Jan 2024	CSF
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	03 Jan 2024	MCD
pH (on-site)	7.86 @28.7°C	---	6.5-8.5	Electrometric	02 Jan 2024	MGF
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	03 Jan 2024	MCD
Total Dissolved Solids (TDS)	291	mg/L	600	Gravimetric, Dried @180°C	03 Jan 2024	MCD
Sulfate	<1.0	mg/L	250	Turbidimetric	03 Jan 2024	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	03 Jan 2024	TGG
Arsenic	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	03 Jan 2024	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID: **S24-A02-032D**
 Sample Description: **Deepwell 11**
 Sample Matrix: **Drinking Water**

Sampling Date: **02 Jan 2024**
 Sampling Time: **01:52 PM**
 Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Color, Apparent	<5 @7.79	CU	10	Visual Comparison	03 Jan 2024	MCD
Nitrate as NO ₃ N	<0.05	mg/L	50	Colorimetric, Brucine	03 Jan 2024	CSF
Chlorine, Residual	1.5	---	0.3-1.5	Colorimetric	02 Jan 2024	MGF
Iron	<0.005	mg/L	1.0	Phenanthroline	09 Jan 2024	CSF
Odor	No Objectional Odor	---	No Objectional Taste	Threshold Odor Test	03 Jan 2024	MCD
pH (on-site)	8.48 @28.6°C	---	6.5-8.5	Electrometric	02 Jan 2024	MGF
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	03 Jan 2024	MCD
Total Dissolved Solids (TDS)	292	mg/L	600	Gravimetric, Dried @180°C	03 Jan 2024	MCD
Sulfate	<1.0	mg/L	250	Turbidimetric	03 Jan 2024	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	03 Jan 2024	TGG
Arsenic	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	03 Jan 2024	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF

Sample ID: **S24-A02-036D**
 Sample Description: **Deepwell 13**
 Sample Matrix: **Drinking Water**

Sampling Date: **02 Jan 2024**
 Sampling Time: **02:30 PM**
 Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Color, Apparent	5 @7.85	CU	10	Visual Comparison	03 Jan 2024	MCD
Nitrate as NO ₃ N	<0.05	mg/L	50	Colorimetric, Brucine	03 Jan 2024	CSF
Chlorine, Residual	1.0	---	0.3-1.5	Colorimetric	02 Jan 2024	MGF
Iron	<0.005	mg/L	1.0	Phenanthroline	09 Jan 2024	CSF
Manganese	0.40	mg/L	0.40	Persulfate	09 Jan 2024	CSF
pH (on-site)	8.17 @27.8°C	---	6.5-8.5	Electrometric	02 Jan 2024	MGF
Taste	No Objectional Odor	---	No Objectional Taste	Flavor Threshold Test	03 Jan 2024	MCD
Total Dissolved Solids (TDS)	304	mg/L	600	Gravimetric, Dried @180°C	03 Jan 2024	MCD
Sulfate	<1.0	mg/L	250	Turbidimetric	03 Jan 2024	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	03 Jan 2024	TGG
Arsenic	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	03 Jan 2024	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF

Notes & References:

Standard Methods for the Examination of Water and Wastewater, 24th Edition.
 DOH Administrative Order No. 2017-0010, PNSDW 2017.
 Test Methods for Evaluating Solid Wastes, Vol 1A, USEPA, Third Edition.
 ICP - OES = Inductively Coupled Plasma - Optical Emission Spectroscopy

Certified by:

Grace D. Montoya
 Lovely Grace D. Montoya, RCh
 Chemist, PRC No. 18651

Approved by:

May Ann M. Estavillo
 May Ann M. Estavillo, RCh
 QA/QC Manager, PRC No. 8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
 company seal



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

DOH Accreditation No. 03-010-2325-LW-2 Valid until December 31, 2025
 DENR C.R.No. 074/2023 Valid until June 24, 2026

TEST REPORT

Client: **Manila Water Philippine Ventures (MWPV)**
 Address: **3rd Floor, One Joroma Place, Congressional Avenue, Quezon City**
 Contact Person: **Ms. Florisza I. Faustino**
 COC Number: **2024-A0006**

Test Report No.: **TR-24A-044A**
 Date and Time Received: **02 Jan 2024 @05:00PM**
 Sampled By: **ECHEM**
 Report Date: **31 Jan 2024**

Sample ID: **S24-A02-012D** Sampling Date: **02 Jan 2024**
 Sample Description: **Reservoir 1** Sampling Time: **10:57 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Color, Apparent	<5 @7.71	CU	10	Visual Comparison	03 Jan 2024	MCD
Nitrate as NO ₃ N	<0.05	mg/L	50	Colorimetric, Brucine	03 Jan 2024	CSF
Chlorine, Residual	1.5	---	0.3-1.5	Colorimetric	02 Jan 2024	MGF
Iron	<0.005	mg/L	1.0	Phenanthroline	09 Jan 2024	CSF
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	03 Jan 2024	MCD
pH (on-site)	7.58 @28.6°C	---	6.5-8.5	Electrometric	02 Jan 2024	MGF
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	03 Jan 2024	MCD
Total Dissolved Solids (TDS)	295	mg/L	600	Gravimetric, Dried @180°C	03 Jan 2024	MCD
Sulfate	<1.0	mg/L	250	Turbidimetric	03 Jan 2024	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	03 Jan 2024	TGG
Arsenic	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	03 Jan 2024	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF

Sample ID: **S24-A02-034D** Sampling Date: **02 Jan 2024**
 Sample Description: **Reservoir 2** Sampling Time: **02:09 PM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Color, Apparent	10 @7.80	CU	10	Visual Comparison	03 Jan 2024	MCD
Nitrate as NO ₃ N	<0.05	mg/L	50	Colorimetric, Brucine	03 Jan 2024	CSF
Chlorine, Residual	1.5	---	0.3-1.5	Colorimetric	02 Jan 2024	MGF
Iron	<0.005	mg/L	1.0	Phenanthroline	09 Jan 2024	CSF
pH (on-site)	8.87 @27.6°C	---	6.5-8.5	Electrometric	02 Jan 2024	MGF
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	03 Jan 2024	MCD
Total Dissolved Solids (TDS)	316	mg/L	600	Gravimetric, Dried @180°C	03 Jan 2024	MCD
Sulfate	<1.0	mg/L	250	Turbidimetric	03 Jan 2024	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	03 Jan 2024	TGG
Arsenic	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	03 Jan 2024	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	17 Jan 2024	CSF



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
Technical: 0917-507-8753 • 0917-164-2944

Notes & References:

Standard Methods for the Examination of Water and Wastewater, 24th Edition.
DOH Administrative Order No. 2017-0010, PNSDW 2017.
Test Methods for Evaluating Solid Wastes, Vol 1A, USEPA, Third Edition.
ICP - OES = Inductively Coupled Plasma - Optical Emission Spectroscopy

Certified by:

Grace D. Montoya 01 Feb 2024
Lovely Grace D. Montoya, RCh
Chemist, PRC No. 3651

Approved by:

May Ann M. Estavillo 01 Feb 2024
May Ann M. Estavillo, RCh
QA/QC Manager, PRC No. 8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
company seal



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

DOH Accreditation No.03-010-2325-LW-2 Valid until December 31, 2025
 DENR C.R.No. 074/2023 Valid until June 24, 2026

TEST REPORT

Client: **Manila Water Philippine Ventures** Test Report No.: **TR-24B-045**
 Address: **3rd Floor, One Jorama Place, Congressional Avenue, Quezon City** Date and Time Received: **23 Jan 2024 @04:10PM**
 Contact Person: **Ms. Florisza I. Faustino** Sampled By: **ECHEM**
 COC Number: **2024-A0337** Report Date: **02 Feb 2024**

Sample ID: **S24-A23-051D** Sampling Date: **23 Jan 2024**
 Sample Description: **N5** Sampling Time: **10:30 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Manganese	<0.10	mg/L	0.40	Persulfate	30 Jan 2024	CSF
Odor	No objectional odor	---	No Objectionable Odor	Threshold Odor Test	24 Jan 2024	MCD

Sample ID: **S24-A23-052D** Sampling Date: **23 Jan 2024**
 Sample Description: **SRCC Boston** Sampling Time: **10:36 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Manganese	<0.10	mg/L	0.40	Persulfate	30 Jan 2024	CSF
Odor	No objectional odor	---	No Objectionable Odor	Threshold Odor Test	24 Jan 2024	MCD

Sample ID: **S24-A23-053D** Sampling Date: **23 Jan 2024**
 Sample Description: **N4** Sampling Time: **10:41 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Manganese	<0.10	mg/L	0.40	Persulfate	30 Jan 2024	CSF

Sample ID: **S24-A23-054D** Sampling Date: **23 Jan 2024**
 Sample Description: **N3** Sampling Time: **10:47 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Manganese	<0.10	mg/L	0.40	Persulfate	30 Jan 2024	CSF
Odor	No objectional odor	---	No Objectionable Odor	Threshold Odor Test	24 Jan 2024	MCD

Sample ID: **S24-A23-055D** Sampling Date: **23 Jan 2024**
 Sample Description: **N7** Sampling Time: **10:50 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Manganese	<0.10	mg/L	0.40	Persulfate	30 Jan 2024	CSF

Sample ID: **S24-A23-056D** Sampling Date: **23 Jan 2024**
 Sample Description: **Tulfo Residence** Sampling Time: **10:55 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Manganese	<0.10	mg/L	0.40	Persulfate	30 Jan 2024	CSF

Sample ID: **S24-A23-058D** Sampling Date: **23 Jan 2024**
 Sample Description: **N1** Sampling Time: **11:10 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Manganese	<0.10	mg/L	0.40	Persulfate	30 Jan 2024	CSF



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID: S24-A23-061D Sample Description: S2A Sample Matrix: Drinking Water				Sampling Date: 23 Jan 2024 Sampling Time: 11:31 AM Sampling Location: Anvaya Cove, Morong, Bataan		
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Manganese	<0.10	mg/L	0.40	Persulfate	30 Jan 2024	CSF
Sample ID: S24-A23-062D Sample Description: BNC Pawikan Sample Matrix: Drinking Water				Sampling Date: 23 Jan 2024 Sampling Time: 11:40 AM Sampling Location: Anvaya Cove, Morong, Bataan		
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Manganese	<0.10	mg/L	0.40	Persulfate	30 Jan 2024	CSF
Sample ID: S24-A23-063D Sample Description: Villas Sample Matrix: Drinking Water				Sampling Date: 23 Jan 2024 Sampling Time: 11:48 AM Sampling Location: Anvaya Cove, Morong, Bataan		
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Manganese	<0.10	mg/L	0.40	Persulfate	30 Jan 2024	CSF
Odor	No objectional odor	---	No Detectable Odor	Threshold Odor Test	24 Jan 2024	MCD
Sample ID: S24-A23-064D Sample Description: BNC Back Door Sample Matrix: Drinking Water				Sampling Date: 23 Jan 2024 Sampling Time: 11:54 AM Sampling Location: Anvaya Cove, Morong, Bataan		
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Manganese	<0.10	mg/L	0.40	Persulfate	30 Jan 2024	CSF
Sample ID: S24-A23-065D Sample Description: Beech Croft Sample Matrix: Drinking Water				Sampling Date: 23 Jan 2024 Sampling Time: 11:59 AM Sampling Location: Anvaya Cove, Morong, Bataan		
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Manganese	<0.10	mg/L	0.40	Persulfate	30 Jan 2024	CSF
Odor	No objectional odor	---	No Detectable Odor	Threshold Odor Test	24 Jan 2024	MCD
Sample ID: S24-A23-066D Sample Description: Sports Center Common Area Sample Matrix: Drinking Water				Sampling Date: 23 Jan 2024 Sampling Time: 12:07 PM Sampling Location: Anvaya Cove, Morong, Bataan		
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Manganese	<0.10	mg/L	0.40	Persulfate	30 Jan 2024	CSF
Odor	No objectional odor	---	No Detectable Odor	Threshold Odor Test	24 Jan 2024	MCD
Sample ID: S24-A23-067D Sample Description: Sports Center Kitchen Sample Matrix: Drinking Water				Sampling Date: 23 Jan 2024 Sampling Time: 12:10 PM Sampling Location: Quezon City		
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Manganese	<0.10	mg/L	0.40	Persulfate	30 Jan 2024	CSF
Sample ID: S24-A23-068D Sample Description: Golf Kitchen Sample Matrix: Drinking Water				Sampling Date: 23 Jan 2024 Sampling Time: 12:17 PM Sampling Location: Anvaya Cove, Morong, Bataan		
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Manganese	<0.10	mg/L	0.40	Persulfate	30 Jan 2024	CSF
Odor	No objectional odor	---	No Detectable Odor	Threshold Odor Test	24 Jan 2024	MCD



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID: **S24-A23-069D**
 Sample Description: **Caddie**
 Sample Matrix: **Drinking Water**

Sampling Date: **23 Jan 2024**
 Sampling Time: **12:24 PM**
 Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Manganese	<0.10	mg/L	0.40	Persulfate	30 Jan 2024	CSF

Sample ID: **S24-A23-072D**
 Sample Description: **N9**
 Sample Matrix: **Drinking Water**

Sampling Date: **23 Jan 2024**
 Sampling Time: **12:45 PM**
 Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Manganese	<0.10	mg/L	0.40	Persulfate	30 Jan 2024	CSF

Sample ID: **S24-A23-075D**
 Sample Description: **NGB**
 Sample Matrix: **Drinking Water**

Sampling Date: **23 Jan 2024**
 Sampling Time: **12:58 PM**
 Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Manganese	<0.10	mg/L	0.40	Persulfate	30 Jan 2024	CSF

Sample ID: **S24-A23-077D**
 Sample Description: **SBV Condo**
 Sample Matrix: **Drinking Water**

Sampling Date: **23 Jan 2024**
 Sampling Time: **01:16 PM**
 Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Manganese	<0.10	mg/L	0.40	Persulfate	30 Jan 2024	CSF

Notes & References:

Standard Methods for the Examination of Water and Wastewater, 24th Edition.
 DOH Administrative Order No. 2017-0010, PNSDW 2017.

Certified by:

Yvonne D. Montoya
 Lovely Grace D. Montoya, RCh
 Chemist, PRC No. 13651

Approved by:

May Ann M. Estavillo
 May Ann M. Estavillo, RCh
 QA/QC Manager, PRC No. 8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
 company seal



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

DOH Accreditation No.03-010-2325-LW-2 Valid until December 31, 2025
 DENR C.R.No. 074/2023 Valid until June 24, 2026

TEST REPORT

Client: **Manila Water Philippine Ventures** Test Report No.: **TR-24B-045**
 Address: **3rd Floor, One Joroma Place, Congressional Avenue, Quezon City** Date and Time Received: **23 Jan 2024 @04:10PM**
 Contact Person: **Ms. Florisza I. Faustino** Sampled By: **ECHEM**
 COC Number: **2024-A0337** Report Date: **02 Feb 2024**

Sample ID: S24-A23-059D		Sampling Date: 23 Jan 2024				
Sample Description: Deepwell 5		Sampling Time: 11:20 AM				
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan				
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Manganese	<0.10	mg/L	0.40	Persulfate	30 Jan 2024	CSF
Odor	No objectional odor	---	No Objectionable Odor	Threshold Odor Test	24 Jan 2024	MCD
Sample ID: S24-A23-060D		Sampling Date: 23 Jan 2024				
Sample Description: Deepwell 7		Sampling Time: 11:26 AM				
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan				
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Manganese	<0.10	mg/L	0.40	Persulfate	30 Jan 2024	CSF
Odor	No objectional odor	---	No Objectionable Odor	Threshold Odor Test	24 Jan 2024	MCD
Sample ID: S24-A23-070D		Sampling Date: 23 Jan 2024				
Sample Description: Deepwell 8		Sampling Time: 12:30 PM				
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan				
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Manganese	<0.10	mg/L	0.40	Persulfate	30 Jan 2024	CSF
Sample ID: S24-A23-071D		Sampling Date: 23 Jan 2024				
Sample Description: Deepwell 9		Sampling Time: 12:39 PM				
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan				
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Manganese	<0.10	mg/L	0.40	Persulfate	30 Jan 2024	CSF
Sample ID: S24-A23-073D		Sampling Date: 23 Jan 2024				
Sample Description: Deepwell 10		Sampling Time: 12:49 PM				
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan				
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Manganese	<0.10	mg/L	0.40	Persulfate	30 Jan 2024	CSF
Sample ID: S24-A23-074D		Sampling Date: 23 Jan 2024				
Sample Description: Deepwell 11		Sampling Time: 12:53 PM				
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan				
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Manganese	<0.10	mg/L	0.40	Persulfate	30 Jan 2024	CSF

Notes & References:

Standard Methods for the Examination of Water and Wastewater, 24th Edition.
 DOH Administrative Order No. 2017-0010, PNSDW 2017.



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
Technical: 0917-507-8753 • 0917-164-2944

Certified by:

Grace D. Montoya 05 Feb 2024
Lovely Grace D. Montoya, RCh
Chemist, PRC No. 13651

Approved by:

May Ann M. Estavillo 05 Feb 2024
May Ann M. Estavillo, RCh
QA/QC Manager, PRC No. 8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
company seal



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

DOH Accreditation No.03-010-2325-LW-2 Valid until December 31, 2025
 DENR C.R.No. 074/2023 Valid until June 24, 2026

TEST REPORT

Client: **Manila Water Philippine Ventures (MWPV)**
 Address: **3rd Floor, One Joroma Place, Congressional Avenue, Quezon City**
 Contact Person: **Ms. Florisza I. Faustino**
 COC Number: **2024-A0006**

Test Report No.: **TR-24A-044B**
 Date and Time Received: **02 Jan 2024 @05:00PM**
 Sampled By: **ECHEM**
 Report Date: **11 Jan 2024**

Sample ID: **S24-A02-007D**
 Sample Description: **N5**
 Sample Matrix: **Drinking Water**

Sampling Date: **02 Jan 2024**
 Sampling Time: **10:20 AM**
 Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jan 2024 @06:23PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @06:23PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Jan 2024 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @06:23PM	AHP

Sample ID: **S24-A02-008D**
 Sample Description: **SRCC Boston**
 Sample Matrix: **Drinking Water**

Sampling Date: **02 Jan 2024**
 Sampling Time: **10:27 AM**
 Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jan 2024 @06:26PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @06:26PM	AHP
Heterotrophic Plate Count (HPC)	3	CFU/mL	< 500	PASSED	Pour Plate	02 Jan 2024 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @06:26PM	AHP

Sample ID: **S24-A02-009D**
 Sample Description: **N4**
 Sample Matrix: **Drinking Water**

Sampling Date: **02 Jan 2024**
 Sampling Time: **10:32 AM**
 Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jan 2024 @06:29PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @06:29PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Jan 2024 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @06:29PM	AHP

Sample ID: **S24-A02-010D**
 Sample Description: **N7**
 Sample Matrix: **Drinking Water**

Sampling Date: **02 Jan 2024**
 Sampling Time: **10:40 AM**
 Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jan 2024 @06:32PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @06:32PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Jan 2024 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @06:32PM	AHP

Sample ID: **S24-A02-011D**
 Sample Description: **Tulfo Residence**
 Sample Matrix: **Drinking Water**

Sampling Date: **02 Jan 2024**
 Sampling Time: **10:48 AM**
 Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jan 2024 @06:35PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @06:35PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Jan 2024 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @06:35PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID: S24-A02-012D		Sampling Date: 02 Jan 2024					
Sample Description: Reservoir 1		Sampling Time: 10:57 AM					
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jan 2024 @06:38PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @06:38PM	AHP
Heterotrophic Plate Count (HPC)	1	CFU/mL	< 500	PASSED	Pour Plate	02 Jan 2024 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @06:38PM	AHP
Sample ID: S24-A02-013D		Sampling Date: 02 Jan 2024					
Sample Description: N2		Sampling Time: 11:10 AM					
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jan 2024 @06:41PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @06:41PM	AHP
Heterotrophic Plate Count (HPC)	1	CFU/mL	< 500	PASSED	Pour Plate	02 Jan 2024 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @06:41PM	AHP
Sample ID: S24-A02-014D		Sampling Date: 02 Jan 2024					
Sample Description: N1		Sampling Time: 11:18 AM					
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jan 2024 @06:44PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @06:44PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Jan 2024 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @06:44PM	AHP
Sample ID: S24-A02-015D		Sampling Date: 02 Jan 2024					
Sample Description: N3		Sampling Time: 11:30 AM					
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jan 2024 @06:47PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @06:47PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Jan 2024 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @06:47PM	AHP
Sample ID: S24-A02-016D		Sampling Date: 02 Jan 2024					
Sample Description: Deppwell 7		Sampling Time: 11:40 AM					
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jan 2024 @06:50PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @06:50PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Jan 2024 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @06:50PM	AHP
Sample ID: S24-A02-017D		Sampling Date: 02 Jan 2024					
Sample Description: S1		Sampling Time: 11:48 AM					
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jan 2024 @06:53PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @06:53PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Jan 2024 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @06:53PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID: **S24-A02-018D**
 Sample Description: **S2A**
 Sample Matrix: **Drinking Water**

Sampling Date: **02 Jan 2024**
 Sampling Time: **11:52 AM**
 Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jan 2024 @06:56PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @06:56PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Jan 2024 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @06:56PM	AHP

Sample ID: **S24-A02-019D**
 Sample Description: **BNC Pawikan**
 Sample Matrix: **Drinking Water**

Sampling Date: **02 Jan 2024**
 Sampling Time: **12:20 PM**
 Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jan 2024 @06:59PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @06:59PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Jan 2024 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @06:59PM	AHP

Sample ID: **S24-A02-020D**
 Sample Description: **Villas**
 Sample Matrix: **Drinking Water**

Sampling Date: **02 Jan 2024**
 Sampling Time: **12:30 PM**
 Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jan 2024 @07:02PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @07:02PM	AHP
Heterotrophic Plate Count (HPC)	1	CFU/mL	< 500	PASSED	Pour Plate	02 Jan 2024 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @07:02PM	AHP

Sample ID: **S24-A02-021D**
 Sample Description: **BNC Back Door**
 Sample Matrix: **Drinking Water**

Sampling Date: **02 Jan 2024**
 Sampling Time: **12:36 PM**
 Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jan 2024 @07:05PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @07:05PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Jan 2024 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @07:05PM	AHP

Sample ID: **S24-A02-022D**
 Sample Description: **Beech Craft**
 Sample Matrix: **Drinking Water**

Sampling Date: **02 Jan 2024**
 Sampling Time: **12:41 PM**
 Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jan 2024 @07:08PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @07:08PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Jan 2024 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @07:08PM	AHP

Sample ID: **S24-A02-023D**
 Sample Description: **Deepwell 5**
 Sample Matrix: **Drinking Water**

Sampling Date: **02 Jan 2024**
 Sampling Time: **12:50 PM**
 Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jan 2024 @07:11PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @07:11PM	AHP
Heterotrophic Plate Count (HPC)	1	CFU/mL	< 500	PASSED	Pour Plate	02 Jan 2024 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @07:11PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID: **S24-A02-024D**

Sample Description: **Sports Center Common Area**

Sample Matrix: **Drinking Water**

Sampling Date: **02 Jan 2024**

Sampling Time: **12:59 PM**

Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jan 2024 @07:14PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @07:14PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Jan 2024 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @07:14PM	AHP

Sample ID: **S24-A02-025D**

Sample Description: **Sports Center Kitchen**

Sample Matrix: **Drinking Water**

Sampling Date: **02 Jan 2024**

Sampling Time: **01:04 PM**

Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jan 2024 @07:15PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @07:15PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Jan 2024 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @07:15PM	AHP

Sample ID: **S24-A02-026D**

Sample Description: **Golf Kitchen**

Sample Matrix: **Drinking Water**

Sampling Date: **02 Jan 2024**

Sampling Time: **01:15 PM**

Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jan 2024 @07:20PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @07:20PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Jan 2024 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @07:20PM	AHP

Sample ID: **S24-A02-027D**

Sample Description: **Caddie**

Sample Matrix: **Drinking Water**

Sampling Date: **02 Jan 2024**

Sampling Time: **01:20 PM**

Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jan 2024 @07:23PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @07:23PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Jan 2024 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @07:23PM	AHP

Sample ID: **S24-A02-028D**

Sample Description: **Deepwell 8**

Sample Matrix: **Drinking Water**

Sampling Date: **02 Jan 2024**

Sampling Time: **01:28 PM**

Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jan 2024 @07:26PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @07:26PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Jan 2024 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @07:26PM	AHP

Sample ID: **S24-A02-029D**

Sample Description: **Deepwell 9**

Sample Matrix: **Drinking Water**

Sampling Date: **02 Jan 2024**

Sampling Time: **01:34 PM**

Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jan 2024 @07:29PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @07:29PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Jan 2024 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @07:29PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID: S24-A02-030D		Sampling Date: 02 Jan 2024					
Sample Description: N9		Sampling Time: 01:40 PM					
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jan 2024 @07:32PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @07:32PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Jan 2024 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @07:32PM	AHP
Sample ID: S24-A02-031D		Sampling Date: 02 Jan 2024					
Sample Description: Deepwell 10		Sampling Time: 01:47 PM					
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jan 2024 @07:35PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @07:35PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Jan 2024 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @07:35PM	AHP
Sample ID: S24-A02-032D		Sampling Date: 02 Jan 2024					
Sample Description: Deepwell 11		Sampling Time: 01:52 PM					
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jan 2024 @07:38PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @07:38PM	AHP
Heterotrophic Plate Count (HPC)	1	CFU/mL	< 500	PASSED	Pour Plate	02 Jan 2024 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @07:38PM	AHP
Sample ID: S24-A02-033D		Sampling Date: 02 Jan 2024					
Sample Description: N6B		Sampling Time: 02:01 PM					
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jan 2024 @07:41PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @07:41PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Jan 2024 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @07:41PM	AHP
Sample ID: S24-A02-034D		Sampling Date: 02 Jan 2024					
Sample Description: Reservoir 2		Sampling Time: 02:09 PM					
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jan 2024 @07:44PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @07:44PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Jan 2024 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @07:44PM	AHP
Sample ID: S24-A02-035D		Sampling Date: 02 Jan 2024					
Sample Description: SBV Condo		Sampling Time: 02:14 PM					
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jan 2024 @07:47PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @07:47PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Jan 2024 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @07:47PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
Technical: 0917-507-8753 • 0917-164-2944

Sample ID: **S24-A02-036D**
Sample Description: **Deepwell 13**
Sample Matrix: **Drinking Water**


Sampling Date: **02 Jan 2024**
Sampling Time: **02:30 PM**
Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jan 2024 @07:50PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @07:50PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Jan 2024 @08:00PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jan 2024 @07:50PM	AHP

Notes & References:

Standard Methods for the Examination of Water and Wastewater, 24th Edition.
DOH Administrative Order No. 2017-0010, PNSDW 2017.

Certified by:


Anita H. Pineda, RMT
Medical Technologist, PRC No. 52546

Approved by:


May Ann M. Estavillo, RCh
QA/QC Manager, PRC No. 8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
company seal