



TEST REPORT

Client: **Manila Water Philippine Ventures (MWPV)**
 Address: **3rd Floor, One Joroma Place, Congressional Avenue, Quezon City**
 Contact Person: **Ms. Florisza I. Faustino**
 COC Number: **2024-D0066**

Test Report No.: **TR-24D-225**
 Date and Time Received: **03 Apr 2024 @04:05PM**
 Sampled By: **ECHEM**
 Report Date: **12 Apr 2024**

Sample ID: **S24-D03-025D** Sampling Date: **03 Apr 2024**
 Sample Description: **Deepwell 13** Sampling Time: **09:45 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Apr 2024 @05:53PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @05:53PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Apr 2024 @07:58PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @05:53PM	AHP

Sample ID: **S24-D03-038D** Sampling Date: **03 Apr 2024**
 Sample Description: **Deepwell 5** Sampling Time: **10:52 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Apr 2024 @06:32PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:32PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Apr 2024 @07:58PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:32PM	AHP

Sample ID: **S24-D03-043D** Sampling Date: **03 Apr 2024**
 Sample Description: **Deepwell 8** Sampling Time: **11:30 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Apr 2024 @06:47PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:47PM	AHP
Heterotrophic Plate Count (HPC)	1	CFU/mL	< 500	PASSED	Pour Plate	03 Apr 2024 @07:58PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:47PM	AHP

Sample ID: **S24-D03-044D** Sampling Date: **03 Apr 2024**
 Sample Description: **Deepwell 9** Sampling Time: **11:38 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Apr 2024 @06:50PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:50PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Apr 2024 @07:58PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:50PM	AHP

Sample ID: **S24-D03-046D** Sampling Date: **03 Apr 2024**
 Sample Description: **Deepwell 10** Sampling Time: **11:49 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Apr 2024 @06:56PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:56PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Apr 2024 @07:58PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:56PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID: **S24-D03-047D** Sampling Date: **03 Apr 2024**
 Sample Description: **Deepwell 11** Sampling Time: **11:54 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Apr 2024 @06:59PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:59PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Apr 2024 @07:58PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:59PM	AHP


Sample ID: **S24-D03-051D** Sampling Date: **03 Apr 2024**
 Sample Description: **Deepwell 7** Sampling Time: **12:20 PM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Apr 2024 @07:11PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @07:11PM	AHP
Heterotrophic Plate Count (HPC)	1	CFU/mL	< 500	PASSED	Pour Plate	03 Apr 2024 @07:58PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @07:11PM	AHP

Notes & References:

Standard Methods for the Examination of Water and Wastewater, 24th Edition.
 DOH Administrative Order No. 2017-0010, PNSDW 2017.

Certified by:


Anita H. Pineda, RMT
 Medical Technologist, PRC No. 52546

Approved by:


May Ann M. Estavillo, RCh
 QA/QC Manager, PRC No. 8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
company seal



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
Technical: 0917-507-8753 • 0917-164-2944

DOH Accreditation No.03-010-2325-LW-2 Valid until December 31, 2025
DENR C.R.No. 074/2023 Valid until June 24, 2026

TEST REPORT

Client: **Manila Water Philippine Ventures (MWPV)**
Address: **3rd Floor, One Joroma Place, Congressional Avenue, Quezon City**
Contact Person: **Ms. Florisza I. Faustino**
COC Number: **2024-D0066**

Test Report No.: **TR-24D-225**
Date and Time Received: **03 Apr 2024 @04:05PM**
Sampled By: **ECHEM**
Report Date: **12 Apr 2024**

Sample ID:	S24-D03-030D	Sampling Date:	03 Apr 2024
Sample Description:	Reservoir 1	Sampling Time:	10:13 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MFTT Thermotolerant Coliform Test (EC Medium)	03 Apr 2024 @06:08PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:08PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Apr 2024 @07:58PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:08PM	AHP


Sample ID:	S24-D03-050D	Sampling Date:	03 Apr 2024
Sample Description:	Reservoir 2	Sampling Time:	12:12 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MFTT Thermotolerant Coliform Test (EC Medium)	03 Apr 2024 @07:08PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @07:08PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Apr 2024 @07:58PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @07:08PM	AHP

Notes & References:

Standard Methods for the Examination of Water and Wastewater, 24th Edition.
DOH Administrative Order No. 2017-0010, PNSDW 2017.

Certified by:


Anita H. Pineda, RMT
Medical Technologist, PRC No. 52546

Approved by:


May Ann M. Estavillo, RCh
QA/QC Manager, PRC No. 8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
company seal



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

DOH Accreditation No.03-010-2325-LW-2 Valid until December 31, 2025
 DENR C.R.No. 074/2023 Valid until June 24, 2026

TEST REPORT

Client: **Manila Water Philippine Ventures (MWPV)**
 Address: **3rd Floor, One Joroma Place, Congressional Avenue, Quezon City**
 Contact Person: **Ms. Florisza I. Faustino**
 COC Number: **2024-D0066**

Test Report No.: **TR-24D-225**
 Date and Time Received: **03 Apr 2024 @04:05PM**
 Sampled By: **ECHEM**
 Report Date: **12 Apr 2024**

Sample ID: **S24-D03-024D** Sampling Date: **03 Apr 2024**
 Sample Description: **N5** Sampling Time: **09:40 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Apr 2024 @05:50PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @05:50PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Apr 2024 @07:58PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @05:50PM	AHP

Sample ID: **S24-D03-026D** Sampling Date: **03 Apr 2024**
 Sample Description: **SRCC Boston** Sampling Time: **09:50 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Apr 2024 @05:56PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @05:56PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Apr 2024 @07:58PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @05:56PM	AHP

Sample ID: **S24-D03-027D** Sampling Date: **03 Apr 2024**
 Sample Description: **N4** Sampling Time: **09:57 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Apr 2024 @05:59PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @05:59PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Apr 2024 @07:58PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @05:59PM	AHP

Sample ID: **S24-D03-028D** Sampling Date: **03 Apr 2024**
 Sample Description: **N7** Sampling Time: **10:03 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Apr 2024 @06:02PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:02PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Apr 2024 @07:58PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:02PM	AHP

Sample ID: **S24-D03-029D** Sampling Date: **03 Apr 2024**
 Sample Description: **Tulfo Residence** Sampling Time: **10:09 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Apr 2024 @06:05PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:05PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Apr 2024 @07:58PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:05PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: ecchemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID: S24-D03-031D	Sampling Date: 03 Apr 2024
Sample Description: N2	Sampling Time: 10:18 AM
Sample Matrix: Drinking Water	Sampling Location: Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Apr 2024 @06:11PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:11PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Apr 2024 @07:58PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:11PM	AHP

Sample ID: S24-D03-032D	Sampling Date: 03 Apr 2024
Sample Description: N1	Sampling Time: 10:22 AM
Sample Matrix: Drinking Water	Sampling Location: Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Apr 2024 @06:14PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:14PM	AHP
Heterotrophic Plate Count (HPC)	3	CFU/mL	< 500	PASSED	Pour Plate	03 Apr 2024 @07:58PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:14PM	AHP

Sample ID: S24-D03-033D	Sampling Date: 03 Apr 2024
Sample Description: N3	Sampling Time: 10:28 AM
Sample Matrix: Drinking Water	Sampling Location: Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Apr 2024 @06:17PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:17PM	AHP
Heterotrophic Plate Count (HPC)	1	CFU/mL	< 500	PASSED	Pour Plate	03 Apr 2024 @07:58PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:17PM	AHP

Sample ID: S24-D03-034D	Sampling Date: 03 Apr 2024
Sample Description: BNC Pawikan	Sampling Time: 10:33 AM
Sample Matrix: Drinking Water	Sampling Location: Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Apr 2024 @06:20PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:20PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Apr 2024 @07:58PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:20PM	AHP

Sample ID: S24-D03-035D	Sampling Date: 03 Apr 2024
Sample Description: Villas	Sampling Time: 10:39 AM
Sample Matrix: Drinking Water	Sampling Location: Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Apr 2024 @06:23PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:23PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Apr 2024 @07:58PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:23PM	AHP

Sample ID: S24-D03-036D	Sampling Date: 03 Apr 2024
Sample Description: BNC Back Door	Sampling Time: 10:42 AM
Sample Matrix: Drinking Water	Sampling Location: Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Apr 2024 @06:26PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:26PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Apr 2024 @07:58PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:26PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID: S24-D03-037D		Sampling Date: 03 Apr 2024	
Sample Description: Beech Croft		Sampling Time: 10:47 AM	
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan	

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Apr 2024 @06:29PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:29PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Apr 2024 @07:58PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:29PM	AHP

Sample ID: S24-D03-039D		Sampling Date: 03 Apr 2024	
Sample Description: Sports Center Common Area		Sampling Time: 11:09 AM	
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan	

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Apr 2024 @06:35PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:35PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Apr 2024 @07:58PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:35PM	AHP

Sample ID: S24-D03-040D		Sampling Date: 03 Apr 2024	
Sample Description: Sports Center Kitchen		Sampling Time: 11:11 AM	
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan	

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Apr 2024 @06:38PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:38PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Apr 2024 @07:58PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:38PM	AHP

Sample ID: S24-D03-041D		Sampling Date: 03 Apr 2024	
Sample Description: Golf Kitchen		Sampling Time: 11:17 AM	
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan	

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Apr 2024 @06:41PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:41PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Apr 2024 @07:58PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:41PM	AHP

Sample ID: S24-D03-042D		Sampling Date: 03 Apr 2024	
Sample Description: Caddie		Sampling Time: 11:23 AM	
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan	

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Apr 2024 @06:44PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:44PM	AHP
Heterotrophic Plate Count (HPC)	2	CFU/mL	< 500	PASSED	Pour Plate	03 Apr 2024 @07:58PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:44PM	AHP

Sample ID: S24-D03-045D		Sampling Date: 03 Apr 2024	
Sample Description: N9		Sampling Time: 11:42 AM	
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan	

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Apr 2024 @06:53PM	AHP
Fecal Coliform (DW)	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:53PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Apr 2024 @07:58PM	AHP
Total Coliform (DW)	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @06:53PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID: **S24-D03-048D** Sampling Date: **03 Apr 2024**
 Sample Description: **SBV Condo** Sampling Time: **12:01 PM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Apr 2024 @07:02PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @07:02PM	AHP
Heterotrophic Plate Count (HPC)	1	CFU/mL	< 500	PASSED	Pour Plate	03 Apr 2024 @07:58PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @07:02PM	AHP

Sample ID: **S24-D03-049D** Sampling Date: **03 Apr 2024**
 Sample Description: **N6B** Sampling Time: **12:07 PM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Apr 2024 @07:05PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @07:05PM	AHP
Heterotrophic Plate Count (HPC)	8	CFU/mL	< 500	PASSED	Pour Plate	03 Apr 2024 @07:58PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @07:05PM	AHP

Sample ID: **S24-D03-052D** Sampling Date: **03 Apr 2024**
 Sample Description: **S1** Sampling Time: **12:30 PM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Apr 2024 @07:14PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @07:14PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Apr 2024 @07:58PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @07:14PM	AHP

Sample ID: **S24-D03-053D** Sampling Date: **03 Apr 2024**
 Sample Description: **S2A** Sampling Time: **12:38 PM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Apr 2024 @07:17PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @07:17PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Apr 2024 @07:58PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Apr 2024 @07:17PM	AHP

Notes & References:

Standard Methods for the Examination of Water and Wastewater, 24th Edition.
 DOH Administrative Order No. 2017-0010, PNSDW 2017.

Certified by:

Anita H. Pineda
 Anita H. Pineda, RMT
 Medical Technologist, PRC No. 52546

Approved by:

May Ann M. Estavillo
 May Ann M. Estavillo, RCh
 QA/QC Manager, PRC No.8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
 company seal