



# Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga  
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga  
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com  
 Technical: 0917-507-8753 • 0917-164-2944

DOH Accreditation No.03-010-2325-LW-2 Valid until December 31, 2025  
 DENR C.R.No. 074/2023 Valid until June 24, 2026

## TEST REPORT

Client: **Manila Water Philippine Ventures (MWPV)**  
 Address: **3rd Floor, One Joroma Place, Congressional Avenue, Quezon City**  
 Contact Person: **Mr. John Michael M. De Guzman**  
 COC Number: **2024-H0084**

Test Report No.: **TR-24H-139**  
 Date and Time Received: **06 Aug 2024 @06:40PM**  
 Sampled By: **ECHEM**  
 Report Date: **12 Aug 2024**

Sample ID: **S24-H06-048D** Sampling Date: **06 Aug 2024**  
 Sample Description: **N5** Sampling Time: **09:50 AM**  
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Aug 2024 @07:15PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @07:15PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>&lt;1</b>	CFU/mL	< 500	PASSED	Pour Plate	06 Aug 2024 @08:55PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @07:15PM	AHP

Sample ID: **S24-H06-049D** Sampling Date: **06 Aug 2024**  
 Sample Description: **Deepwell 13** Sampling Time: **09:55 AM**  
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Aug 2024 @07:18PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @07:18PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>&lt;1</b>	CFU/mL	< 500	PASSED	Pour Plate	06 Aug 2024 @08:55PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @07:18PM	AHP

Sample ID: **S24-H06-050D** Sampling Date: **06 Aug 2024**  
 Sample Description: **SRCC Boston** Sampling Time: **10:00 AM**  
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Aug 2024 @07:21PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @07:21PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>2</b>	CFU/mL	< 500	PASSED	Pour Plate	06 Aug 2024 @08:55PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @07:21PM	AHP

Sample ID: **S24-H06-051D** Sampling Date: **06 Aug 2024**  
 Sample Description: **N4** Sampling Time: **10:06 AM**  
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Aug 2024 @07:24PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @07:24PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>1</b>	CFU/mL	< 500	PASSED	Pour Plate	06 Aug 2024 @08:55PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @07:24PM	AHP

Sample ID: **S24-H06-052D** Sampling Date: **06 Aug 2024**  
 Sample Description: **N7** Sampling Time: **10:10 AM**  
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Aug 2024 @07:27PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @07:27PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>&lt;1</b>	CFU/mL	< 500	PASSED	Pour Plate	06 Aug 2024 @08:55PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @07:27PM	AHP



# Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga  
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga  
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com  
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID: <b>S24-H06-053D</b>		Sampling Date: <b>06 Aug 2024</b>					
Sample Description: <b>Tulfo Residence</b>		Sampling Time: <b>10:16 AM</b>					
Sample Matrix: <b>Drinking Water</b>		Sampling Location: <b>Anvaya Cove, Morong, Bataan</b>					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Aug 2024 @07:30PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @07:30PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>5</b>	CFU/mL	< 500	PASSED	Pour Plate	06 Aug 2024 @08:55PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @07:30PM	AHP
Sample ID: <b>S24-H06-054D</b>		Sampling Date: <b>06 Aug 2024</b>					
Sample Description: <b>Reservoir 1</b>		Sampling Time: <b>10:21 AM</b>					
Sample Matrix: <b>Drinking Water</b>		Sampling Location: <b>Anvaya Cove, Morong, Bataan</b>					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Aug 2024 @07:33PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @07:33PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>&lt;1</b>	CFU/mL	< 500	PASSED	Pour Plate	06 Aug 2024 @08:55PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @07:33PM	AHP
Sample ID: <b>S24-H06-055D</b>		Sampling Date: <b>06 Aug 2024</b>					
Sample Description: <b>N2</b>		Sampling Time: <b>10:25 AM</b>					
Sample Matrix: <b>Drinking Water</b>		Sampling Location: <b>Anvaya Cove, Morong, Bataan</b>					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Aug 2024 @07:36PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @07:36PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>&lt;1</b>	CFU/mL	< 500	PASSED	Pour Plate	06 Aug 2024 @08:55PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @07:36PM	AHP
Sample ID: <b>S24-H06-056D</b>		Sampling Date: <b>06 Aug 2024</b>					
Sample Description: <b>N1</b>		Sampling Time: <b>10:30 AM</b>					
Sample Matrix: <b>Drinking Water</b>		Sampling Location: <b>Anvaya Cove, Morong, Bataan</b>					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Aug 2024 @07:39PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @07:39PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>&lt;1</b>	CFU/mL	< 500	PASSED	Pour Plate	06 Aug 2024 @08:55PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @07:39PM	AHP
Sample ID: <b>S24-H06-057D</b>		Sampling Date: <b>06 Aug 2024</b>					
Sample Description: <b>N3</b>		Sampling Time: <b>10:34 AM</b>					
Sample Matrix: <b>Drinking Water</b>		Sampling Location: <b>Anvaya Cove, Morong, Bataan</b>					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Aug 2024 @07:42PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @07:42PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>8</b>	CFU/mL	< 500	PASSED	Pour Plate	06 Aug 2024 @08:55PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @07:42PM	AHP
Sample ID: <b>S24-H06-058D</b>		Sampling Date: <b>06 Aug 2024</b>					
Sample Description: <b>Deepwell 7</b>		Sampling Time: <b>10:38 AM</b>					
Sample Matrix: <b>Drinking Water</b>		Sampling Location: <b>Anvaya Cove, Morong, Bataan</b>					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Aug 2024 @07:45PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @07:45PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>&lt;1</b>	CFU/mL	< 500	PASSED	Pour Plate	06 Aug 2024 @08:55PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @07:45PM	AHP



# Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga  
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga  
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com  
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID:	<b>S24-H06-059D</b>	Sampling Date:	<b>06 Aug 2024</b>
Sample Description:	<b>S2A</b>	Sampling Time:	<b>10:42 AM</b>
Sample Matrix:	<b>Drinking Water</b>	Sampling Location:	<b>Anvaya Cove, Morong, Bataan</b>

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Aug 2024 @07:48PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @07:48PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>&lt;1</b>	CFU/mL	< 500	PASSED	Pour Plate	06 Aug 2024 @08:55PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @07:48PM	AHP

Sample ID:	<b>S24-H06-060D</b>	Sampling Date:	<b>06 Aug 2024</b>
Sample Description:	<b>S1</b>	Sampling Time:	<b>10:46 AM</b>
Sample Matrix:	<b>Drinking Water</b>	Sampling Location:	<b>Anvaya Cove, Morong, Bataan</b>

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Aug 2024 @07:51PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @07:51PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>&lt;1</b>	CFU/mL	< 500	PASSED	Pour Plate	06 Aug 2024 @08:55PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @07:51PM	AHP

Sample ID:	<b>S24-H06-061D</b>	Sampling Date:	<b>06 Aug 2024</b>
Sample Description:	<b>BNC Pawikan</b>	Sampling Time:	<b>10:50 AM</b>
Sample Matrix:	<b>Drinking Water</b>	Sampling Location:	<b>Anvaya Cove, Morong, Bataan</b>

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Aug 2024 @07:54PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @07:54PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>3</b>	CFU/mL	< 500	PASSED	Pour Plate	06 Aug 2024 @08:55PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @07:54PM	AHP

Sample ID:	<b>S24-H06-062D</b>	Sampling Date:	<b>06 Aug 2024</b>
Sample Description:	<b>Villas</b>	Sampling Time:	<b>10:54 AM</b>
Sample Matrix:	<b>Drinking Water</b>	Sampling Location:	<b>Anvaya Cove, Morong, Bataan</b>

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Aug 2024 @07:57PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @07:57PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>&lt;1</b>	CFU/mL	< 500	PASSED	Pour Plate	06 Aug 2024 @08:55PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @07:57PM	AHP

Sample ID:	<b>S24-H06-063D</b>	Sampling Date:	<b>06 Aug 2024</b>
Sample Description:	<b>BNC Backdoor</b>	Sampling Time:	<b>10:58 AM</b>
Sample Matrix:	<b>Drinking Water</b>	Sampling Location:	<b>Anvaya Cove, Morong, Bataan</b>

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Aug 2024 @08:00PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @08:00PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>1</b>	CFU/mL	< 500	PASSED	Pour Plate	06 Aug 2024 @08:55PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @08:00PM	AHP

Sample ID:	<b>S24-H06-064D</b>	Sampling Date:	<b>06 Aug 2024</b>
Sample Description:	<b>Beech Craft</b>	Sampling Time:	<b>11:05 AM</b>
Sample Matrix:	<b>Drinking Water</b>	Sampling Location:	<b>Anvaya Cove, Morong, Bataan</b>

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Aug 2024 @08:03PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @08:03PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>12</b>	CFU/mL	< 500	PASSED	Pour Plate	06 Aug 2024 @08:55PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @08:03PM	AHP



# Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga  
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga  
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com  
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID: <b>S24-H06-065D</b>		Sampling Date: <b>06 Aug 2024</b>	
Sample Description: <b>Deepwell 5</b>		Sampling Time: <b>11:09 AM</b>	
Sample Matrix: <b>Drinking Water</b>		Sampling Location: <b>Anvaya Cove, Morong, Bataan</b>	

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Aug 2024 @08:06PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @08:06PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>&lt;1</b>	CFU/mL	< 500	PASSED	Pour Plate	06 Aug 2024 @08:55PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @08:06PM	AHP

Sample ID: <b>S24-H06-066D</b>		Sampling Date: <b>06 Aug 2024</b>	
Sample Description: <b>SC Common Area</b>		Sampling Time: <b>11:14 AM</b>	
Sample Matrix: <b>Drinking Water</b>		Sampling Location: <b>Anvaya Cove, Morong, Bataan</b>	

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Aug 2024 @08:09PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @08:09PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>16</b>	CFU/mL	< 500	PASSED	Pour Plate	06 Aug 2024 @08:55PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @08:09PM	AHP

Sample ID: <b>S24-H06-067D</b>		Sampling Date: <b>06 Aug 2024</b>	
Sample Description: <b>SC Kitchen</b>		Sampling Time: <b>11:19 AM</b>	
Sample Matrix: <b>Drinking Water</b>		Sampling Location: <b>Anvaya Cove, Morong, Bataan</b>	

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Aug 2024 @08:12PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @08:12PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>27</b>	CFU/mL	< 500	PASSED	Pour Plate	06 Aug 2024 @08:55PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @08:12PM	AHP

Sample ID: <b>S24-H06-068D</b>		Sampling Date: <b>06 Aug 2024</b>	
Sample Description: <b>Golf Kitchen</b>		Sampling Time: <b>11:24 AM</b>	
Sample Matrix: <b>Drinking Water</b>		Sampling Location: <b>Anvaya Cove, Morong, Bataan</b>	

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Aug 2024 @08:15PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @08:15PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>3</b>	CFU/mL	< 500	PASSED	Pour Plate	06 Aug 2024 @08:55PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @08:15PM	AHP

Sample ID: <b>S24-H06-069D</b>		Sampling Date: <b>06 Aug 2024</b>	
Sample Description: <b>Caddie</b>		Sampling Time: <b>11:29 AM</b>	
Sample Matrix: <b>Drinking Water</b>		Sampling Location: <b>Anvaya Cove, Morong, Bataan</b>	

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Aug 2024 @08:18PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @08:18PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>43</b>	CFU/mL	< 500	PASSED	Pour Plate	06 Aug 2024 @08:55PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @08:18PM	AHP

Sample ID: <b>S24-H06-070D</b>		Sampling Date: <b>06 Aug 2024</b>	
Sample Description: <b>Deepwell 8</b>		Sampling Time: <b>11:34 AM</b>	
Sample Matrix: <b>Drinking Water</b>		Sampling Location: <b>Anvaya Cove, Morong, Bataan</b>	

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Aug 2024 @08:21PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @08:21PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>&lt;1</b>	CFU/mL	< 500	PASSED	Pour Plate	06 Aug 2024 @08:55PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @08:21PM	AHP



# Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga  
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga  
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com  
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID: <b>S24-H06-071D</b>		Sampling Date: <b>06 Aug 2024</b>					
Sample Description: <b>Deepwell 9</b>		Sampling Time: <b>11:38 AM</b>					
Sample Matrix: <b>Drinking Water</b>		Sampling Location: <b>Anvaya Cove, Morong, Bataan</b>					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Aug 2024 @08:24PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @08:24PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>&lt;1</b>	CFU/mL	< 500	PASSED	Pour Plate	06 Aug 2024 @08:55PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @08:24PM	AHP

Sample ID: <b>S24-H06-072D</b>		Sampling Date: <b>06 Aug 2024</b>					
Sample Description: <b>N9</b>		Sampling Time: <b>11:43 AM</b>					
Sample Matrix: <b>Drinking Water</b>		Sampling Location: <b>Anvaya Cove, Morong, Bataan</b>					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Aug 2024 @08:27PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @08:27PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>&lt;1</b>	CFU/mL	< 500	PASSED	Pour Plate	06 Aug 2024 @08:55PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @08:27PM	AHP

Sample ID: <b>S24-H06-073D</b>		Sampling Date: <b>06 Aug 2024</b>					
Sample Description: <b>SBV Condo</b>		Sampling Time: <b>11:47 AM</b>					
Sample Matrix: <b>Drinking Water</b>		Sampling Location: <b>Anvaya Cove, Morong, Bataan</b>					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Aug 2024 @08:30PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @08:30PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>6</b>	CFU/mL	< 500	PASSED	Pour Plate	06 Aug 2024 @08:55PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @08:30PM	AHP

Sample ID: <b>S24-H06-074D</b>		Sampling Date: <b>06 Aug 2024</b>					
Sample Description: <b>Reservoir 2</b>		Sampling Time: <b>11:51 AM</b>					
Sample Matrix: <b>Drinking Water</b>		Sampling Location: <b>Anvaya Cove, Morong, Bataan</b>					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Aug 2024 @08:33PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @08:33PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>&lt;1</b>	CFU/mL	< 500	PASSED	Pour Plate	06 Aug 2024 @08:55PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @08:33PM	AHP

Sample ID: <b>S24-H06-075D</b>		Sampling Date: <b>06 Aug 2024</b>					
Sample Description: <b>Deepwell 10</b>		Sampling Time: <b>11:56 AM</b>					
Sample Matrix: <b>Drinking Water</b>		Sampling Location: <b>Anvaya Cove, Morong, Bataan</b>					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Aug 2024 @08:36PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @08:36PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>1</b>	CFU/mL	< 500	PASSED	Pour Plate	06 Aug 2024 @08:55PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @08:36PM	AHP

Sample ID: <b>S24-H06-076D</b>		Sampling Date: <b>06 Aug 2024</b>					
Sample Description: <b>N6B</b>		Sampling Time: <b>12:00 PM</b>					
Sample Matrix: <b>Drinking Water</b>		Sampling Location: <b>Anvaya Cove, Morong, Bataan</b>					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Aug 2024 @08:39PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @08:39PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>&lt;1</b>	CFU/mL	< 500	PASSED	Pour Plate	06 Aug 2024 @08:55PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @08:39PM	AHP



# Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga  
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga  
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com  
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID:	S24-H06-077D				Sampling Date:	06 Aug 2024		
Sample Description:	Deepwell 11				Sampling Time:	12:03 PM		
Sample Matrix:	Drinking Water				Sampling Location:	Anvaya Cove, Morong, Bataan		
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst	
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	06 Aug 2024 @08:42PM	AHP	
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @08:42PM	AHP	
<b>Heterotrophic Plate Count (HPC)</b>	<b>&lt;1</b>	CFU/mL	< 500	PASSED	Pour Plate	06 Aug 2024 @08:55PM	AHP	
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	06 Aug 2024 @08:42PM	AHP	

### Notes & References:

Standard Methods for the Examination of Water and Wastewater, 24th Edition.  
 DOH Administrative Order No. 2017-0010, PNSDW 2017.

#### Certified by:

*Anita H. Pineda* 12 Aug 2024  
 Anita H. Pineda, RMT  
 Medical Technologist, PRC No. 52546

#### Approved by:

*Marin M. Estavillo* 12 Aug 2024  
 Marin M. Estavillo, RCh  
 QA/QC Manager, PRC No.8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without  
 company seal