



# Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga  
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga  
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: [echemenvironmental@gmail.com](mailto:echemenvironmental@gmail.com)  
 Technical: 0917-507-8753 • 0917-164-2944

## TEST REPORT

Client: **Manila Water Philippine Ventures (MWPV)**  
 Address: **Level 3, 2nd Phase, BPO Bldg., UP Town Corporate Center, 216 Katipunan Avenue, Diliman, Quezon City**  
 Contact Person: **Ms. Florisza I. Faustino**  
 COC Number: **2023-C0151**

Test Report No.: **TR-23C-188A**  
 Date and Time Received: **08 Mar 2023 @05:47 PM**  
 Sampled By: **Echem**  
 Report Date: **14 Mar 2023**

Sample ID: **S23-C08-040D** Sampling Date: **08 Mar 2023**  
 Sample Description: **Deepwell 9** Sampling Time: **12:15 PM**  
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	08 Mar 2023 @09:31PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	08 Mar 2023 @09:31PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>&lt;1</b>	CFU/mL	< 500	PASSED	Pour Plate	08 Mar 2023 @10:07PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	08 Mar 2023 @09:31PM	AHP

Sample ID: **S23-C08-042D** Sampling Date: **08 Mar 2023**  
 Sample Description: **Deepwell 10** Sampling Time: **12:30 PM**  
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	08 Mar 2023 @09:37PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	08 Mar 2023 @09:37PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>&lt;1</b>	CFU/mL	< 500	PASSED	Pour Plate	08 Mar 2023 @10:07PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	08 Mar 2023 @09:37PM	AHP

Sample ID: **S23-C08-043D** Sampling Date: **08 Mar 2023**  
 Sample Description: **Deepwell 11** Sampling Time: **12:37 PM**  
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	08 Mar 2023 @09:40PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	08 Mar 2023 @09:40PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>&lt;1</b>	CFU/mL	< 500	PASSED	Pour Plate	08 Mar 2023 @10:07PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	08 Mar 2023 @09:40PM	AHP

Sample ID: **S23-C08-049D** Sampling Date: **08 Mar 2023**  
 Sample Description: **Deepwell 13** Sampling Time: **01:17 PM**  
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	08 Mar 2023 @09:58PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	08 Mar 2023 @09:58PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>2</b>	CFU/mL	< 500	PASSED	Pour Plate	08 Mar 2023 @10:07PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	08 Mar 2023 @09:58PM	AHP



# **Echem** ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga  
Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga  
Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: [echemenvironmental@gmail.com](mailto:echemenvironmental@gmail.com)  
Technical: 0917-507-8753 • 0917-164-2944

## Notes & References:

Standard Methods for the Examination of Water and Wastewater, 23rd Edition.  
DOH Administrative Order No. 2017-0010, PNSDW 2017.

### Certified by:

*Anita H. Pineda* 21 Mar 2023  
**Anita H. Pineda, RMT**  
Medical Technologist, PRC No. 52546

### Approved by:

*May Ann M. Estavillo* 21 Mar 2023  
**May Ann M. Estavillo, RCh**  
QA/QC Manager, PRC No. 8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without  
company seal



# Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga  
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga  
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: [echemenvironmental@gmail.com](mailto:echemenvironmental@gmail.com)  
 Technical: 0917-507-8753 • 0917-164-2944

## TEST REPORT

Client: **Manila Water Philippine Ventures (MWPV)** Test Report No.: **TR-23C-188A**  
 Address: **Level 3, 2nd Phase, BPO Bldg., UP Town Corporate Center, 216 Katipunan Avenue, Diliman, Quezon City** Date and Time Received: **08 Mar 2023@05:47 PM**  
 Contact Person: **Ms. Florisza I. Faustino** Sampled By: **ECHEM**  
 COC Number: **2023-C0151** Report Date: **14 Mar 2023**

Sample ID: **S23-C08-041D** Sampling Date: **08 Mar 2023**  
 Sample Description: **N9** Sampling Time: **12:21 PM**  
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	08 Mar 2023 @09:34PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	08 Mar 2023 @09:34PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>&lt;1</b>	CFU/mL	< 500	PASSED	Pour Plate	08 Mar 2023 @10:07PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	08 Mar 2023 @09:34PM	AHP

Sample ID: **S23-C08-044D** Sampling Date: **08 Mar 2023**  
 Sample Description: **SBV Condo** Sampling Time: **12:42 PM**  
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	08 Mar 2023 @09:43PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	08 Mar 2023 @09:43PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>&lt;1</b>	CFU/mL	< 500	PASSED	Pour Plate	08 Mar 2023 @10:07PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	08 Mar 2023 @09:43PM	AHP

Sample ID: **S23-C08-045D** Sampling Date: **08 Mar 2023**  
 Sample Description: **N6B** Sampling Time: **12:46 PM**  
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	08 Mar 2023 @09:46PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	08 Mar 2023 @09:46PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>&lt;1</b>	CFU/mL	< 500	PASSED	Pour Plate	08 Mar 2023 @10:07PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	08 Mar 2023 @09:46PM	AHP

Sample ID: **S23-C08-047D** Sampling Date: **08 Mar 2023**  
 Sample Description: **S1** Sampling Time: **01:01 PM**  
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	08 Mar 2023 @09:52PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	08 Mar 2023 @09:52PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>&lt;1</b>	CFU/mL	< 500	PASSED	Pour Plate	08 Mar 2023 @10:07PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	08 Mar 2023 @09:52PM	AHP



# Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga  
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga  
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: [echemenvironmental@gmail.com](mailto:echemenvironmental@gmail.com)  
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID:	<b>S23-C08-048D</b>	Sampling Date:	<b>08 Mar 2023</b>
Sample Description:	<b>S2A</b>	Sampling Time:	<b>01:08 PM</b>
Sample Matrix:	<b>Drinking Water</b>	Sampling Location:	<b>Anvaya Cove, Morong, Bataan</b>

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	08 Mar 2023 @09:55PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	08 Mar 2023 @09:55PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>&lt;1</b>	CFU/mL	< 500	PASSED	Pour Plate	08 Mar 2023 @10:07PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	08 Mar 2023 @09:55PM	AHP

### Notes & References:

Standard Methods for the Examination of Water and Wastewater, 23rd Edition.  
 DOH Administrative Order No. 2017-0010, PNSDW 2017.

#### Certified by:

*Anita H. Pineda* 21 Mar 2023

**Anita H. Pineda, RMT**  
 Medical Technologist, PRC No. 52546

#### Approved by:

*May Ann M. Estavillo* 21 Mar 2023  
**May Ann M. Estavillo, RCh**  
 QA/QC Manager, PRC No. 8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without  
 company seal



# Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga  
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga  
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: [echemenvironmental@gmail.com](mailto:echemenvironmental@gmail.com)  
 Technical: 0917-507-8753 • 0917-164-2944

## TEST REPORT

Client: **Manila Water Philippine Ventures (MWPV)**  
 Address: **Level 3, 2nd Phase, BPO Bldg., UP Town Corporate Center, 216 Katipunan Avenue, Diliman, Quezon City**  
 Contact Person: **Ms. Florisza I. Faustino**  
 COC Number: **2023-C0151**

Test Report No.: **TR-23C-188A**  
 Date and Time Received: **08 Mar 2023@05:47 PM**  
 Sampled By: **ECHEM**  
 Report Date: **14 Mar 2023**


Sample ID:	<b>S23-C08-046D</b>	Sampling Date:	<b>08 Mar 2023</b>
Sample Description:	<b>Reservoir 2</b>	Sampling Time:	<b>12:50 PM</b>
Sample Matrix:	<b>Drinking Water</b>	Sampling Location:	<b>Anvaya Cove, Morong, Bataan</b>

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	08 Mar 2023 @09:49PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	08 Mar 2023 @09:49PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>&lt;1</b>	CFU/mL	< 500	PASSED	Pour Plate	08 Mar 2023 @10:07PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	08 Mar 2023 @09:49PM	AHP

### Notes & References:

Standard Methods for the Examination of Water and Wastewater, 23rd Edition.  
 DOH Administrative Order No. 2017-0010, PNSDW 2017.

#### Certified by:

  
**Anita H. Pineda, RMT**  
 Medical Technologist, PRC No. 52546

#### Approved by:

  
**May Ann M. Estavillo, RCh**  
 QA/QC Manager, PRC No. 8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without  
company seal



# Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga  
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga  
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: [ecchemenvironmental@gmail.com](mailto:ecchemenvironmental@gmail.com)  
 Technical: 0917-507-8753 • 0917-164-2944

## TEST REPORT

Client: **Manila Water Philippine Ventures (MWPV)** Test Report No.: **TR-23C-188B**  
 Address: **Level 3, 2nd Phase, BPO Bldg., UP Town Corporate Center, 216 Katipunan Ave., Dillman, Quezon City** Date and Time Received: **08 Mar 2023 @05:47PM**  
 Contact Person: **Ms. Florisza I. Faustino** Sampled By: **ECHEM**  
 COC Number: **2023-C0151** Report Date: **30 Mar 2023**

Sample ID: **S23-C08-049D** Sampling Date: **08 Mar 2023**  
 Sample Description: **Deepwell 13** Sampling Time: **01:17 PM**  
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
*Arsenic	<0.005	mg/L	0.01	Inductively Coupled Plasma-Optical Emission Spectroscopy	14 Mar 2023	---
*Cadmium	<0.001	mg/L	0.003	Inductively Coupled Plasma-Optical Emission Spectroscopy	14 Mar 2023	---
*Lead	<0.005	mg/L	0.01	Inductively Coupled Plasma-Optical Emission Spectroscopy	14 Mar 2023	---
Iron	0.009	mg/L	1.0	Phenanthroline	09 Mar 2023	RRM
Manganese	<0.10	mg/L	0.40	Persulfate	09 Mar 2023	RRM
Chlorine, Residual	1.0	mg/L	0.30-1.50	Colorimetric	08 Mar 2023	MGF
Color, Apparent	100 @pH 6.70	CU	10	Visual Comparison	09 Mar 2023	TGG
Nitrate as NO <sub>3</sub> -N	<0.10	mg/L	50	Colorimetric, Brucine	09 Mar 2023	RRM
Odor	No Objectionable Odor	---	No Objectionable Odor	Threshold Odor Test	09 Mar 2023	TGG
pH (on-site)	6.71 @27.1°C	---	6.5-8.5	Electrometric	08 Mar 2023	MGF
Sulfate	<1.0	mg/L	250	Turbidimetric	13 Mar 2023	RRM
Taste	No Objectionable Taste	---	No Objectionable Taste	Flavor Threshold Test	09 Mar 2023	TGG
Total Dissolved Solids (TDS)	221	mg/L	600	Gravimetric, Dried @180°C	14 Mar 2023	TGG
Turbidity	2.4	NTU	5.0	Colorimetric	09 Mar 2023	RRM

### Notes & References:

Standard Methods for the Examination of Water and Wastewater, 23rd Edition.  
 DOH Administrative Order No. 2017-0010, PNSDW 2017.  
 Test Methods for Evaluating Solid Wastes, Vol 1A, USEPA, Third Edition.  
 \* Subcontracted to CRL Environmental Corp.

#### Certified by:

*Lovely Grace D. Montoya* 30 Mar 2023  
 Lovely Grace D. Montoya, RCh  
 Chemist, PRC No. 13651

#### Approved by:

*May Ann M. Estavillo* 31 Mar 2023  
 May Ann M. Estavillo, RCh  
 QA/QC Manager, PRC No. 8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without  
company seal

# Results of Analyses

## ECHEM ENVIRONMENTAL TESTING LABORATORY CORPORATION

G/F ASCORP Bldg., Dolores, City of San Fernando, Pampanga  
 Contact No.: 09108000781

SN: F00105767.014



Date Received:

03/10/2023

Lab No.: P00136633



**Project Name:** Not Supplied

**Attention:** Ms. May Ann M. Estavillo

Test Description	Results	Units	Test Methods	Date Analyzed	By	Ref
<b>Sample No.: P00136633-17</b>			<b>Date Sampled: 03-08-23 13:17</b>			
<b>Sample ID: S23 - C08 - 049D</b>			<b>Matrix: Drinking Water</b>			
<b>-Metals-</b>						
Arsenic	< 0.005	mg/L	ICP - OES (SMEWW 3120B / USEPA 6010B)	03/14/23	PPG	
Cadmium	< 0.001	mg/L	ICP - OES (SMEWW 3120B / USEPA 6010B)	03/14/23	PPG	
Lead	< 0.005	mg/L	ICP - OES (SMEWW 3120B / USEPA 6010B)	03/14/23	PPG	

>>> end of result set for Sample No.:P00136633-17 <<<

>>> end of result set for Lab No.:P00136633; Total no. of sample analyzed: 1 <<<

Results are reported "as received basis".

ICP - OES = Inductively Coupled Plasma - Optical Emission Spectroscopy

Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 23rd Edition.

Test Methods for Evaluating Solid Wastes, Vol 1A, USEPA, Third Edition

FOR REFERENCE ONLY



Analyzed by:

Date: 03/23/2023

Prescilla P. Galbonton  
PRC License No.: 679  
Chemical Testing

Certified by:

Date: 03/23/2023

Ronald G. Espiritu  
PRC License No.: 9248  
Chemical Testing

Date: 03/23/2023

Juliana C. Oriña  
PRC License No.: 8774  
Chemical Testing

Date: 03/23/2023

Chas C. Arroyo  
PRC License No.: 6701  
Chemical Testing



SN: F00105767.014

Disclaimer: This report pertains only to the samples investigated and does not necessarily apply to other apparently identical or similar materials. This report is submitted for the exclusive use of the customer to whom it is addressed. Any reproduction of this report or use of this Laboratory's name for advertising or publicity purpose without authorization is prohibited. This analytical report is NOT VALID without the official dry seal of CRL Environmental Corporation.

FOR REFERENCE ONLY

