



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

DOH Accreditation No.03-002-21-LW-2 Valid until December 31, 2023

DENR C.R.No. 074/2021 Valid until September 28, 2024

TEST REPORT

Client: **Manila Water Philippine Ventures (MWPV)**
 Address: **Level 3 2nd Phase, BPO Bldg., UP Town Corporate Center, 216 Katipunan Ave., Diliman, Quezon City**
 Contact Person: **Ms. Florisza I. Faustino**
 COC Number: **2022-E0033**

Test Report No.: **TR-22E-173**
 Date and Time Received: **02 May 2022 @03:30PM**
 Sampled By: **ECEM**
 Report Date: **16 May 2022**

Sample ID:	S22-E02-122D	Sampling Date:	02 May 2022
Sample Description:	N5	Sampling Time:	10:15 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 May 2022 @04:20PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @04:20PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 May 2022 @05:54PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @04:20PM	AHP

Sample ID:	S22-E02-123D	Sampling Date:	02 May 2022
Sample Description:	SRCC Boston	Sampling Time:	10:22 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 May 2022 @04:23PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @04:23PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 May 2022 @05:54PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @04:23PM	AHP

Sample ID:	S22-E02-124D	Sampling Date:	02 May 2022
Sample Description:	N4	Sampling Time:	10:31 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 May 2022 @04:26PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @04:26PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 May 2022 @05:54PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @04:26PM	AHP

Sample ID:	S22-E02-125D	Sampling Date:	02 May 2022
Sample Description:	N7	Sampling Time:	10:42 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 May 2022 @04:29PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @04:29PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 May 2022 @05:54PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @04:29PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID:	S22-E02-126D	Sampling Date:	02 May 2022
Sample Description:	Tulfo Residence	Sampling Time:	10:53 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 May 2022 @04:32PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @04:32PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 May 2022 @05:54PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @04:32PM	AHP

Sample ID:	S22-E02-128D	Sampling Date:	02 May 2022
Sample Description:	N2	Sampling Time:	11:08 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 May 2022 @04:38PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @04:38PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 May 2022 @05:54PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @04:38PM	AHP

Sample ID:	S22-E02-129D	Sampling Date:	02 May 2022
Sample Description:	N1	Sampling Time:	11:16 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 May 2022 @04:41PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @04:41PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 May 2022 @05:54PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @04:41PM	AHP

Sample ID:	S22-E02-131D	Sampling Date:	02 May 2022
Sample Description:	BNC Pawikan	Sampling Time:	11:38 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 May 2022 @04:47PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @04:47PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 May 2022 @05:54PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @04:47PM	AHP

Sample ID:	S22-E02-132D	Sampling Date:	02 May 2022
Sample Description:	Beehcroft	Sampling Time:	11:47 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 May 2022 @04:50PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @04:50PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 May 2022 @05:54PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @04:50PM	AHP



Echem

ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID: S22-E02-133D	Sampling Date: 02 May 2022
Sample Description: Villas	Sampling Time: 11:53 AM
Sample Matrix: Drinking Water	Sampling Location: Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 May 2022 @04:53PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @04:53PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 May 2022 @05:54PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @04:53PM	AHP

Sample ID: S22-E02-134D	Sampling Date: 02 May 2022
Sample Description: BNC Backdoor	Sampling Time: 11:59 AM
Sample Matrix: Drinking Water	Sampling Location: Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 May 2022 @04:56PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @04:56PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 May 2022 @05:54PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @04:56PM	AHP

Sample ID: S22-E02-136D	Sampling Date: 02 May 2022
Sample Description: Sports Center Common Area	Sampling Time: 12:15 PM
Sample Matrix: Drinking Water	Sampling Location: Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 May 2022 @05:02PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @05:02PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 May 2022 @05:54PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @05:02PM	AHP

Sample ID: S22-E02-137D	Sampling Date: 02 May 2022
Sample Description: Sports Center Kitchen	Sampling Time: 12:20 PM
Sample Matrix: Drinking Water	Sampling Location: Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 May 2022 @05:05PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @05:05PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 May 2022 @05:54PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @05:05PM	AHP

Sample ID: S22-E02-138D	Sampling Date: 02 May 2022
Sample Description: Golf Kitchen	Sampling Time: 12:30 PM
Sample Matrix: Drinking Water	Sampling Location: Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 May 2022 @05:08PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @05:08PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 May 2022 @05:54PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @05:08PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID:	S22-E02-139D	Sampling Date:	02 May 2022
Sample Description:	Cddie	Sampling Time:	12:38 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 May 2022 @05:11PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @05:11PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 May 2022 @05:54PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @05:11PM	AHP

Sample ID:	S22-E02-142D	Sampling Date:	02 May 2022
Sample Description:	N9	Sampling Time:	01:03 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 May 2022 @05:20PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @05:20PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 May 2022 @05:54PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @05:20PM	AHP

Sample ID:	S22-E02-144D	Sampling Date:	02 May 2022
Sample Description:	SBV Condo	Sampling Time:	01:21 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 May 2022 @05:26PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @05:26PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 May 2022 @05:54PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @05:26PM	AHP

Sample ID:	S22-E02-145D	Sampling Date:	02 May 2022
Sample Description:	N6B	Sampling Time:	01:28 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 May 2022 @05:29PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @05:29PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 May 2022 @05:54PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @05:29PM	AHP

Notes & References:

Standard Methods for the Examination of Water and Wastewater, 23rd Edition.
DOH Administrative Order No. 2017-0010, PNSDW 2017.



echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Certified by:

Anita H. Pineda 17 May 2024

Anita H. Pineda, RMT

Medical Technologist, PRC No. 52546

Approved by:

May Ann M. Estavillo 17 May 2024

May Ann M. Estavillo, RCh

QA/QC Manager, PRC No. 8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
company seal



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-164-2927 • 0917-164-2944

DOH Accreditation No.03-002-21-LW-2 Valid until December 31, 2023
 DENR C.R.No. 074/2021 Valid until September 28, 2024

TEST REPORT

Client: **Manila Water Philippine Ventures (MWPV)** Test Report No.: **TR-22E-173**
 Address: **Level 3 2nd Phase, BPO Bldg., UP Town Corporate Center, 216 Katipunan Ave., Dilliman, Quezon City** Date and Time Received: **02 May 2022 @03:30PM**
 Contact Person: **Ms. Florisza I. Faustino** Sampled By: **ECHEM**
 COC Number: **2022-E0033** Report Date: **16 May 2022**

Sample ID: **S22-E02-127D** Sampling Date: **02 May 2022**
 Sample Description: **Reservoir 1** Sampling Time: **11:00 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MFTT Thermotolerant Coliform Test (EC Medium)	02 May 2022 @04:35PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @04:35PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 May 2022 @05:54PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @04:35PM	AHP


Sample ID: **S22-E02-146D** Sampling Date: **02 May 2022**
 Sample Description: **Reservoir 2** Sampling Time: **01:37 PM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MFTT Thermotolerant Coliform Test (EC Medium)	02 May 2022 @05:32PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @05:32PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 May 2022 @05:54PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @05:32PM	AHP


Notes & References:

Standard Methods for the Examination of Water and Wastewater, 23rd Edition.
 DOH Administrative Order No. 2017-0010, PNSDW 2017.

Certified by:


Anital H. Pineda, RMT
 Medical Technologist, PRC No. 52546

Approved by:


May Ann M. Estavillo, RCh
 QA/QC Manager, PRC No. 8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
 company seal



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

DOH Accreditation No.03-002-21-LW-2 Valid until December 31, 2023

DENR C.R.No. 074/2021 Valid until September 28, 2024

TEST REPORT

Client: **Manila Water Philippine Ventures (MWPV)**

Address: **Level 3 2nd Phase, BPO Bldg., UP Town Corporate Center, 216 Katipunan Ave., Diliman, Quezon City**

Contact Person: **Ms. Florisza I. Faustino**

COC Number: **2022-E0033**

Test Report No.: **TR-22E-173**

Date and Time Received: **02 May 2022 @03:30PM**

Sampled By: **ECHEM**

Report Date: **16 May 2022**

Sample ID:	S22-E02-130D	Sampling Date:	02 May 2022
Sample Description:	Deepwell 7	Sampling Time:	11:28 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 May 2022 @04:44PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @04:44PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 May 2022 @05:54PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @04:44PM	AHP

Sample ID:	S22-E02-135D	Sampling Date:	02 May 2022
Sample Description:	Deepwell 5	Sampling Time:	12:10 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 May 2022 @04:59PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @04:59PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 May 2022 @05:54PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @04:59PM	AHP

Sample ID:	S22-E02-140D	Sampling Date:	02 May 2022
Sample Description:	Deepwell 8	Sampling Time:	12:45 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 May 2022 @05:14PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @05:14PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 May 2022 @05:54PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @05:14PM	AHP

Sample ID:	S22-E02-141D	Sampling Date:	02 May 2022
Sample Description:	Deepwell 9	Sampling Time:	12:54 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 May 2022 @05:17PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @05:17PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 May 2022 @05:54PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @05:17PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID:	S22-E02-143D	Sampling Date:	02 May 2022
Sample Description:	Deepwell 10	Sampling Time:	01:15 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 May 2022 @05:23PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @05:23PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 May 2022 @05:54PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @05:23PM	AHP


Sample ID:	S22-E02-147D	Sampling Date:	02 May 2022
Sample Description:	Depwell 11	Sampling Time:	01:43 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 May 2022 @05:35PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @05:35PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 May 2022 @05:54PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 May 2022 @05:35PM	AHP


Notes & References:

Standard Methods for the Examination of Water and Wastewater, 23rd Edition.
DOH Administrative Order No. 2017-0010, PNSDW 2017.

Certified by:


Anita H. Pineda, RMT
Medical Technologist, PRC No. 52546

Approved by:


May Ann M. Estavillo, RCh
QA/QC Manager, PRC No.8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
company seal