



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-164-2927 • 0917-164-2944

DOH Accreditation No.03-002-21-LW-2 Valid until December 31, 2023
 DENR C.R.No. 074/2021 Valid until September 28, 2024

TEST REPORT

Client: **Manila Water Philippine Ventures (MWPV)** Test Report No.: **TR-221-152**
 Address: **Level 3, 2nd Phase, BPO Bldg., UP Town Corporate Center, 216 Katipunan Avenue, Diliman Quezon City** Date and Time Received: **02 Sep 2022 @04:25PM**
 Contact Person: **Ms. Florisza I. Faustino** Sampled By: **ECHEM**
 COC Number: **2022-10027** Report Date: **15 Sep 2022**

Sample ID: **S22-102-021D** Sampling Date: **02 Sep 2022**
 Sample Description: **N5** Sampling Time: **10:40 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Sep 2022 @06:15PM	AHP
Fecal Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @06:15PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Sep 2022 @07:40PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @06:15PM	AHP

Sample ID: **S22-102-022D** Sampling Date: **02 Sep 2022**
 Sample Description: **SRCC Boston** Sampling Time: **10:48 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Sep 2022 @06:18PM	AHP
Fecal Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @06:18PM	AHP
Heterotrophic Plate Count (HPC)	2	CFU/mL	< 500	PASSED	Pour Plate	02 Sep 2022 @07:40PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @06:18PM	AHP

Sample ID: **S22-102-023D** Sampling Date: **02 Sep 2022**
 Sample Description: **N4** Sampling Time: **10:57 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Sep 2022 @06:22PM	AHP
Fecal Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @06:22PM	AHP
Heterotrophic Plate Count (HPC)	2	CFU/mL	< 500	PASSED	Pour Plate	02 Sep 2022 @07:40PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @06:22PM	AHP

Sample ID: **S22-102-024D** Sampling Date: **02 Sep 2022**
 Sample Description: **N7** Sampling Time: **11:10 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Sep 2022 @06:25PM	AHP
Fecal Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @06:25PM	AHP
Heterotrophic Plate Count (HPC)	1	CFU/mL	< 500	PASSED	Pour Plate	02 Sep 2022 @07:40PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @06:25PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID:	S22-I02-025D	Sampling Date:	02 Sep 2022
Sample Description:	Tulfo Residence	Sampling Time:	11:17 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Sep 2022 @06:28PM	AHP
Fecal Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @06:28PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Sep 2022 @07:40PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @06:28PM	AHP

Sample ID:	S22-I02-027D	Sampling Date:	02 Sep 2022
Sample Description:	N2	Sampling Time:	11:27 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Sep 2022 @06:34PM	AHP
Fecal Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @06:34PM	AHP
Heterotrophic Plate Count (HPC)	52	CFU/mL	< 500	PASSED	Pour Plate	02 Sep 2022 @07:40PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @06:34PM	AHP

Sample ID:	S22-I02-028D	Sampling Date:	02 Sep 2022
Sample Description:	N1	Sampling Time:	11:36 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Sep 2022 @06:37PM	AHP
Fecal Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @06:37PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Sep 2022 @07:40PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @06:37PM	AHP

Sample ID:	S22-I02-029D	Sampling Date:	02 Sep 2022
Sample Description:	N3	Sampling Time:	11:42 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Sep 2022 @06:40PM	AHP
Fecal Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @06:40PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Sep 2022 @07:40PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @06:40PM	AHP

Sample ID:	S22-I02-031D	Sampling Date:	02 Sep 2022
Sample Description:	BNC Pawikan	Sampling Time:	12:04 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Sep 2022 @06:46PM	AHP
Fecal Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @06:46PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Sep 2022 @07:40PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @06:46PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID:	S22-I02-032D	Sampling Date:	02 Sep 2022
Sample Description:	Beechcroft	Sampling Time:	12:10 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Sep 2022 @06:49PM	AHP
Fecal Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @06:49PM	AHP
Heterotrophic Plate Count (HPC)	3	CFU/mL	< 500	PASSED	Pour Plate	02 Sep 2022 @07:40PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @06:49PM	AHP

Sample ID:	S22-I02-033D	Sampling Date:	02 Sep 2022
Sample Description:	Villas	Sampling Time:	12:15 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Sep 2022 @06:51PM	AHP
Fecal Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @06:51PM	AHP
Heterotrophic Plate Count (HPC)	1	CFU/mL	< 500	PASSED	Pour Plate	02 Sep 2022 @07:40PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @06:51PM	AHP

Sample ID:	S22-I02-034D	Sampling Date:	02 Sep 2022
Sample Description:	BNC Backdoor	Sampling Time:	12:19 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Sep 2022 @06:54PM	AHP
Fecal Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @06:54PM	AHP
Heterotrophic Plate Count (HPC)	2	CFU/mL	< 500	PASSED	Pour Plate	02 Sep 2022 @07:40PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @06:54PM	AHP

Sample ID:	S22-I02-036D	Sampling Date:	02 Sep 2022
Sample Description:	Sports Center Common Area	Sampling Time:	12:36 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Sep 2022 @07:00PM	AHP
Fecal Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @07:00PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Sep 2022 @07:40PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @07:00PM	AHP

Sample ID:	S22-I02-037D	Sampling Date:	02 Sep 2022
Sample Description:	Sports Center Kitchen	Sampling Time:	12:40 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Sep 2022 @07:03PM	AHP
Fecal Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @07:03PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Sep 2022 @07:40PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @07:03PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID:	S22-I02-038D	Sampling Date:	02 Sep 2022
Sample Description:	Golf Kitchen	Sampling Time:	12:45 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Sep 2022 @07:06PM	AHP
Fecal Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @07:06PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Sep 2022 @07:40PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @07:06PM	AHP

Sample ID:	S22-I02-039D	Sampling Date:	02 Sep 2022
Sample Description:	Caddie	Sampling Time:	12:54 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Sep 2022 @07:10PM	AHP
Fecal Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @07:10PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Sep 2022 @07:40PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @07:10PM	AHP

Sample ID:	S22-I02-042D	Sampling Date:	02 Sep 2022
Sample Description:	N9	Sampling Time:	01:28 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Sep 2022 @07:19PM	AHP
Fecal Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @07:19PM	AHP
Heterotrophic Plate Count (HPC)	1	CFU/mL	< 500	PASSED	Pour Plate	02 Sep 2022 @07:40PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @07:19PM	AHP

Sample ID:	S22-I02-045D	Sampling Date:	02 Sep 2022
Sample Description:	N6B	Sampling Time:	01:42 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Sep 2022 @07:26PM	AHP
Fecal Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @07:26PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Sep 2022 @07:40PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @07:26PM	AHP

Sample ID:	S22-I02-047D	Sampling Date:	02 Sep 2022
Sample Description:	SBV Condo	Sampling Time:	01:52 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Sep 2022 @07:32PM	AHP
Fecal Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @07:32PM	AHP
Heterotrophic Plate Count (HPC)	2	CFU/mL	< 500	PASSED	Pour Plate	02 Sep 2022 @07:40PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @07:32PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Notes & References:

Standard Methods for the Examination of Water and Wastewater, 23rd Edition.

DOH Administrative Order No. 2017-0010, PNSDW 2017.

Certified by:

Anita H. Pineda 16 Sep 2022

Anita H. Pineda, RMT

Medical Technologist, PRC No. 52546

Approved by:

May Ann M. Estavillo 16 Sep 2022

May Ann M. Estavillo, RCh

QA/QC Manager, PRC No. 8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
company seal



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-164-2927 • 0917-164-2944

DOH Accreditation No.03-002-21-LW-2 Valid until December 31, 2023
 DENR C.R.No. 074/2021 Valid until September 28, 2024

TEST REPORT

Client: **Manila Water Philippine Ventures (MWPV)** Test Report No.: **TR-221-152**
 Address: **Level 3, 2nd Phase, BPO Bldg., UP Town Corporate Center, 216 Katipunan Avenue, Diliman Quezon City** Date and Time Received: **02 Sep 2022 @04:25PM**
 Contact Person: **Ms. Florisza I. Faustino** Sampled By: **ECHEM**
 COC Number: **2022-I0027** Report Date: **15 Sep 2022**

Sample ID: **S22-I02-026D** Sampling Date: **02 Sep 2022**
 Sample Description: **Reservoir 1** Sampling Time: **11:21 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Sep 2022 @06:31PM	AHP
Fecal Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @06:31PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Sep 2022 @07:40PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @06:31PM	AHP

Sample ID: **S22-I02-046D** Sampling Date: **02 Sep 2022**
 Sample Description: **Reservoir 2** Sampling Time: **01:48 PM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Sep 2022 @07:29PM	AHP
Fecal Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @07:29PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Sep 2022 @07:40PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @07:29PM	AHP

Notes & References:

Standard Methods for the Examination of Water and Wastewater, 23rd Edition.
 DOH Administrative Order No. 2017-0010, PNSDW 2017.

Certified by:

Anita H. Pineda 13 Sep 2022
Anita H. Pineda, RMT
 Medical Technologist, PRC No. 52546

Approved by:

May Ann M. Estavillo 16 Sep 2022
May Ann M. Estavillo, RCh
 QA/QC Manager, PRC No.8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
 company seal



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795
 Technical: 0917-164-2927 • 0917-164-2944
 Email: echemenvironmental@gmail.com

DOH Accreditation No.03-002-21-LW-2 Valid until December 31, 2023
 DENR C.R.No. 074/2021 Valid until September 28, 2024

TEST REPORT

Client: **Manila Water Philippine Ventures (MWPV)**

Address: **Level 3, 2nd Phase, BPO Bldg., UP Town Corporate Center, 216 Katipunan Avenue, Diliman Quezon City**

Contact Person: **Ms. Florisza I. Faustino**

COC Number: **2022-I0027**

Test Report No.: **TR-221-152**

Date and Time Received: **02 Sep 2022 @04:25PM**

Sampled By: **ECHEM**

Report Date: **15 Sep 2022**

Sample ID:	S22-I02-030D	Sampling Date:	02 Sep 2022
Sample Description:	Deepwell 7	Sampling Time:	11:53 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Sep 2022 @06:43PM	AHP
Fecal Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @06:43PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Sep 2022 @07:40PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @06:43PM	AHP

Sample ID:	S22-I02-035D	Sampling Date:	02 Sep 2022
Sample Description:	Deepwell 5	Sampling Time:	12:28 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Sep 2022 @06:57PM	AHP
Fecal Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @06:57PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Sep 2022 @07:40PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @06:57PM	AHP

Sample ID:	S22-I02-040D	Sampling Date:	02 Sep 2022
Sample Description:	Deepwell 8	Sampling Time:	01:10 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Sep 2022 @07:13PM	AHP
Fecal Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @07:13PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Sep 2022 @07:40PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @07:13PM	AHP

Sample ID:	S22-I02-041D	Sampling Date:	02 Sep 2022
Sample Description:	Deepwell 9	Sampling Time:	01:19 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Sep 2022 @07:16PM	AHP
Fecal Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @07:16PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Sep 2022 @07:40PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @07:16PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID:	S22-I02-043D	Sampling Date:	02 Sep 2022
Sample Description:	Deepwell 10	Sampling Time:	01:30 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Sep 2022 @07:21PM	AHP
Fecal Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @07:21PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Sep 2022 @07:40PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @07:21PM	AHP

Sample ID:	S22-I02-044D	Sampling Date:	02 Sep 2022
Sample Description:	Deepwell 11	Sampling Time:	01:39 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Sep 2022 @07:23PM	AHP
Fecal Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @07:23PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Sep 2022 @07:40PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2022 @07:23PM	AHP

Notes & References:

Standard Methods for the Examination of Water and Wastewater, 23rd Edition.
DOH Administrative Order No. 2017-0010, PNSDW 2017.

Certified by:

Anita H. Pineda 16 Sep 2022

Anita H. Pineda, RMT

Medical Technologist, PRC No. 52546

Approved by:

May Ann M. Estavillo 16 Sep 2022

May Ann M. Estavillo, RCh

QA/QC Manager, PRC No.8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
company seal