



ESTATE WATER

**A MANILA WATER
PHILIPPINE VENTURES DIVISION**

JULY 2019

Facility Name	Residual Chlorine	Total Coliform	Fecal Coliform	E-Coli	HPC	Remarks
	0.3 – 1.5	<1.1	<1.1	Negative	<500	
DW No. 5	n/a	<1.1	<1.1	Negative	28	Passed
DW No. 6	n/a	<1.1	<1.1	Negative	24	Passed
DW No. 7	n/a	<1.1	<1.1	Negative	<1	Passed
Reservoir No.1	0.3	<1.1	<1.1	Negative	<1	Passed
DW No. 8	n/a	<1.1	<1.1	Negative	87	Passed
DW No. 9	n/a	<1.1	<1.1	Negative	<1	Passed
DW No. 10	n/a	<1.1	<1.1	Negative	<1	Passed
DW No. 11	n/a	<1.1	<1.1	Negative	1	Passed
Reservoir No.2	0.4	<1.1	<1.1	Negative	1	Passed

ANALYSIS DETAILS	Sampling Date	07-04-19	Re-sampling Date	
	Receiving Date of Result	07-25-19	Location	
	Lab Analysis Control No.	P00094707-01/30	Lab Analysis/Control No.	

AUGUST 2019

Facility Name	Residual Chlorine	Total Coliform	Fecal Coliform	E-Coli	HPC	Remarks
	0.3 – 1.5	<1.1	<1.1	Negative	<500	
DW No. 5	n/a	<1.1	<1.1	Negative	9.5	Passed
DW No. 6	n/a	<1.1	<1.1	Negative	<1	Passed
DW No. 7	n/a	<1.1	<1.1	Negative	<1	Passed
Reservoir No.1	0.3	<1.1	<1.1	Negative	<1	Passed
DW No. 8	n/a	<1.1	<1.1	Negative	<1	Passed
DW No. 9	n/a	<1.1	<1.1	Negative	2	Passed
DW No. 10	n/a	<1.1	<1.1	Negative	<1	Passed
DW No. 11	n/a	<1.1	<1.1	Negative	<1	Passed
Reservoir No.2	0.2	<1.1	<1.1	Negative	<1	Passed

ANALYSIS DETAILS	Sampling Date	08-16-19	Re-sampling Date	08-28-19
	Receiving Date of Result	09-03-19	Location	Deepwell No.9
	Lab Analysis Control No.	P00096274-01/29	Lab Analysis/Control No.	P00096274-22

SEPTEMBER 2019

Facility Name	Residual Chlorine	Total Coliform	Fecal Coliform	E-Coli	HPC	Remarks
	0.3 – 1.5	<1.1	<1.1	Negative	<500	
DW No. 5	n/a	<1.1	<1.1	Negative	2.5	Passed
DW No. 6	n/a	<1.1	<1.1	Negative	<1	Passed
DW No. 7	n/a	<1.1	<1.1	Negative	5.5	Passed
Reservoir No.1	0.2	<1.1	<1.1	Negative	2	Passed
DW No. 8	n/a	<1.1	<1.1	Negative	<1	Passed
DW No. 9	n/a	<1.1	<1.1	Negative	<1	Passed
DW No. 10	n/a	<1.1	<1.1	Negative	<1	Passed
DW No. 11	n/a	<1.1	<1.1	Negative	<1	Passed
Reservoir No.2	0.2	<1.1	<1.1	Negative	<1	Passed

ANALYSIS DETAILS	Sampling Date	09-12-19	Re-sampling Date	
	Receiving Date of Result	10-01-19	Location	
	Lab Analysis Control No.	P00097910-01/29	Lab Analysis/Control No.	